

LEAD ANALYSIS RESULTS FROM INITIAL DRINKING WATER SAMPLING ACTIVITIES (November 20 and 21, 2018)

School	Room No./Location	Sample ID	Fixture Type	Sample Date	Result (ppb)	Notes
Bethesda ES	Kitchen	KT-05-FD	Kitchen Tap	11/21/2018	ND	3-bay kitchen sink furthest right, closest to door
Bethesda ES	Kitchen	KT-05-FL	Kitchen Tap	11/21/2018	ND	3-bay kitchen sink furthest right, closest to door
Bethesda ES	310	SOW-02-FD	Sink with Bubbler	11/21/2018	0.764	
Bethesda ES	310	SOW-02-FD-D	Sink with Bubbler	11/21/2018	0.723	
Bethesda ES	310	SOW-02-FL	Sink with Bubbler	11/21/2018	0.524	
Bethesda ES	115	SOW-03-FD	Sink with Bubbler	11/21/2018	ND	
Bethesda ES	115	SOW-03-FL	Sink with Bubbler	11/21/2018	ND	
Bethesda ES	Hallway	WC-04-FD	Bubbler with Cooler	11/21/2018	ND	Across from Room 702A, bubbler without bottle filler (bubbler on the right)
Bethesda ES	Hallway	WC-04-FL	Bubbler with Cooler	11/21/2018	ND	Across from Room 702A, bubbler without bottle filler (bubbler on the right)
Bethesda ES		FB-01	Field Blank	11/29/2018	ND	
Brentwood HS	Kitchen	KT-2-FD	Kitchen Tap	11/20/2018	1.53	
Brentwood HS	Kitchen	KT-3-FL	Kitchen Tap	11/20/2018	0.620	
Brentwood HS	Hallway	WC-4-FD	Bubbler with Cooler	11/20/2018	ND	
Brentwood HS	Hallway	WC-5-FL	Bubbler with Cooler	11/20/2018	ND	
Brentwood HS	Hallway	WC-6-FD	Bubbler with Cooler	11/20/2018	ND	
Brentwood HS	Hallway	WC-7-FL	Bubbler with Cooler	11/20/2018	ND	
Brentwood HS	Hallway	WC-7-FL-D	Bubbler with Cooler	11/20/2018	ND	
Brentwood HS	Hallway	WC-8-FD	Bubbler with Cooler	11/20/2018	ND	
Brentwood HS	Hallway	WC-9-FL	Bubbler with Cooler	11/20/2018	ND	
Brentwood HS		FB-10	Field Blank	11/29/2018	ND	
Brentwood MS	Kitchen	KT-2-FD	Kitchen Tap	11/20/2018	ND	
Brentwood MS	Kitchen	KT-3-FL	Kitchen Tap	11/20/2018	ND	
Brentwood MS	Hallway	WC-4-FD	Bubbler with Cooler	11/20/2018	ND	
Brentwood MS	Hallway	WC-5-FL	Bubbler with Cooler	11/20/2018	ND	
Brentwood MS	Hallway	WC-6-FD	Bubbler with Cooler	11/20/2018	0.799	
Brentwood MS	Hallway	WC-7-FL	Bubbler with Cooler	11/20/2018	0.793	
Brentwood MS	Hallway	WC-7-FL-D	Bubbler with Cooler	11/20/2018	0.722	
Brentwood MS	Hallway	WC-8-FD	Bubbler with Cooler	11/20/2018	ND	
Brentwood MS	Hallway	WC-9-FL	Bubbler with Cooler	11/20/2018	ND	
Brentwood MS		FB-10	Field Blank	11/29/2018	ND	
Centennial HS	Kitchen	KT-02-FD	Kitchen Tap	11/20/2018	ND	Adjacent Office
Centennial HS	Kitchen	KT-02-FD-D	Kitchen Tap	11/20/2018	ND	Adjacent Office
Centennial HS	Kitchen	KT-02-FL	Kitchen Tap	11/20/2018	ND	Adjacent Office
Centennial HS	Locker Room	WC-03-FD	Bubbler with Cooler	11/20/2018	ND	Boys Basketball Locker Room
Centennial HS	Locker Room	WC-03-FL	Bubbler with Cooler	11/20/2018	ND	Boys Basketball Locker Room
Centennial HS	Hallway	WC-04-FD	Bubbler with Cooler	11/20/2018	ND	Across from Class Room 215, left cooler
Centennial HS	Hallway	WC-04-FL	Bubbler with Cooler	11/20/2018	ND	Across from Class Room 215, left cooler
Centennial HS	Hallway	WC-05-FD	Bubbler with Cooler	11/20/2018	ND	Across from Class Room 115, right cooler
Centennial HS	Hallway	WC-05-FL	Bubbler with Cooler	11/20/2018	ND	Across from Class Room 115, right cooler
Centennial HS		FB-01	Field Blank	11/29/2018	ND	
College Grove ES	Kitchen	KT-05-FD	Kitchen Tap	11/21/2018	3.45	Sink next to kitchen office
College Grove ES	Kitchen	KT-05-FL	Kitchen Tap	11/21/2018	0.522	Sink next to kitchen office
College Grove ES	304	SOW-03-FD	Sink with Bubbler	11/21/2018	2.67	

College Grove ES	304	SOW-03-FL	Sink with Bubblers	11/21/2018	0.652	
College Grove ES	413	SOW-04-FD	Sink with Bubblers	11/21/2018	ND	
College Grove ES	413	SOW-04-FL	Sink with Bubblers	11/21/2018	ND	
College Grove ES	Hallway	WC-02-FD	Bubbler with Cooler	11/21/2018	ND	In hallway before Room 202, (cooler on right)
College Grove ES	Hallway	WC-02-FL	Bubbler with Cooler	11/21/2018	0.506	In hallway before Room 202, (cooler on right)
College Grove ES	Hallway	WC-02-FL-D	Bubbler with Cooler	11/21/2018	ND	In hallway before Room 202, (cooler on right)
College Grove ES		FB-01	Field Blank	11/29/2018	ND	
Crockett ES	Kitchen	KT-03-FD	Kitchen Tap	11/21/2018	ND	
Crockett ES	Kitchen	KT-03-FL	Kitchen Tap	11/21/2018	ND	
Crockett ES	Hallway	WC-04-FD	Bubbler with Cooler	11/21/2018	ND	Left fountain
Crockett ES	Hallway	WC-04-FL	Bubbler with Cooler	11/21/2018	ND	Left fountain
Crockett ES	Hallway	WC-05-FD	Bubbler with Cooler	11/21/2018	ND	Right fountain
Crockett ES	Hallway	WC-05-FL	Bubbler with Cooler	11/21/2018	ND	Right fountain
Crockett ES	Hallway	WC-06-FD	Bubbler with Cooler	11/21/2018	ND	Left fountain
Crockett ES	Hallway	WC-06-FL	Bubbler with Cooler	11/21/2018	ND	Left fountain
Crockett ES	Hallway	WC-06-FL-D	Bubbler with Cooler	11/21/2018	ND	Left fountain
Crockett ES		FB-02	Field Blank	11/29/2018	ND	
Edmondson ES	Kitchen	KT-03-FD	Kitchen Tap	11/21/2018	1.33	
Edmondson ES	Kitchen	KT-03-FL	Kitchen Tap	11/21/2018	ND	
Edmondson ES	Kitchen	KT-03-FL-D	Kitchen Tap	11/21/2018	ND	
Edmondson ES	208	SOW-04-FD	Sink with Bubblers	11/21/2018	ND	
Edmondson ES	208	SOW-04-FL	Sink with Bubblers	11/21/2018	ND	
Edmondson ES	310	SOW-05-FD	Sink with Bubblers	11/21/2018	ND	
Edmondson ES	310	SOW-05-FL	Sink with Bubblers	11/21/2018	ND	
Edmondson ES	513	SOW-06-FD	Sink with Bubblers	11/21/2018	ND	
Edmondson ES	513	SOW-06-FL	Sink with Bubblers	11/21/2018	ND	
Edmondson ES		FB-02	Field Blank	11/29/2018	ND	
Fairview ES	Kitchen	KT-05-FD	Kitchen Tap	11/20/2018	ND	2-bay sink on right, closest to electric panel
Fairview ES	Kitchen	KT-05-FL	Kitchen Tap	11/20/2018	ND	2-bay sink on right, closest to electric panel
Fairview ES	101	SOW-04-FD	Sink with Bubblers	11/20/2018	ND	
Fairview ES	101	SOW-04-FL	Sink with Bubblers	11/20/2018	ND	
Fairview ES	Hallway	WC-02-FD	Bubbler with Cooler	11/20/2018	0.546	Hallway outside Room 602
Fairview ES	Hallway	WC-02-FL	Bubbler with Cooler	11/20/2018	ND	Hallway outside Room 602
Fairview ES	Hallway	WC-03-FD	Bubbler with Cooler	11/20/2018	ND	Hallway outside Dr. Ballard's office
Fairview ES	Hallway	WC-03-FD-D	Bubbler with Cooler	11/20/2018	ND	Hallway outside Dr. Ballard's office
Fairview ES	Hallway	WC-03-FL	Bubbler with Cooler	11/20/2018	ND	Hallway outside Dr. Ballard's office
Fairview ES		FB-01	Field Blank	11/29/2018	ND	
Fairview HS	Kitchen	KT-05-FD	Kitchen Tap	11/20/2018	0.729	3-bay sink on left, adjacent to Room C119
Fairview HS	Kitchen	KT-05-FL	Kitchen Tap	11/20/2018	ND	3-bay sink on left, adjacent to Room C119
Fairview HS	Hallway	WC-02-FD	Bubbler with Cooler	11/20/2018	ND	Cooler on right without bottle filler, between girls and boys restroom
Fairview HS	Hallway	WC-02-FL	Bubbler with Cooler	11/20/2018	ND	Cooler on right without bottle filler, between girls and boys restroom
Fairview HS	Hallway	WC-03-FD	Bubbler with Cooler	11/20/2018	ND	Between the girls and boys restroom, in the hallway
Fairview HS	Hallway	WC-03-FD-D	Bubbler with Cooler	11/20/2018	ND	Cooler on right without bottle filler
Fairview HS	Hallway	WC-03-FL	Bubbler with Cooler	11/20/2018	ND	Cooler on right without bottle filler
Fairview HS	Hallway	WC-04-FD	Bubbler with Cooler	11/20/2018	0.615	To the right of boys restroom, in the hallway, without a bottle filler
Fairview HS	Hallway	WC-04-FL	Bubbler with Cooler	11/20/2018	ND	To the right of boys restroom, in the hallway, without a bottle filler
Fairview HS		FB-01	Field Blank	11/29/2018	ND	

Fairview MS	Kitchen	KT-05-FD	Kitchen Tap	11/20/2018	0.543	Kitchen by office (2-bay sink)
Fairview MS	Kitchen	KT-05-FL	Kitchen Tap	11/20/2018	ND	Kitchen by office (2-bay sink)
Fairview MS	Hallway	WC-02-FD	Bubbler with Cooler	11/20/2018	0.782	In Hallway, to the left of locker #543, cooler on the left
Fairview MS	Hallway	WC-02-FL	Bubbler with Cooler	11/20/2018	0.690	In Hallway, to the left of locker #543, cooler on the left
Fairview MS	Commons Area	WC-03-FD	Bubbler with Cooler	11/20/2018	ND	Commons Area
Fairview MS	Commons Area	WC-03-FL	Bubbler with Cooler	11/20/2018	ND	Commons Area
Fairview MS	Hallway	WC-04-FD	Bubbler with Cooler	11/20/2018	ND	Outside of gym, cooler on left, same hallway as Room 40
Fairview MS	Hallway	WC-04-FD-D	Bubbler with Cooler	11/20/2018	ND	Outside of gym, cooler on left, same hallway as Room 41
Fairview MS	Hallway	WC-04-FL	Bubbler with Cooler	11/20/2018	ND	Outside of gym, cooler on left, same hallway as Room 42
Fairview MS		FB-01	Field Blank	11/29/2018	ND	
Franklin HS	Kitchen	KT-05-FD	Kitchen Tap	11/20/2018	ND	Back wall; Large basin adjacent to walk-in freezers
Franklin HS	Kitchen	KT-05-FL	Kitchen Tap	11/20/2018	ND	Back wall; Large basin adjacent to walk-in freezers
Franklin HS	Hallway	WC-02-FD	Bubbler with Cooler	11/20/2018	ND	Adjacent to men's restroom across from Room 102, left cooler
Franklin HS	Hallway	WC-02-FL	Bubbler with Cooler	11/20/2018	ND	Adjacent to men's restroom across from Room 102, left cooler
Franklin HS	Hallway	WC-03-FD	Bubbler with Cooler	11/20/2018	ND	Adjacent to men's restroom across from Room 205, left cooler
Franklin HS	Hallway	WC-03-FL	Bubbler with Cooler	11/20/2018	ND	Adjacent to men's restroom across from Room 205, left cooler
Franklin HS	Hallway	WC-04-FD	Bubbler with Cooler	11/20/2018	ND	Adjacent to men's restroom across from Room 905, left cooler
Franklin HS	Hallway	WC-04-FD-D	Bubbler with Cooler	11/20/2018	ND	Adjacent to men's restroom across from Room 905, left cooler
Franklin HS	Hallway	WC-04-FL	Bubbler with Cooler	11/20/2018	ND	Adjacent to men's restroom across from Room 905, left cooler
Franklin HS		FB-01	Field Blank	11/29/2018	ND	
Grassland ES	Kitchen	KT-2-FD	Kitchen Tap	11/20/2018	0.516	
Grassland ES	Kitchen	KT-3-FL	Kitchen Tap	11/20/2018	ND	
Grassland ES	Kitchen	KT-3-FL-D	Kitchen Tap	11/20/2018	ND	
Grassland ES	510	SOW-10-FL	Sink with Bubbler	11/20/2018	ND	
Grassland ES	205	SOW-5-FD	Sink with Bubbler	11/20/2018	ND	
Grassland ES	205	SOW-6-FL	Sink with Bubbler	11/20/2018	ND	
Grassland ES	308	SOW-7-FD	Sink with Bubbler	11/20/2018	ND	
Grassland ES	308	SOW-8-FL	Sink with Bubbler	11/20/2018	ND	
Grassland ES	510	SOW-9-FD	Sink with Bubbler	11/20/2018	ND	
Grassland ES		FB-4	Field Blank	11/29/2018	ND	
Grassland MS	Kitchen	KT-2-FD	Kitchen Tap	11/20/2018	0.873	
Grassland MS	Kitchen	KT-3-FL	Kitchen Tap	11/20/2018	ND	
Grassland MS	Kitchen	KT-3-FL-D	Kitchen Tap	11/20/2018	ND	
Grassland MS	Hallway	WC-10-FL	Bubbler with Cooler	11/20/2018	0.716	
Grassland MS	Commons Area	WC-4-FD	Bubbler with Cooler	11/20/2018	1.05	Commons Area
Grassland MS	Commons Area	WC-5-FL	Bubbler with Cooler	11/20/2018	0.995	Commons Area
Grassland MS	Hallway	WC-7-FD	Bubbler with Cooler	11/20/2018	ND	
Grassland MS	Hallway	WC-8-FL	Bubbler with Cooler	11/20/2018	0.798	
Grassland MS	Hallway	WC-9-FD	Bubbler with Cooler	11/20/2018	ND	
Grassland MS		FB-6	Field Blank	11/29/2018	ND	
Hillsboro ES-MS		FB-01	Field Blank	11/29/2018	ND	
Hillsboro ES-MS	Kitchen	KT-05-FD	Kitchen Tap	11/20/2018	ND	Kitchen 3-bay sink, tap on the right near the ice maker
Hillsboro ES-MS	Kitchen	KT-05-FL	Kitchen Tap	11/20/2018	ND	Kitchen 3-bay sink, tap on the right near the ice maker
Hillsboro ES-MS	3	SOW-03-FD	Sink with Bubbler	11/20/2018	ND	
Hillsboro ES-MS	3	SOW-03-FD-D	Sink with Bubbler	11/20/2018	ND	
Hillsboro ES-MS	3	SOW-03-FL	Sink with Bubbler	11/20/2018	ND	
Hillsboro ES-MS	Hallway	WC-02-FD	Bubbler with Cooler	11/20/2018	ND	Hallway between the restroom and electrical near Room 31, cooler on right

Hillsboro ES-MS	Hallway	WC-02-FL	Bubbler with Cooler	11/20/2018	ND	Hallway between the restroom and electrical near Room 31, cooler on right
Hillsboro ES-MS	Hallway	WC-04-FD	Bubbler with Cooler	11/20/2018	ND	Hallway outside gym, short cooler on right
Hillsboro ES-MS	Hallway	WC-04-FL	Bubbler with Cooler	11/20/2018	ND	Hallway outside gym, short cooler on right
Huntersbend ES	Kitchen	KT-02-FD	Kitchen Tap	11/20/2018	ND	Back wall adjacent to the office
Huntersbend ES	Kitchen	KT-02-FL	Kitchen Tap	11/20/2018	ND	Back wall adjacent to the office
Huntersbend ES	208	SOW-03-FD	Sink with Bubbler	11/20/2018	ND	
Huntersbend ES	208	SOW-03-FL	Sink with Bubbler	11/20/2018	ND	
Huntersbend ES	208	SOW-03-FL-D	Sink with Bubbler	11/20/2018	ND	
Huntersbend ES	513	SOW-04-FD	Sink with Bubbler	11/20/2018	1.52	
Huntersbend ES	513	SOW-04-FL	Sink with Bubbler	11/20/2018	ND	
Huntersbend ES	409	SOW-05-FD	Sink with Bubbler	11/20/2018	1.11	
Huntersbend ES	409	SOW-05-FL	Sink with Bubbler	11/20/2018	0.619	
Huntersbend ES		FB-01	Field Blank	11/29/2018	ND	
Lipscomb ES	Kitchen	KT-2-FD	Kitchen Tap	11/20/2018	ND	
Lipscomb ES	Kitchen	KT-3-FL	Kitchen Tap	11/20/2018	ND	
Lipscomb ES	507	SOW-10-FL	Sink with Bubbler	11/20/2018	ND	
Lipscomb ES	507	SOW-10-FL-D	Sink with Bubbler	11/20/2018	ND	
Lipscomb ES	205	SOW-4-FD	Sink with Bubbler	11/20/2018	ND	
Lipscomb ES	205	SOW-5-FL	Sink with Bubbler	11/20/2018	ND	
Lipscomb ES	410	SOW-6-FD	Sink with Bubbler	11/20/2018	ND	
Lipscomb ES	410	SOW-7-FL	Sink with Bubbler	11/20/2018	ND	
Lipscomb ES	507	SOW-9-FD	Sink with Bubbler	11/20/2018	ND	
Lipscomb ES		FB-8	Field Blank	11/29/2018	ND	
Oak View ES	Kitchen	KT-02-FD	Kitchen Tap	11/20/2018	ND	Kitchen; Adjacent to the office and fire extinguisher
Oak View ES	Kitchen	KT-02-FL	Kitchen Tap	11/20/2018	ND	Kitchen; Adjacent to the office and fire extinguisher
Oak View ES	409	SOW-03-FD	Sink with Bubbler	11/20/2018	ND	
Oak View ES	409	SOW-03-FL	Sink with Bubbler	11/20/2018	ND	
Oak View ES	409	SOW-03-FL-D	Sink with Bubbler	11/20/2018	ND	
Oak View ES	513	SOW-04-FD	Sink with Bubbler	11/20/2018	1.84	
Oak View ES	513	SOW-04-FL	Sink with Bubbler	11/20/2018	ND	
Oak View ES	212	SOW-05-FD	Sink with Bubbler	11/20/2018	ND	
Oak View ES	212	SOW-05-FL	Sink with Bubbler	11/20/2018	ND	
Oak View ES		FB-01	Field Blank	11/29/2018	ND	
Page HS	Kitchen	KT-02-FD	Kitchen Tap	11/21/2018	ND	2-bay sink, labeled food prep
Page HS	Kitchen	KT-02-FD-D	Kitchen Tap	11/21/2018	ND	2-bay sink, labeled food prep
Page HS	Kitchen	KT-02-FL	Kitchen Tap	11/21/2018	ND	2-bay sink, labeled food prep
Page HS	Hallway	WC-03-FD	Bubbler with Cooler	11/21/2018	ND	Next to Room 703
Page HS	Hallway	WC-03-FL	Bubbler with Cooler	11/21/2018	ND	Next to Room 703
Page HS	Hallway	WC-04-FD	Bubbler with Cooler	11/21/2018	ND	Bubbler on right, without bottle filler
Page HS	Hallway	WC-04-FL	Bubbler with Cooler	11/21/2018	ND	Bubbler on right, without bottle filler
Page HS	Hallway	WC-05-FD	Bubbler with Cooler	11/21/2018	ND	Bubbler on right, without bottle filler
Page HS	Hallway	WC-05-FL	Bubbler with Cooler	11/21/2018	ND	Bubbler on right, without bottle filler
Page HS		FB-01	Field Blank	11/30/2018	ND	
Page MS	Kitchen	KT-02-FD	Kitchen Tap	11/21/2018	0.520	Sink furthest right, tap furthest right
Page MS	Kitchen	KT-02-FL	Kitchen Tap	11/21/2018	0.569	Sink furthest right, tap furthest right
Page MS	Kitchen	KT-02-FL-D	Kitchen Tap	11/21/2018	0.623	Sink furthest right, tap furthest right
Page MS	Hallway	WC-03-FD	Bubbler with Cooler	11/21/2018	ND	Fountain on the right, next to room D5

Page MS	Hallway	WC-03-FL	Bubbler with Cooler	11/21/2018	ND	Fountain on the right, next to room D5
Page MS	Hallway	WC-04-FD	Bubbler with Cooler	11/21/2018	ND	Fountain on the right, between rooms A3/A5
Page MS	Hallway	WC-04-FL	Bubbler with Cooler	11/21/2018	ND	Fountain on the right, between rooms A3/A5
Page MS	Hallway	WC-05-FD	Bubbler with Cooler	11/21/2018	ND	Fountain on the left, next to room B11
Page MS	Hallway	WC-05-FL	Bubbler with Cooler	11/21/2018	ND	Fountain on the left, next to room B11
Page MS		FB-01	Field Blank	11/29/2018	ND	
Pinewood ES	Kitchen	KT-05-FD	Kitchen Tap	11/20/2018	8.15	Former kitchen, 3-bay sink, right tap
Pinewood ES	Kitchen	KT-05-FL	Kitchen Tap	11/20/2018	0.733	Former kitchen, 3-bay sink, right tap
Pinewood ES	1	OW-02-FD	Drinking Water Bubbler	11/20/2018	5.28	
Pinewood ES	1	OW-02-FL	Drinking Water Bubbler	11/20/2018	0.861	
Pinewood ES	Hallway	WC-03-FD	Bubbler with Cooler	11/20/2018	1.34	Hallway outside women's restroom
Pinewood ES	Hallway	WC-03-FD-D	Bubbler with Cooler	11/20/2018	1.25	Hallway outside women's restroom
Pinewood ES	Hallway	WC-03-FL	Bubbler with Cooler	11/20/2018	0.808	Hallway outside women's restroom
Pinewood ES	Hallway	WC-04-FD	Bubbler with Cooler	11/20/2018	1.20	Hallway near lobby (outside Room 3)
Pinewood ES	Hallway	WC-04-FL	Bubbler with Cooler	11/20/2018	0.796	Hallway near lobby (outside Room 3)
Pinewood ES		FB-01	Field Blank	11/29/2018	ND	
Renaissance HS	Lobby	WC-01-FD	Bubbler with Cooler	11/20/2018	ND	Left Cooler
Renaissance HS	Lobby	WC-01-FL	Bubbler with Cooler	11/20/2018	ND	Left Cooler
Renaissance HS	Hallway	WC-02-FD	Bubbler with Cooler	11/20/2018	ND	Across the hallway from women's restroom, adjacent to exterior exit, left cooler
Renaissance HS	Hallway	WC-02-FL	Bubbler with Cooler	11/20/2018	ND	Across the hallway from women's restroom, adjacent to exterior exit, left cooler
Renaissance HS	Hallway	WC-04-FD	Bubbler with Cooler	11/20/2018	ND	Adjacent Room 204 and stairwell door, left cooler
Renaissance HS	Hallway	WC-04-FL	Bubbler with Cooler	11/20/2018	ND	Adjacent Room 204 and stairwell door, left cooler
Renaissance HS	Hallway	WC-04-FL-D	Bubbler with Cooler	11/20/2018	ND	Adjacent Room 204 and stairwell door, left cooler
Renaissance HS		FB-01	Field Blank	11/29/2018	ND	
Scales ES	Kitchen	KT-2-FD	Kitchen Tap	11/20/2018	ND	
Scales ES	Kitchen	KT-3-FL	Kitchen Tap	11/20/2018	ND	
Scales ES	18	SOW-4-FD	Sink with Bubbler	11/20/2018	1.65	
Scales ES	18	SOW-5-FL	Sink with Bubbler	11/20/2018	ND	
Scales ES	18	SOW-5-FL-D	Sink with Bubbler	11/20/2018	ND	
Scales ES	55	SOW-7-FD	Sink with Bubbler	11/20/2018	ND	
Scales ES	55	SOW-8-FL	Sink with Bubbler	11/20/2018	ND	
Scales ES	Hallway	WC-10-FL	Bubbler with Cooler	11/20/2018	ND	
Scales ES	Hallway	WC-9-FD	Bubbler with Cooler	11/20/2018	ND	
Scales ES		FB-6	Field Blank	11/29/2018	ND	
Trinity ES	Kitchen	KT-03-FD	Kitchen Tap	11/21/2018	ND	Sprayer tap
Trinity ES	Kitchen	KT-03-FL	Kitchen Tap	11/21/2018	ND	Sprayer tap
Trinity ES	110	SOW-04-FD	Sink with Bubbler	11/21/2018	ND	
Trinity ES	110	SOW-04-FL	Sink with Bubbler	11/21/2018	ND	
Trinity ES	510	SOW-06-FD	Sink with Bubbler	11/21/2018	0.559	
Trinity ES	510	SOW-06-FL	Sink with Bubbler	11/21/2018	ND	
Trinity ES	Hallway	WC-05-FD	Bubbler with Cooler	11/21/2018	ND	Near room 202
Trinity ES	Hallway	WC-05-FL	Bubbler with Cooler	11/21/2018	ND	Near room 202
Trinity ES	Hallway	WC-05-FL-D	Bubbler with Cooler	11/21/2018	ND	Near room 202
Trinity ES		FB-02	Field Blank	11/29/2018	ND	
Walnut Grove ES	Kitchen	KT-01-FD	Kitchen Tap	11/20/2018	0.517	Food prep sink with sprayer; Adjacent to walk-in coolers
Walnut Grove ES	Kitchen	KT-01-FL	Kitchen Tap	11/20/2018	ND	Food prep sink with sprayer; Adjacent to walk-in coolers
Walnut Grove ES	802	OW-05-FD	Drinking Water Bubbler	11/20/2018	ND	

Walnut Grove ES	802	OW-05-FL	Drinking Water Bubblers	11/20/2018	ND	
Walnut Grove ES	706	SOW-02-FD	Sink with Bubblers	11/20/2018	ND	
Walnut Grove ES	706	SOW-02-FD-D	Sink with Bubblers	11/20/2018	ND	
Walnut Grove ES	706	SOW-02-FL	Sink with Bubblers	11/20/2018	ND	
Walnut Grove ES	Hallway	WC-03-FD	Bubbler with Cooler	11/20/2018	ND	Hallway; across from room 102B; left cooler
Walnut Grove ES	Hallway	WC-03-FL	Bubbler with Cooler	11/20/2018	ND	Hallway; across from room 102B; left cooler
Walnut Grove ES		FB-01	Field Blank	11/29/2018	ND	
Woodland MS	Kitchen	KT-03-FD	Kitchen Tap	11/21/2018	ND	
Woodland MS	Kitchen	KT-03-FL	Kitchen Tap	11/21/2018	ND	
Woodland MS	Commons Area	WC-04-FD	Bubbler with Cooler	11/21/2018	ND	Cafeteria, right cooler
Woodland MS	Commons Area	WC-04-FL	Bubbler with Cooler	11/21/2018	ND	Cafeteria, right cooler
Woodland MS	Hallway	WC-05-FD	Bubbler with Cooler	11/21/2018	ND	
Woodland MS	Hallway	WC-05-FL	Bubbler with Cooler	11/21/2018	ND	
Woodland MS	Hallway	WC-05-FL-D	Bubbler with Cooler	11/21/2018	ND	
Woodland MS	Hallway	WC-06-FD	Bubbler with Cooler	11/21/2018	ND	
Woodland MS	Hallway	WC-06-FL	Bubbler with Cooler	11/21/2018	ND	
Woodland MS		FB-02	Field Blank	11/29/2018	ND	

FIXTURE TYPE	
SOW	Sink with Bubblers
WC	Water Cooler
KT	Kitchen Tap
OW	Drinking Water Bubblers
FB	Quality Control Field Blank

NOTES

Results are in parts per billion (ppb).
 -FD sample ID suffix indicates sample is a First Draw sample collected from a fixture.
 -FD-D sample ID suffix indicates a duplicate First Draw sample collected from a fixture concurrently with another First Draw sample from the same fixture for quality control purposes.
 -FL sample ID suffix indicates sample is a Flush sample collected after a 30 second flush of the fixture.
 -FL-D sample ID suffix indicates a duplicate Flush sample collected from a fixture concurrently with another Flush sample from the same fixture for quality control purposes.
 ND results indicate the lead concentration was less than 0.500 ppb which is the lower limit of the laboratory analysis protocol.
 FB sample is a Field Blank sample of distilled water poured into a container in the field and shipped to laboratory with field samples for quality control purposes.