

LEAD ANALYSIS RESULTS FROM DRINKING WATER SAMPLING ACTIVITIES (June 19, 2019)

School	Room No./Location	Sample ID	Fixture Type	Sample Date	Result (ppb)	Notes
College Grove ES	Kitchen	IM-6-FD	Ice Maker	6/19/2019	ND	Ice Machine
College Grove ES	Kitchen	KT-7-FD	Kitchen Tap	6/19/2019	3.89	Kitchen Sink - Washing sink
College Grove ES	405	SOW-08-FD	Sink with Bubblers	6/19/2019	5.73	Room 405
College Grove ES	115	TL-9-FD	Teachers Lounge	6/19/2019	0.970	Teachers Lounge Sink
College Grove ES	Main Office	WC-10-FD	Bubbler with Cooler	6/19/2019	ND	Main Office - Recently Installed
College Grove ES	103	CL-11-FD	Nurses Clinic	6/19/2019	0.772	Nurses Clinic
College Grove ES	203	SOW-12-FD	Sink with Bubblers	6/19/2019	2.34	Room 203
College Grove ES	202	SOW-13-FD	Sink with Bubblers	6/19/2019	3.15	Room 202
College Grove ES	208	SOW-14-FD	Sink with Bubblers	6/19/2019	ND	Room 208
College Grove ES	211	SOW-15-FD	Sink with Bubblers	6/19/2019	0.853	Room 211
College Grove ES	210	SOW-16-FD	Sink with Bubblers	6/19/2019	ND	Room 210
College Grove ES	207	SOW-17-FD	Sink with Bubblers	6/19/2019	ND	Room 207
College Grove ES	207	SOW-17-FD-D	Sink with Bubblers	6/19/2019	ND	Room 207 Duplicate
College Grove ES	Hallway	WC-18-FD	Bubbler with Cooler	6/19/2019	ND	Hallway, Between Rm 303 and Storage Room 120
College Grove ES	305	SOW-19-FD	Sink with Bubblers	6/19/2019	2.24	Room 305
College Grove ES	302	SOW-20-FD	Sink with Bubblers	6/19/2019	2.00	Room 304
College Grove ES	Hallway	WC-21-FD	Bubbler with Cooler	6/19/2019	ND	Chiller on right between bathrooms, in front of gym doors
College Grove ES	Outside	OW-22-FD	Drinking Water Bubbler	6/19/2019	ND	Outside gym, by picnic tables
College Grove ES	403	SOW-23-FD	Sink with Bubblers	6/19/2019	3.98	Room 403
College Grove ES	407	SOW-24-FD	Sink with Bubblers	6/19/2019	1.05	Room 407
College Grove ES	408	SOW-25-FD	Sink with Bubblers	6/19/2019	0.602	Room 408
College Grove ES	411	SOW-26-FD	Sink with Bubblers	6/19/2019	0.523	Room 411
College Grove ES	412	SOW-27-FD	Sink with Bubblers	6/19/2019	1.19	Room 412
College Grove ES	Outside	OW-28-FD	Drinking Water Bubbler	6/19/2019	0.797	Outside @ Playground, near basketball hoops
College Grove ES	N/A	FB-1	Field Blank	6/19/2019	ND	Field Blank
OakView ES	Kitchen	KT-06-FD	Kitchen Tap	6/19/2019	ND	Sink on the Right in the corner
OakView ES	Hallway Sink	WC-07-FD	Bubbler with Cooler	6/19/2019	ND	Sink on the right, across hall from Room 402
OakView ES	Room 408	SOW-08-FD	Sink with Bubblers	6/19/2019	ND	Room 408
OakView ES	Room 405	SOW-09-FD	Sink with Bubblers	6/19/2019	ND	Room 405
OakView ES	Hallway Sink	WC-10-FD	Bubbler with Cooler	6/19/2019	ND	Sink on the right, across hall from Room 301
OakView ES	Room 304	SOW-11-FD	Sink with Bubblers	6/19/2019	ND	Room 304
OakView ES	Room 307	SOW-12-FD	Sink with Bubblers	6/19/2019	ND	Room 307
OakView ES	Room 204	SOW-13-FD	Sink with Bubblers	6/19/2019	ND	Room 204
OakView ES	Room 205	SOW-14-FD	Sink with Bubblers	6/19/2019	ND	Room 205
OakView ES	Room 501	SOW-15-FD	Sink with Bubblers	6/19/2019	ND	Room 501
OakView ES	Hallway Sink	WC-16-FD	Bubbler with Cooler	6/19/2019	ND	Sink on the right, across hall from the Gym
OakView ES	Room 211	SOW-17-FD	Sink with Bubblers	6/19/2019	ND	Room 211
OakView ES	Room 506	SOW-18-FD	Sink with Bubblers	6/19/2019	ND	Room 506
OakView ES	Room 507	SOW-19-FD	Sink with Bubblers	6/19/2019	ND	Room 507

OakView ES	Room 510	SOW-20-FD	Sink with Bubblers	6/19/2019	ND	Room 510
OakView ES	Room 511	SOW-21-FD	Sink with Bubblers	6/19/2019	0.786	Room 511
OakView ES	Room 209	SOW-22-FD	Sink with Bubblers	6/19/2019	ND	Room 209
OakView ES	Room 402	SOW-23-FD	Sink with Bubblers	6/19/2019	ND	Room 402
OakView ES	Room 404	SOW-24-FD	Sink with Bubblers	6/19/2019	ND	Room 404
OakView ES	Room 404	SOW-24-FD-D	Sink with Bubblers	6/19/2019	ND	Room 404 duplicate
OakView ES	Room 407	SOW-25-FD	Sink with Bubblers	6/19/2019	ND	Room 407
OakView ES	Room 410	SOW-26-FD	Sink with Bubblers	6/19/2019	ND	Room 410
OakView ES	Nurses Clinic	CL-27-FD	Nurses Clinic	6/19/2019	ND	Nurses Clinic
OakView ES	Kitchen	IM-28-FD	Ice Maker	6/19/2019	ND	Ice Machine Maker in Kitchen
OakView ES	N/A	FB-1	Field Blank	6/19/2019	ND	Field Blank
ScalesES	Kitchen	IM-11-FD	Ice Maker	6/19/2019	ND	Ice Maker
ScalesES	Kitchen	KT-12-FD	Kitchen Tap	6/19/2019	ND	Right faucet, next to ice maker
Scales ES	Cafeteria	WC-13-FD	Bubbler with Cooler	6/19/2019	ND	Cafeteria to the Right of storage
Scales ES	Area for Rooms 30-36	WC-14-FD	Bubbler with Cooler	6/19/2019	ND	Bubbler on left side of the room, Bubbler on the right
Scales ES	Area for Rooms 30-36	WC-15-FD	Bubbler with Cooler	6/19/2019	ND	Bubbler on right side of the room, Bubbler on the left
Scales ES	Room 51	SOW-16-FD	Sink with Bubblers	6/19/2019	ND	Room 51
Scales ES	Room 52	SOW-17-FD	Sink with Bubblers	6/19/2019	ND	Room 52
Scales ES	Hallway	WC-18-FD	Bubbler with Cooler	6/19/2019	ND	Bubbler on left side of hallway, Bubbler on the left
Scales ES	Room 54	SOW-19-FD	Sink with Bubblers	6/19/2019	ND	Room 54
Scales ES	Cafeteria	WC-20-FD	Bubbler with Cooler	6/19/2019	ND	Bubbler on far side wall, away from storage
Scales ES	Hallway	WC-21-FD	Bubbler with Cooler	6/19/2019	ND	Bubbler on right side of the room, Bubbler on the left
Scales ES	Hallway	WC-22-FD	Bubbler with Cooler	6/19/2019	ND	Bubbler on left side of the room, Bubbler on the right
Scales ES	Area for Rooms 19-26	WC-23-FD	Bubbler with Cooler	6/19/2019	ND	Bubbler on left side of the room, Bubbler on the right
Scales ES	Area for Rooms 19-26	WC-24-FD	Bubbler with Cooler	6/19/2019	ND	Bubbler on right side of the room, Bubbler on the left
Scales ES	Room 11	SOW-25-FD	Sink with Bubblers	6/19/2019	0.536	Room 11
Scales ES	Room 12	SOW-26-FD	Sink with Bubblers	6/19/2019	ND	Room 12
Scales ES	Room 12	SOW-26-FD-D	Sink with Bubblers	6/19/2019	ND	Room 12, duplicate
Scales ES	Room 13	SOW-27-FD	Sink with Bubblers	6/19/2019	0.718	Room 13
Scales ES	Room 14	SOW-28-FD	Sink with Bubblers	6/19/2019	ND	Room 14
Scales ES	Room 15	SOW-29-FD	Sink with Bubblers	6/19/2019	5.25	Room 15
Scales ES	Room 16	SOW-30-FD	Sink with Bubblers	6/19/2019	0.731	Room 16
Scales ES	Room 17	SOW-31-FD	Sink with Bubblers	6/19/2019	ND	Room 17
Scales ES	Kitchen	KT-32-FD	Kitchen Tap	6/19/2019	1.04	Kitchen
Scales ES	Room 53	SOW-33-FD	Sink with Bubblers	6/19/2019	ND	Room 53
Scales ES	N/A	FB-1	Field Blank	6/19/2019	ND	Field Blank

FIXTURE TYPE	
SOW	Sink with Bubblers
WC	Water Cooler
KT	Kitchen Tap
OW	Drinking Water Bubbler

CL	Nurse's Clinic
IM	Ice Maker
TL	Teacher's Lounge
FB	Quality Control Field Blank

NOTES

Results are in parts per billion (ppb).

-FD sample ID suffix indicates sample is a First Draw sample collected from a fixture.

-FD-D sample ID suffix indicates a duplicate First Draw sample collected from a fixture concurrently with another First Draw sample from the same fixture for quality control purposes.

ND results indicate the lead concentration was less than 0.500 ppb which is the lower limit of the laboratory analysis protocol.

FB sample is a Field Blank sample of distilled water poured into a container in the field and shipped to laboratory with field samples for quality control purposes.