

June 28, 2024

Adam Christopher and William Butler
Williamson County Schools
1761 West Main Street
Franklin, Tennessee

**Re: Summary Report of 2024 Drinking Water Sampling and Analysis
Williamson County Schools**

Gentlemen,

EnSafe Inc. is pleased to provide this summary report for the recently completed drinking water sampling and analysis activities performed at Williamson County Schools (WCS) for the 2023/2024 school calendar year. The objective of the activities was to help ensure WCS's compliance with the law Tennessee Code Annotated (TCA) §49-2-133.

SCOPE OF WORK

The sampling and analysis activities for the 2023/2024 school calendar year were performed in general accordance with the WCS Lead in Drinking Water Program, dated June 17, 2019. The testing focused on representative drinking water supply locations to provide an overview of drinking water quality in 26 schools constructed prior to January 1, 1998. The sampling was completed May 8 through 24, 2024. WCS coordinated with EnSafe regarding selection of the schools, scheduling, and access. Fixtures (sampling locations) were strategically selected to help ensure representative first draw water samples were collected. Quality assurance (QA) samples were also collected from the schools, including duplicate first draw samples and field blank samples. Each sample was collected in a laboratory provided container, labeled with the proper school name and sample identification. A total of 552 samples from the May 2024 activities were transported to Waypoint Analytical laboratories under chain-of-custody control for analysis of lead concentrations using U.S. Environmental Protection Agency (USEPA) Method 200.8.

Upon receipt of analytical results from the laboratory, the results were reviewed and compared to the action levels of 15 and 20 parts per billion (ppb) referenced in T.C.A. § 49-2-133. Notifications of the results relative to the action levels were then provided to WCS. Additionally, the results were entered into a database, as well as a detailed table format previously requested by WCS. As discussed in the following section, the results were favorable.

FINDINGS

The collection of 552 samples was performed May 8 through 24, 2024. Laboratory results, sampling locations, and fixture types are shown on Table 1. Laboratory results reported that no lead concentrations were greater than the action levels of 15 ppb or 20 ppb in the first draw samples. As such, no additional sampling of individual taps was required. Additionally, because of the low concentrations no notification of exceedances were required to be submitted to parents, guardians, or governmental agencies.

Thank you again for your time and consideration regarding this project. If you have any questions, or require additional information, please contact us at 615-255-9300.

Sincerely,

EnSafe Inc.



By: Bonnie Nguyen, G.I.T.
Project Geologist



Ronald T. Dow, P.G.
Senior Project Manager

Attachment: Attachment A Laboratory Results



Attachment A
2024 Drinking Water
Results

WILLIAMSON COUNTY SCHOOLS 2024 DRINKING WATER RESULTS

School Name	Sampled Date/Time	Sample ID	Result	Location Notes
Bethesda ES	5/22/2024 6:13	FB-01	<0.500	Field Blank; Quality Control Sample
Bethesda ES	5/22/2024 6:14	KT-41-FD	<0.500	kitchen tap on the left, furthest from the door, 3 bay sink
Bethesda ES	5/22/2024 6:15	WC-40-FD	<0.500	WC outside cafeteria, right
Bethesda ES	5/22/2024 6:17	WC-39-FD	<0.500	Wc on left outside cafeteria ; WC on left with bottle filler.
Bethesda ES	5/22/2024 6:19	WC-04-FD	<0.500	Across from Room 702A, bubbler without bottle filler (bubbler on the right)
Bethesda ES	5/22/2024 6:21	SOW-37-FD	6.93	Room 701, music room. To the right
Bethesda ES	5/22/2024 6:23	SOW-38-FD	3.43	Room 703, art room
Bethesda ES	5/22/2024 6:23	SOW-38-FD-D	1.06	Room 703, art room
Bethesda ES	5/22/2024 6:26	WC-36-FD	<0.500	Next to Room 613 (office room)
Bethesda ES	5/22/2024 6:27	WC-34-FD	<0.500	Left WC, next to Room 201 & boy's restroom
Bethesda ES	5/22/2024 6:28	WC-44-FD	<0.500	Right wc, with bottle filler outside room 103
Bethesda ES	5/22/2024 6:31	SOW-45-FD	4.31	Room 114
Bethesda ES	5/22/2024 6:34	SOW-03-FD	0.732	Room 115
Bethesda ES	5/22/2024 6:37	WC-21-FD	<0.500	between Room 202 & boys bathroom, left WC
Bethesda ES	5/22/2024 6:38	WC-22-FD	<0.500	between Room 202 & Boys bathroom, right WC
Bethesda ES	5/22/2024 6:40	WC-20-FD	<0.500	Next to mechanical room
Bethesda ES	5/22/2024 6:42	WC-31-FD	<0.500	Next to Room 616 (office/admin) door.
Bethesda ES	5/22/2024 6:43	TL-32-FD	<0.500	Sink in teacher's lounge
Bethesda ES	5/22/2024 6:46	SOW-23-FD	7.38	Room 302, to the left, bubbler leaks
Bethesda ES	5/22/2024 6:47	SOW-24-FD	<0.500	Room 301, to the right
Bethesda ES	5/22/2024 6:48	SOW-25-FD	2.05	Room 304, to the right, leaks water
Bethesda ES	5/22/2024 6:50	SOW-28-FD	1.85	Room 306, to the left, leaks some water
Bethesda ES	5/22/2024 6:53	SOW-27-FD	<0.500	Room 305, to the right
Bethesda ES	5/22/2024 6:56	WC-47-FD	<0.500	Left wc with bottle filler outside gym
Bethesda ES	5/22/2024 6:57	WC-48-FD	<0.500	Right wc outside gym
Brentwood HS	5/10/2024 5:39	FB-01	<0.500	Field Blank; Quality Control Sample
Brentwood HS	5/10/2024 6:05	WC-38-FD	<0.500	In cafeteria
Brentwood HS	5/10/2024 6:07	KT-03-FD	<0.500	Kitchen tap
Brentwood HS	5/10/2024 6:13	WC-24-FD	<0.500	WC next to C4 & C5 rooms, right (shorter) WC
Brentwood HS	5/10/2024 6:14	WC-23-FD	<0.500	WC next to C4 & C5 rooms, left (taller) WC
Brentwood HS	5/10/2024 6:14	WC-23-FD-D	<0.500	WC next to C4 & C5 rooms, left (taller) WC
Brentwood HS	5/10/2024 6:20	WC-25-FD	<0.500	WC next to room C2, in front of library, left (taller) WC
Brentwood HS	5/10/2024 6:22	WC-26-FD	<0.500	WC next to room C2, in front of library, right (shorter) WC
Brentwood HS	5/10/2024 6:26	WC-27-FD	1.92	WC in front of Room A1, (taller) left WC
Brentwood HS	5/10/2024 6:27	WC-28-FD	1.25	WC in front of Room A1, (shorter) right WC
Brentwood HS	5/10/2024 6:30	WC-29-FD	<0.500	WC in front of Room A4, taller, left WC.
Brentwood HS	5/10/2024 6:31	WC-30-FD	<0.500	WC in front of Room A4, (shorter) right WC
Brentwood HS	5/10/2024 6:33	WC-06-FD	<0.500	WC in front of Room A7, left (taller) WC
Brentwood HS	5/10/2024 6:34	WC-31-FD	<0.500	WC in front of Room A7, right (shorter) WC
Brentwood HS	5/10/2024 6:37	WC-32-FD	<0.500	WC in front of Room A14, left (taller) WC
Brentwood HS	5/10/2024 6:38	WC-33-FD	<0.500	WC in front of Room A14, right (shorter) WC
Brentwood HS	5/10/2024 6:41	WC-34-FD	<0.500	WC in front of Room A19, left (taller) WC
Brentwood HS	5/10/2024 6:43	WC-35-FD	<0.500	WC in front of Room A19, right (shorter) WC
Brentwood HS	5/10/2024 6:46	WC-36-FD	<0.500	WC in front if Room A22, left (taller) WC.
Brentwood HS	5/10/2024 6:52	WC-40-FD	0.599	Next to classroom F1A, taller fountain
Brentwood HS	5/10/2024 6:53	WC-41-FD	0.534	Shorter, next to F1A; WC in front of Room 620, left WC
Brentwood HS	5/10/2024 6:59	WC-42-FD	1.11	Hall B, next to B19, taller; WC in front of Room B18
Brentwood HS	5/10/2024 7:01	WC-43-FD	0.805	Shorter, hall B by classroom B19; WC in front of Room B18
Brentwood HS	5/10/2024 7:10	WC-08-FD	<0.500	Taller water cooler
Brentwood HS	5/10/2024 7:11	WC-09-FD	<0.500	Short water cooler
Centennial HS	5/15/2024 6:04	FB-01	<0.500	Field Blank; Quality Control Sample
Centennial HS	5/15/2024 6:05	KT-06-FD	0.895	Kitchen tap next to kitchen office, right tap; Kitchen tap next to kitchen office
Centennial HS	5/15/2024 6:09	WC-07-FD	<0.500	Left cooler, left set outside of gym next to male bathroom; left (taller) cooler; across from Room 115
Centennial HS	5/15/2024 6:11	WC-08-FD	<0.500	Right wc, outside gym, left set next to male bathroom; left (shorter) bottle filler, across from stairwell near Room 124
Centennial HS	5/15/2024 6:13	WC-09-FD	<0.500	Left wc, right set of wc, outside concession stand and gym; right (taller) cooler, across from stairwell near Room 124
Centennial HS	5/15/2024 6:14	WC-10-FD	<0.500	Right wc, right set of wc, outside concession stand and gym; left (shorter) cooler, adjacent to school store
Centennial HS	5/15/2024 6:19	WC-28-FD	<0.500	Girls locker room
Centennial HS	5/15/2024 6:23	WC-22-FD	<0.500	Left wc, outside room 147; right (shorter) cooler; across from Room 239.
Centennial HS	5/15/2024 6:23	WC-22-FD-D	<0.500	Left wc, outside room 147; right (shorter) cooler; across from Room 239.
Centennial HS	5/15/2024 6:26	WC-23-FD	<0.500	Right tall wc outside rm 147; left (taller) bottle filler; adjacent to Room 137
Centennial HS	5/15/2024 6:29	WC-24-FD	<0.500	Right wc in front of rm 140
Centennial HS	5/15/2024 6:31	WC-25-FD	<0.500	Left wc in front of rm 140, has bottle filler; Left wc in front of rm 140
Centennial HS	5/15/2024 6:34	TL-11-FD	<0.500	On left side of room, TL sink; Library office next to library doors
Centennial HS	5/15/2024 6:35	WC-29-FD	<0.500	Wc in teachers lounge has bottle filler
Centennial HS	5/15/2024 6:39	WC-12-FD	<0.500	Left tall wc outside rm 116; left (shorter) cooler; adjacent to women's restroom near exit

WILLIAMSON COUNTY SCHOOLS 2024 DRINKING WATER RESULTS

School Name	Sampled Date/Time	Sample ID	Result	Location Notes
Centennial HS	5/15/2024 6:40	WC-05-FD	<0.500	Across from Class Room 115, right cooler
Centennial HS	5/15/2024 6:45	WC-14-FD	<0.500	2nd floor, right wc in front of rm 224
Centennial HS	5/15/2024 6:46	WC-15-FD	<0.500	2nd floor, left wc in front of rm 224
Centennial HS	5/15/2024 6:49	WC-04-FD	<0.500	Across from Class Room 215, left cooler
Centennial HS	5/15/2024 6:50	WC-13-FD	<0.500	Right wc outside of rm 216; right (taller) cooler; adjacent to women's restroom near exit
Centennial HS	5/15/2024 6:54	WC-17-FD	<0.500	Right wc in front of rm 232
Centennial HS	5/15/2024 6:56	WC-19-FD	<0.500	Left wc in front of rm 238
Centennial HS	5/15/2024 6:58	WC-20-FD	<0.500	Right WC, 2nd floor, outside rm 252; left (taller) cooler; adjacent to Room 230
Centennial HS	5/15/2024 7:01	WC-21-FD	<0.500	Left wc, 2nd floor outside rm 252; right (shorter) cooler; adjacent to Room 230
College Grove ES	5/8/2024 7:08	WC-02-FD	<0.500	Water cooler (right) across from me just room 201; In hallway before Room 202, (cooler on right)
College Grove ES	5/8/2024 7:08	FB-01	<0.500	Field Blank; Quality Control Sample
College Grove ES	5/8/2024 7:12	SOW-41-FD	<0.500	CR 205 bubbler; Room 205
College Grove ES	5/8/2024 7:15	SOW-40-FD	7.39	CR 204 bubbler ; Room 204
College Grove ES	5/8/2024 7:19	SOW-43-FD	0.542	CR 209 BUBBLER ; Room 209
College Grove ES	5/8/2024 7:23	SOW-14-FD	1.56	CR 208 BUBBLER ; Room 208
College Grove ES	5/8/2024 7:27	SOW-45-FD	<0.500	CR213; Room 213
College Grove ES	5/8/2024 7:29	SOW-44-FD	<0.500	CR 212 bubbler ; Room 212
College Grove ES	5/8/2024 7:35	KT-05-FD	<0.500	Sink next to kitchen office
College Grove ES	5/8/2024 7:35	KT-05-FD-D	<0.500	Sink next to kitchen office
College Grove ES	5/8/2024 7:41	TL-09-FD	<0.500	food prep sink in kitchenette; Teachers Lounge
College Grove ES	5/8/2024 7:45	SOW-19-FD	3.80	CR 305 BUBBLER ; Room 305
College Grove ES	5/8/2024 7:48	SOW-03-FD	<0.500	CR 304 BUBBLER ; Room 304
College Grove ES	5/8/2024 7:51	SOW-47-FD	2.08	CR 303 BUBBLER ; Room 303
College Grove ES	5/8/2024 7:54	SOW-20-FD	0.858	CR 302 BUBBLER ; Room 304
College Grove ES	5/8/2024 7:58	WC-18-FD	<0.500	WC (RIGHT SIDE) ACROSS FROM CR 301; Hallway, between Room 303 and Storage Room 120
College Grove ES	5/8/2024 8:01	SOW-46-FD	4.34	CR 301 BUBBLER ; Room 301
College Grove ES	5/8/2024 8:03	SOW-48-FD	2.24	CR 300 BUBBLER ; Room 300
College Grove ES	5/8/2024 8:07	WC-21-FD	<0.500	WC w/ Bottle filler (left) adj girls restroom ; cooler on right between bathrooms, in front of gym doors
College Grove ES	5/8/2024 8:11	SOW-49-FD	5.23	CR 404 BUBBLER ; Room 404
College Grove ES	5/8/2024 8:15	SOW-25-FD	<0.500	CR 408 BUBBLER ; Room 408
College Grove ES	5/8/2024 8:18	SOW-24-FD	<0.500	CR 407 BUBBLER ; Room 407
College Grove ES	5/8/2024 8:21	SOW-27-FD	<0.500	CR 412 BUBBLER ; Room 412
College Grove ES	5/8/2024 8:25	SOW-26-FD	<0.500	CR 411 BUBBLER ; Room 411
College Grove ES	5/8/2024 8:27	SOW-04-FD	<0.500	CR 413 BUBBLER ; Room 413
Crockett ES	5/10/2024 7:08	FB-01	<0.500	Field Blank; Quality Control Sample
Crockett ES	5/10/2024 7:09	KT-40-FD	<0.500	Kitchen food prep, unlabeled
Crockett ES	5/10/2024 7:14	WC-21-FD	<0.500	Outside cafeteria, right cooler
Crockett ES	5/10/2024 7:15	WC-20-FD	<0.500	Outside cafeteria, left cooler, has bottle filler; outside cafeteria, left cooler
Crockett ES	5/10/2024 7:17	WC-25-FD	<0.500	Outside Room 613, single wc; outside Room 102, left cooler
Crockett ES	5/10/2024 7:19	TL-39-FD	<0.500	Breakroom by library
Crockett ES	5/10/2024 7:21	WC-06-FD	<0.500	Outside Room 2, left cooler
Crockett ES	5/10/2024 7:22	WC-22-FD	<0.500	Outside Room 2, right cooler
Crockett ES	5/10/2024 7:22	WC-22-FD-D	<0.500	Outside Room 2, right cooler
Crockett ES	5/10/2024 7:26	SOW-41-FD	0.621	Room 7
Crockett ES	5/10/2024 7:30	WC-26-FD	<0.500	Outside Room 202, right cooler
Crockett ES	5/10/2024 7:33	WC-05-FD	<0.500	Outside Room 202; outside Room 202, left cooler
Crockett ES	5/10/2024 7:36	WC-42-FD	11.0	Single wc outside 200 hallway and 300 hallway
Crockett ES	5/10/2024 7:39	WC-27-FD	<0.500	Outside library (300 wing)
Crockett ES	5/10/2024 7:41	SOW-31-FD	0.595	Room 303
Crockett ES	5/10/2024 7:42	SOW-28-FD	<0.500	Room 301
Crockett ES	5/10/2024 7:43	SOW-29-FD	<0.500	Room 302
Crockett ES	5/10/2024 7:45	SOW-30-FD	0.538	Room 304
Crockett ES	5/10/2024 7:49	SOW-33-FD	<0.500	Room 305
Crockett ES	5/10/2024 7:50	SOW-34-FD	<0.500	Room 307
Crockett ES	5/10/2024 7:51	SOW-32-FD	<0.500	Room 306
Crockett ES	5/10/2024 7:53	SOW-35-FD	0.782	Room 308
Crockett ES	5/10/2024 7:54	SOW-37-FD	2.42	Room 309
Crockett ES	5/10/2024 7:55	SOW-36-FD	<0.500	Room 310
Crockett ES	5/10/2024 7:58	WC-38-FD	<0.500	Outside gymnasium, right wc with bottle filler
Edmondson ES	5/8/2024 7:06	FB-01	<0.500	Field Blank; Quality Control Sample
Edmondson ES	5/8/2024 7:08	WC-21-FD	<0.500	Between Room 202 & boys bathroom, left WC & has bottle filler; outside cafeteria, left cooler
Edmondson ES	5/8/2024 7:10	WC-22-FD	<0.500	Between Room 202 & Boys bathroom, right WC, has bottle filler; outside cafeteria, right cooler
Edmondson ES	5/8/2024 7:12	KT-03-FD	0.846	Kitchen tap on right side of room, food prep; Kitchen
Edmondson ES	5/8/2024 7:21	WC-24-FD	<0.500	WC next to 303, right WC has bottle filler; outside Room 302, left cooler

WILLIAMSON COUNTY SCHOOLS 2024 DRINKING WATER RESULTS

School Name	Sampled Date/Time	Sample ID	Result	Location Notes
Edmondson ES	5/8/2024 7:23	WC-25-FD	<0.500	Left WC, bottle filler next to rm 303; outside Room 302, right cooler
Edmondson ES	5/8/2024 7:26	SOW-28-FD	<0.500	Room 305, art room; in Room 305
Edmondson ES	5/8/2024 7:28	SOW-27-FD	<0.500	in Room 304
Edmondson ES	5/8/2024 7:31	SOW-29-FD	<0.500	in Room 309
Edmondson ES	5/8/2024 7:35	SOW-05-FD	<0.500	Room 310
Edmondson ES	5/8/2024 7:35	SOW-05-FD-D	<0.500	Room 310
Edmondson ES	5/8/2024 7:42	SOW-41-FD	0.591	in Room 504
Edmondson ES	5/8/2024 7:43	WC-46-FD	<0.500	Wc in 500 hallway right WC, HAS BOTTLE FILLER
Edmondson ES	5/8/2024 7:47	WC-45-FD	<0.500	Left wc outside of room 506 and 507, has bottle filler; left wc outside of room 506 and 507
Edmondson ES	5/8/2024 7:49	SOW-42-FD	<0.500	in Room 509
Edmondson ES	5/8/2024 7:51	SOW-06-FD	<0.500	Room 513
Edmondson ES	5/8/2024 7:57	WC-39-FD	<0.500	WC on right, has bottle filler, outside of gym
Edmondson ES	5/8/2024 7:58	WC-40-FD	<0.500	WC left outside of gym, has bottle filler
Edmondson ES	5/8/2024 8:00	SOW-38-FD	<0.500	Rm 407; in Room 407
Edmondson ES	5/8/2024 8:02	SOW-37-FD	<0.500	Rm 404; in Room 404
Edmondson ES	5/8/2024 8:05	SOW-36-FD	<0.500	Room 402
Edmondson ES	5/8/2024 8:08	WC-30-FD	<0.500	Right Wc in 200 hallway; next to room 201, left cooler
Edmondson ES	5/8/2024 8:09	WC-31-FD	<0.500	Left Wc in 200 hallway; next to room 201, right cooler
Edmondson ES	5/8/2024 8:11	SOW-32-FD	<0.500	Room 201
Edmondson ES	5/8/2024 8:12	SOW-33-FD	<0.500	Room 205
Fairview ES	5/24/2024 8:01	FB-01	<0.500	Field Blank; Quality Control Sample
Fairview ES	5/24/2024 8:03	WC-32-FD	<0.500	by office and front entrance, single wc, has bottle fill ; by office
Fairview ES	5/24/2024 8:05	TL-33-FD	<0.500	staff lounge
Fairview ES	5/24/2024 8:07	SOW-35-FD	<0.500	Room 206
Fairview ES	5/24/2024 8:08	SOW-34-FD	<0.500	Room 205
Fairview ES	5/24/2024 8:10	SOW-36-FD	<0.500	Room 203
Fairview ES	5/24/2024 8:11	SOW-37-FD	<0.500	Room 204
Fairview ES	5/24/2024 8:13	SOW-41-FD	<0.500	Room 202
Fairview ES	5/24/2024 8:14	SOW-40-FD	<0.500	Room 201
Fairview ES	5/24/2024 8:16	SOW-04-FD	<0.500	Room 101
Fairview ES	5/24/2024 8:18	SOW-42-FD	<0.500	Room 102
Fairview ES	5/24/2024 8:19	SOW-38-FD	<0.500	Room 103
Fairview ES	5/24/2024 8:20	SOW-39-FD	<0.500	Room 104
Fairview ES	5/24/2024 8:23	KT-30-FD	0.561	Kitchen right sink (right side of room), right tap, double bay sink
Fairview ES	5/24/2024 8:27	WC-21-FD	<0.500	right cooler, by Room 306
Fairview ES	5/24/2024 8:27	WC-21-FD-D	<0.500	Right cooler, by Room 306
Fairview ES	5/24/2024 8:30	WC-22-FD	<0.500	Left cooler, by Room 306
Fairview ES	5/24/2024 8:31	WC-43-FD	<0.500	Next to rm 401. Single Wc has bottle fill; Next to rm 401. Single Wc
Fairview ES	5/24/2024 8:33	WC-23-FD	<0.500	By library, outside room 506, single wc; by library
Fairview ES	5/24/2024 8:35	WC-45-FD	<0.500	Single wc with bottle filler next to rm 501
Fairview ES	5/24/2024 8:37	WC-46-FD	<0.500	Single wc next to nurses clinic near rm 406
Fairview ES	5/24/2024 8:38	NS-47-FD	0.967	Nurses sink in rm 128 by 600s hallway
Fairview ES	5/24/2024 8:39	WC-26-FD	<0.500	by Room 602, has bottle fill; by Room 602
Fairview HS	5/24/2024 7:02	FB-01	<0.500	Field Blank; Quality Control Sample
Fairview HS	5/24/2024 7:03	WC-48-FD	<0.500	Wc left next to boys rr outside of gymnasium (c104), has bottle fill
Fairview HS	5/24/2024 7:08	WC-50-FD	<0.500	Wrestling locker room dressing room, access by going through auditorium single wc with bottle fill
Fairview HS	5/24/2024 7:11	WC-25-FD	<0.500	By Room C104, left cooler has bottle fill; by Room C104, left cooler
Fairview HS	5/24/2024 7:13	WC-24-FD	0.693	By Room C104, main hall, right cooler
Fairview HS	5/24/2024 7:15	WC-22-FD	<0.500	Across from Room B111, left cooler
Fairview HS	5/24/2024 7:15	WC-22-FD-D	<0.500	Across from Room B111, left cooler
Fairview HS	5/24/2024 7:17	WC-21-FD	<0.500	Across from Room B111, right cooler
Fairview HS	5/24/2024 7:18	TL-45-FD	<0.500	In room between rm b111 and b117. Being used as daycare as of 05/03/22. Sink used for water for kids/babies
Fairview HS	5/24/2024 7:21	WC-27-FD	<0.500	Room C104, main hall, right, has bottle fill ; Room C104, main hall, right
Fairview HS	5/24/2024 7:23	WC-28-FD	<0.500	Room C104, main hall, left
Fairview HS	5/24/2024 7:24	WC-43-FD	1.33	Single Wc in cafeteria
Fairview HS	5/24/2024 7:25	KT-05-FD	<0.500	3-bay sink on left, adjacent to Room C119
Fairview HS	5/24/2024 7:29	WC-42-FD	<0.500	Left wc with bottle fill short next to f130 has bottle fill ; Left wc with bottle fill short next to f130
Fairview HS	5/24/2024 7:30	WC-02-FD	<0.500	Cooler on right without bottle filler, between girls and boys restroom, by f130
Fairview HS	5/24/2024 7:33	WC-37-FD	<0.500	G hallway across from G128, right cooler, has bottle fill; G hallway across from G128, right cooler
Fairview HS	5/24/2024 7:34	WC-38-FD	<0.500	G hallway across from G128, left cooler
Fairview HS	5/24/2024 7:36	WC-35-FD	<0.500	By Room G123, right WC has bottle fill; By Room G123, right WC
Fairview HS	5/24/2024 7:37	WC-36-FD	<0.500	By Room G123, left WC
Fairview HS	5/24/2024 7:39	TL-34-FD	<0.500	Sink in special needs classroom
Fairview HS	5/24/2024 7:42	WC-33-FD	<0.500	by F117, in the C-Hall, left WC
Fairview HS	5/24/2024 7:44	TL-31-FD	1.12	teacher's lounge sink

WILLIAMSON COUNTY SCHOOLS 2024 DRINKING WATER RESULTS

School Name	Sampled Date/Time	Sample ID	Result	Location Notes
Fairview HS	5/24/2024 7:45	NS-51-FD	0.713	nurses clinic
Fairview HS	5/24/2024 7:50	WC-46-FD	<0.500	Lobby of auditorium (fpac) next to bathrooms. Set of two wc. Left taller wc
Fairview HS	5/24/2024 7:51	WC-47-FD	<0.500	Right shorter wc in auditorium lobby
Fairview MS	5/24/2024 6:08	FB-01	<0.500	Field Blank; Quality Control Sample
Fairview MS	5/24/2024 6:09	WC-40-FD	<0.500	Right short wc on right side of auditorium
Fairview MS	5/24/2024 6:10	WC-41-FD	<0.500	Left tall wc on right side of auditorium
Fairview MS	5/24/2024 6:11	WC-42-FD	6.04	Right short wc on left side of auditorium
Fairview MS	5/24/2024 6:13	WC-43-FD	<0.500	Left tall wc on left side of auditorium
Fairview MS	5/24/2024 6:15	WC-32-FD	0.761	Across from A117, left cooler has bottle filler; across from A117, left cooler
Fairview MS	5/24/2024 6:16	WC-31-FD	0.662	Across from A117, left cooler; across from A117, right cooler
Fairview MS	5/24/2024 6:18	WC-34-FD	<0.500	Across from A104, left cooler
Fairview MS	5/24/2024 6:19	WC-33-FD	<0.500	Across from A104, right cooler
Fairview MS	5/24/2024 6:21	WC-35-FD	<0.500	Cafeteria drinking fountain
Fairview MS	5/24/2024 6:21	WC-35-FD-D	<0.500	Cafeteria drinking fountain
Fairview MS	5/24/2024 6:24	KT-05-FD	0.804	Kitchen by office (2-bay sink), in front of office window; Kitchen by office (2-bay sink)
Fairview MS	5/24/2024 6:29	WC-37-FD	<0.500	by gym, left WC
Fairview MS	5/24/2024 6:30	WC-36-FD	<0.500	by gym, right WC
Fairview MS	5/24/2024 6:33	WC-21-FD	<0.500	Across from Room B115, B hall, right WC
Fairview MS	5/24/2024 6:34	WC-22-FD	<0.500	Across from Room B115, B hall, left WC, has bottle fill; across from Room B115, B hall, left WC
Fairview MS	5/24/2024 6:36	WC-24-FD-Filtered	1.67	
Fairview MS	5/24/2024 6:38	WC-23-FD	0.586	Across from Room D102, right WC
Fairview MS	5/24/2024 6:40	TL-54-FD	0.562	Room d101
Fairview MS	5/24/2024 6:42	WC-25-FD	0.681	Across from Room C106, right WC, has bottle fill; across from Room C106, right WC
Fairview MS	5/24/2024 6:43	WC-26-FD	<0.500	Across from Room C106, left WC
Fairview MS	5/24/2024 6:48	WC-29-FD	<0.500	Across from Room B106 (left), has bottle fill; across from Room B106 (left)
Fairview MS	5/24/2024 6:49	WC-28-FD	<0.500	Across from Room B106, right WC
Fairview MS	5/24/2024 6:50	NS-48-FD	<0.500	Rm in front of rm b105
Franklin HS	5/17/2024 5:59	FB-01	<0.500	Field Blank; Quality Control Sample
Franklin HS	5/17/2024 6:03	KT-17-FD	<0.500	Food prep sink. Across from freezer.
Franklin HS	5/17/2024 6:10	WC-19-FD	<0.500	Next to entrance. Across from 409. Right fountain. Bottle fill.
Franklin HS	5/17/2024 6:10	WC-19-FD-D	<0.500	Next to entrance. Across from 409. Right fountain. Bottle fill.
Franklin HS	5/17/2024 6:12	WC-20-FD	<0.500	Across from 409. Left fountain. No bottle fill.
Franklin HS	5/17/2024 6:15	TL-23-FD	2.59	Teacher lounge. Next to band room. Room 426.
Franklin HS	5/17/2024 6:16	WC-21-FD	<0.500	Right cooler with bottle filler; adjacent to mens restroom across from Room 203
Franklin HS	5/17/2024 6:18	WC-22-FD	<0.500	Left cooler; adjacent to Room 204
Franklin HS	5/17/2024 6:23	TL-24-FD	<0.500	Room 901. 2nd floor.
Franklin HS	5/17/2024 6:28	WC-04-FD	<0.500	Adjacent to men's restroom across from Room 905, left cooler
Franklin HS	5/17/2024 6:29	WC-25-FD	<0.500	Right with bottle filler; across from Room 409 and women's restroom
Franklin HS	5/17/2024 6:31	WC-18-FD	<0.500	Across from room 205. Next to restrooms. Right fountain. Bottle fill.
Franklin HS	5/17/2024 6:33	WC-03-FD	<0.500	Adjacent to men's restroom across from Room 205, left cooler
Franklin HS	5/17/2024 6:35	WC-02-FD	<0.500	Adjacent to men's restroom across from Room 102, left cooler
Franklin HS	5/17/2024 6:36	WC-15-FD	<0.500	Across from room 104. Next to restrooms. Right fountain. Bottle fill.
Franklin HS	5/17/2024 6:38	TL-16-FD	0.727	Room 100
Franklin HS	5/17/2024 6:40	WC-14-FD	<0.500	Across from room 009. Right fountain. Bottle fill.
Franklin HS	5/17/2024 6:42	WC-13-FD	<0.500	Across from room 009. Left fountain. No bottle fill.
Franklin HS	5/17/2024 6:44	TL-29-FD	<0.500	Room 12. Behind office.
Franklin HS	5/17/2024 6:47	WC-11-FD	<0.500	Across from Concessions. Right fountain. Bottle fill.
Franklin HS	5/17/2024 6:48	WC-12-FD	<0.500	Across from concession. Left fountain. No bottle fill.
Franklin HS	5/17/2024 6:50	WC-06-FD	<0.500	Across from main gym. Left fountain. Tall.
Franklin HS	5/17/2024 6:51	WC-07-FD	<0.500	Across from main gym. Right fountain. Short. Next to boys restroom.
Franklin HS	5/17/2024 6:52	WC-08-FD	<0.500	Across from gym. Next to room 529. Right fountain. Tall.
Franklin HS	5/17/2024 6:57	WC-10-FD	<0.500	Boys locker room
Franklin HS Annex	5/17/2024 7:05	FB-01	<0.500	Field Blank; Quality Control Sample
Franklin HS Annex	5/17/2024 7:09	WC-23-FD	<0.500	Adjacent to girls rest room across from Room A138, single
Franklin HS Annex	5/17/2024 7:10	WC-21-FD	0.519	Adjacent to boys restroom and Room A119, (left) tall
Franklin HS Annex	5/17/2024 7:11	WC-22-FD	<0.500	Adjacent to boys restroom and Room A119, (right) short
Franklin HS Annex	5/17/2024 7:13	TL-24-FD	<0.500	Room A123, teacher work area
Franklin HS Annex	5/17/2024 7:15	WC-25-FD	<0.500	Adjacent to boys restroom (left) across from Room B102, short
Franklin HS Annex	5/17/2024 7:15	WC-25-FD-D	<0.500	Adjacent to boys restroom (left) across from Room B102, short
Franklin HS Annex	5/17/2024 7:17	WC-26-FD	<0.500	Adjacent to boys restroom (right) across from Room B102, tall
Franklin HS Annex	5/17/2024 7:18	KT-27-FD	<0.500	Room B110; kitchenette in large communal hall
Franklin HS Annex	5/17/2024 7:20	WC-28-FD	<0.500	Tall with bottle filter adjacent to elevator in large common hall
Franklin HS Annex	5/17/2024 7:21	WC-29-FD	<0.500	Next to WC28. Short. No bottle fill. Right fountain.
Grassland ES	5/15/2024 6:32	FB-01	<0.500	Field Blank; Quality Control Sample
Grassland ES	5/15/2024 6:37	KT-23-FD	0.574	food prep adjacent to office - used by staff
Grassland ES	5/15/2024 6:41	TL-02-FD	<0.500	Nurse's office, handwashing sink
Grassland ES	5/15/2024 6:43	WC-03-FD	<0.500	Left cooler; adjacent to Room 201
Grassland ES	5/15/2024 6:44	WC-04-FD	<0.500	Right cooler; adjacent to Room 201

WILLIAMSON COUNTY SCHOOLS 2024 DRINKING WATER RESULTS

School Name	Sampled Date/Time	Sample ID	Result	Location Notes
Grassland ES	5/15/2024 6:45	WC-04-FD-Filtered	<0.500	
Grassland ES	5/15/2024 6:48	SOW-07-FD	<0.500	Room 200
Grassland ES	5/15/2024 6:50	SOW-05-FD	<0.500	Room 202
Grassland ES	5/15/2024 6:52	SOW-06-FD	<0.500	Room 204
Grassland ES	5/15/2024 6:54	SOW-08-FD	<0.500	Room 206, SOW to the right
Grassland ES	5/15/2024 6:56	WC-20-FD	<0.500	Right cooler, short; adjacent to Room 302
Grassland ES	5/15/2024 6:58	SOW-22-FD	<0.500	Room 302
Grassland ES	5/15/2024 7:02	WC-22-FD	<0.500	Next to room 402.
Grassland ES	5/15/2024 7:03	WC-22-FD-Filtered	<0.500	
Grassland ES	5/15/2024 7:07	SOW-17-FD	<0.500	Room 406
Grassland ES	5/15/2024 7:10	SOW-18-FD	<0.500	Room 408
Grassland ES	5/15/2024 7:12	SOW-19-FD	<0.500	Room 410
Grassland ES	5/15/2024 7:14	WC-09-FD	<0.500	Left bottle filler; adjacent to women RR next to gym
Grassland ES	5/15/2024 7:15	WC-09-FD-Filtered	<0.500	
Grassland ES	5/15/2024 7:16	WC-10-FD	<0.500	Right cooler; adjacent to men restroom next to gym
Grassland ES	5/15/2024 7:19	WC-11-FD	<0.500	Left cooler; adjacent to Room 503
Grassland ES	5/15/2024 7:19	WC-11-FD-D	<0.500	Left cooler; adjacent to Room 503
Grassland ES	5/15/2024 7:21	WC-12-FD	<0.500	Right cooler, bottle filler; adjacent to Room 503
Grassland ES	5/15/2024 7:22	WC-12-FD-Filtered	<0.500	
Grassland ES	5/15/2024 7:24	SOW-13-FD	0.530	Room 503
Grassland MS	5/15/2024 5:40	FB-01	<0.500	Field Blank; Quality Control Sample
Grassland MS	5/15/2024 5:44	KT-12-FD	<0.500	farthest from cafeteria; left sink
Grassland MS	5/15/2024 5:51	WC-08-FD	0.785	right cooler; cafeteria
Grassland MS	5/15/2024 5:52	WC-24-FD	<0.500	Left tap.
Grassland MS	5/15/2024 5:54	WC-26-FD	<0.500	Boys locker room
Grassland MS	5/15/2024 5:57	WC-28-FD	<0.500	Across from room 505. Next to boys restroom.
Grassland MS	5/15/2024 5:57	WC-28-FD-D	<0.500	Across from room 505. Next to boys restroom.
Grassland MS	5/15/2024 6:00	WC-27-FD	<0.500	Across from room 505. Next to girls restroom
Grassland MS	5/15/2024 6:02	WC-07-FD	<0.500	left; adj to gym and across from Room 503
Grassland MS	5/15/2024 6:03	WC-06-FD	<0.500	right; adjacent to gym and across from Room 503
Grassland MS	5/15/2024 6:06	WC-05-FD	<0.500	left cooler; adjacent to women's restroom & across from Principal's Office
Grassland MS	5/15/2024 6:07	WC-04-FD	<0.500	right cooler with bottle filler; adjacent to women's restroom & across from Principal's Office
Grassland MS	5/15/2024 6:08	WC-04-FD-Filtered	<0.500	
Grassland MS	5/15/2024 6:11	WC-13-FD	<0.500	Left/short cooler; adjacent to men's restroom across from Room 205
Grassland MS	5/15/2024 6:12	WC-14-FD	<0.500	Right/tall cooler with bottle filler adjacent to men's restroom across from Room 205
Grassland MS	5/15/2024 6:13	WC-14-FD-Filtered	<0.500	
Grassland MS	5/15/2024 6:15	WC-9-FD	<0.500	Hallway
Grassland MS	5/15/2024 6:17	WC-10-FD	<0.500	Right WC by Rm 805
Grassland MS	5/15/2024 6:17	WC-10-FD-Filtered	<0.500	
Grassland MS	5/15/2024 6:20	WC-18-FD	8.62	Left cooler; across from Room 714
Grassland MS	5/15/2024 6:22	WC-17-FD	<0.500	Right coole with bottle filler; across from Room 714
Grassland MS	5/15/2024 6:24	WC-19-FD	<0.500	Right/tall cooler; adjacent to Room 111
Grassland MS	5/15/2024 6:25	WC-20-FD	<0.500	Left/short cooler; adjacent to Room 111; leak at base of spout
Grassland MS	5/15/2024 6:27	WC-21-FD	<0.500	Left cooler; adjacent to Room 704
Grassland MS	5/15/2024 6:28	WC-22-FD	<0.500	Right cooler; adjacent to Room 704
Hillsboro ES-MS	5/22/2024 5:51	FB-01	<0.500	Field Blank; Quality Control Sample
Hillsboro ES-MS	5/22/2024 5:56	KT-05-FD	<0.500	Kitchen 3-bay sink, tap on the right near the ice maker; back wall of kitchen
Hillsboro ES-MS	5/22/2024 5:58	WC-48-FD	<0.500	Single wc in cafeteria
Hillsboro ES-MS	5/22/2024 5:58	WC-48-FD-D	<0.500	Single wc in cafeteria
Hillsboro ES-MS	5/22/2024 6:02	WC-39-FD	<0.500	Outside of gym. Right fountain. Bottle fill.
Hillsboro ES-MS	5/22/2024 6:04	WC-40-FD	<0.500	Outside of gym. Left fountain. No bottle fill.
Hillsboro ES-MS	5/22/2024 6:06	WC-41-FD	<0.500	Right WC; Outside of girls' restroom. Right fountain.
Hillsboro ES-MS	5/22/2024 6:08	WC-42-FD	<0.500	Left WC; Outside of boys restroom. Left fountain.
Hillsboro ES-MS	5/22/2024 6:10	WC-51-FD	<0.500	Theater building. Next to the boys' restroom. Right fountain.
Hillsboro ES-MS	5/22/2024 6:13	WC-49-FD	<0.500	Auditorium, left taller wc next to men's rr; Theater. Next to the boys' restroom. Left fountain.
Hillsboro ES-MS	5/22/2024 6:15	WC-50-FD	<0.500	Auditorium, right taller wc next to women's rr; Theater. Next to the girls' restroom. Right fountain.
Hillsboro ES-MS	5/22/2024 6:17	WC-52-FD	<0.500	Theater. Next to the girls' restroom. Left fountain.
Hillsboro ES-MS	5/22/2024 6:20	WC-44-FD	<0.500	In hallway to the right of cafeteria doors. In front of conference room near main office. Left wc with bottle filler; Across from conference room. Left fountain. Has bottle fill.
Hillsboro ES-MS	5/22/2024 6:22	WC-45-FD	<0.500	In hallway to the right of cafeteria doors. In front of conference room near main office. Right wc with no bottle filler.; Across from conference room. Right fountain. No bottle fill.
Hillsboro ES-MS	5/22/2024 6:24	WC-32-FD	<0.500	WC next to library; Outside the library
Hillsboro ES-MS	5/22/2024 6:26	WC-34-FD	<0.500	Next to electrical room, left WC; Across from room 24. Left fountain. No bottle fill.
Hillsboro ES-MS	5/22/2024 6:28	WC-33-FD	<0.500	Next to electrical room, right WC; Across from room 24. Right fountain. Has bottle fill.

WILLIAMSON COUNTY SCHOOLS 2024 DRINKING WATER RESULTS

School Name	Sampled Date/Time	Sample ID	Result	Location Notes
Hillsboro ES-MS	5/22/2024 6:32	WC-30-FD	<0.500	Across from Room 7, right; Across from room 6. Left fountain.
Hillsboro ES-MS	5/22/2024 6:33	WC-31-FD	<0.500	Across from Room 7, left; Across from room 6. Right fountain.
Hillsboro ES-MS	5/22/2024 6:36	SOW-46-FD	0.584	Room 9C
Hillsboro ES-MS	5/22/2024 6:38	SOW-47-FD	<0.500	Room 10B or 10C
Hillsboro ES-MS	5/22/2024 6:43	WC-43-FD	<0.500	Outside nurses station
Hillsboro ES-MS	5/22/2024 6:45	NS-42-FD	<0.500	In nurses station
Hillsboro ES-MS	5/22/2024 6:47	SOW-26-FD	<0.500	Room 4
Hillsboro ES-MS	5/22/2024 6:49	SOW-25-FD	1.08	Room 3
Hunters Bend ES	5/10/2024 7:14	FB-01	<0.500	Field Blank; Quality Control Sample
Hunters Bend ES	5/10/2024 7:19	KT-42-FD	<0.500	Adjacent to kitchen office
Hunters Bend ES	5/10/2024 7:19	KT-42-FD-D	<0.500	Adjacent to kitchen office
Hunters Bend ES	5/10/2024 7:23	WC-21-FD	<0.500	Water cooler no bottle filler. adjacent to, server room, left unit
Hunters Bend ES	5/10/2024 7:23	WC-22-FD	<0.500	Water cooler with bottle filler. adjacent to, server room
Hunters Bend ES	5/10/2024 7:27	TL-52-FD	<0.500	Adj 117
Hunters Bend ES	5/10/2024 7:30	WC-40-FD	<0.500	Right adjacent to end of hall junction/adjacent to Room 201
Hunters Bend ES	5/10/2024 7:31	WC-41-FD	<0.500	Left adjacent to double doors/adjacent to Room 201
Hunters Bend ES	5/10/2024 7:34	SOW-43-FD	<0.500	Room 205
Hunters Bend ES	5/10/2024 7:36	SOW-38-FD	<0.500	Room 208
Hunters Bend ES	5/10/2024 7:39	SOW-23-FD	3.66	Room 301 adjacent to exterior door
Hunters Bend ES	5/10/2024 7:41	WC-24-FD	<0.500	Left, adjacent to Room 303
Hunters Bend ES	5/10/2024 7:41	WC-25-FD	<0.500	Right, adjacent to double doors
Hunters Bend ES	5/10/2024 7:43	SOW-51-FD	0.642	Room 305
Hunters Bend ES	5/10/2024 7:46	SOW-49-FD	1.66	Room 308
Hunters Bend ES	5/10/2024 7:49	SOW-27-FD	7.05	Room 311
Hunters Bend ES	5/10/2024 7:53	SOW-32-FD	1.02	Room 404
Hunters Bend ES	5/10/2024 7:56	SOW-45-FD	0.657	Room 505
Hunters Bend ES	5/10/2024 7:58	SOW-46-FD	<0.500	Room 508
Hunters Bend ES	5/10/2024 8:01	WC-34-FD	<0.500	right adjacent to Room 509
Hunters Bend ES	5/10/2024 8:01	WC-35-FD	<0.500	left adjacent to Room 507
Hunters Bend ES	5/10/2024 8:05	SOW-31-FD	1.93	Room 409
Hunters Bend ES	5/10/2024 8:07	WC-28-FD	<0.500	Right cooler, adjacent to women's restroom
Hunters Bend ES	5/10/2024 8:08	WC-29-FD	<0.500	Left cooler, adjacent to mens restroom
Hunters Bend ES	5/10/2024 8:11	SOW-30-FD	1.65	Room 411
Lipscomb ES	5/15/2024 7:28	FB-01	<0.500	Field Blank; Quality Control Sample
Lipscomb ES	5/15/2024 7:30	KT-02-FD	<0.500	Food prep sink; Kitchen sink in back corner of kitchen next to mechanical room
Lipscomb ES	5/15/2024 7:32	WC-21-FD	<0.500	outside Room 303 left cooler has bottle fill ; outside Room 303 left cooler
Lipscomb ES	5/15/2024 7:34	WC-22-FD	<0.500	outside Room 303 right cooler
Lipscomb ES	5/15/2024 7:35	SOW-46-FD	<0.500	Rm 306
Lipscomb ES	5/15/2024 7:36	SOW-23-FD	<0.500	Room 305
Lipscomb ES	5/15/2024 7:38	SOW-24-FD	<0.500	Room 309
Lipscomb ES	5/15/2024 7:40	SOW-47-FD	<0.500	Rm 312
Lipscomb ES	5/15/2024 7:40	SOW-47-FD-D	<0.500	Rm 312
Lipscomb ES	5/15/2024 7:42	SOW-48-FD	<0.500	Rm 311
Lipscomb ES	5/15/2024 7:44	SOW-25-FD	<0.500	Room 313
Lipscomb ES	5/15/2024 7:45	SOW-42-FD	<0.500	Room 317
Lipscomb ES	5/15/2024 7:46	SOW-26-FD	<0.500	Room 318
Lipscomb ES	5/15/2024 7:49	WC-38-FD	<0.500	outside Room 200, right cooler
Lipscomb ES	5/15/2024 7:50	WC-37-FD	<0.500	Left wc outside rm 200 has bottle filler; outside Room 200, left cooler
Lipscomb ES	5/15/2024 7:52	SOW-39-FD	<0.500	In Room 200
Lipscomb ES	5/15/2024 7:54	SOW-41-FD	<0.500	In Room 202
Lipscomb ES	5/15/2024 7:55	SOW-40-FD	<0.500	In Room 203
Lipscomb ES	5/15/2024 7:56	SOW-04-FD	<0.500	Room 205
Lipscomb ES	5/15/2024 7:58	SOW-45-FD	<0.500	Room 204
Lipscomb ES	5/15/2024 8:00	SOW-43-FD	<0.500	Room 402
Lipscomb ES	5/15/2024 8:02	WC-30-FD	<0.500	Outside Room 501/505
Lipscomb ES	5/15/2024 8:04	WC-35-FD	<0.500	Outside locker rooms, left cooler;outside gym, left cooler
Lipscomb ES	5/15/2024 8:05	WC-36-FD	<0.500	Outside locker rooms, right cooler;outside gym, right cooler
Lipscomb ES	5/15/2024 8:07	SOW-06-FD	<0.500	Room 410
Oak View ES	5/8/2024 8:05	FB-01	<0.500	Field Blank; Quality Control Sample
Oak View ES	5/8/2024 8:06	WC-10-FD	0.615	WC on the right, across hall from Room 301
Oak View ES	5/8/2024 8:10	SOW-11-FD	<0.500	Room 304
Oak View ES	5/8/2024 8:14	SOW-12-FD	<0.500	Room 307
Oak View ES	5/8/2024 8:18	SOW-13-FD	<0.500	Room 204
Oak View ES	5/8/2024 8:20	SOW-22-FD	1.25	Room 209
Oak View ES	5/8/2024 8:24	WC-16-FD	<0.500	Sink on the right, across hall from the Gym
Oak View ES	5/8/2024 8:27	SOW-05-FD	<0.500	Room 212
Oak View ES	5/8/2024 8:30	SOW-17-FD	<0.500	Room 211
Oak View ES	5/8/2024 8:33	SOW-15-FD	<0.500	Room 501
Oak View ES	5/8/2024 8:36	SOW-14-FD	<0.500	Room 205

WILLIAMSON COUNTY SCHOOLS 2024 DRINKING WATER RESULTS

School Name	Sampled Date/Time	Sample ID	Result	Location Notes
Oak View ES	5/8/2024 8:40	SOW-18-FD	0.716	Room 506
Oak View ES	5/8/2024 8:47	SOW-19-FD	<0.500	Room 507
Oak View ES	5/8/2024 8:49	SOW-21-FD	<0.500	Room 511
Oak View ES	5/8/2024 8:54	SOW-04-FD	<0.500	Room 513, to the left
Oak View ES	5/8/2024 8:58	WC-07-FD	<0.500	WC on the right, across hall from Room 402
Oak View ES	5/8/2024 9:02	WC-58-FD	<0.500	left WC with bottle filler, in front of rm 402
Oak View ES	5/8/2024 9:06	SOW-09-FD	<0.500	Room 405
Oak View ES	5/8/2024 9:08	SOW-25-FD	<0.500	Room 407
Oak View ES	5/8/2024 9:12	SOW-03-FD	<0.500	Room 409
Oak View ES	5/8/2024 9:14	SOW-26-FD	<0.500	Room 410
Oak View ES	5/8/2024 9:20	TL-40-FD	<0.500	Teacher's lounge sink
Oak View ES	5/8/2024 9:24	KT-02-FD	<0.500	Kitchen; Adjacent to the office and fire extinguisher
Oak View ES	5/8/2024 9:24	KT-02-FD-D	<0.500	Kitchen; Adjacent to the office and fire extinguisher
Oak View ES	5/8/2024 9:27	KT-06-FD	<0.500	Sink on the right, in the corner
Page HS	5/8/2024 10:20	FB-01	<0.500	Field Blank; Quality Control Sample
Page HS	5/8/2024 10:25	WC-20-FD	<0.500	Front right area of gym, left cooler
Page HS	5/8/2024 10:26	WC-21-FD	<0.500	Front area of gym, right cooler
Page HS	5/8/2024 10:30	WC-43-FD	<0.500	Front area of gym, middle cooler, w bottle filler ; Library. left fountain
Page HS	5/8/2024 10:34	WC-23-FD	<0.500	Back right corner of gym
Page HS	5/8/2024 10:34	WC-23-FD-D	<0.500	Back right corner of gym
Page HS	5/8/2024 10:37	WC-22-FD	<0.500	Back left corner of gym
Page HS	5/8/2024 10:45	WC-37-FD	<0.500	Auditorium lobby, left (Arno Road) side, right lower unit; auditorium lobby, right cooler
Page HS	5/8/2024 10:47	WC-36-FD	<0.500	Auditorium lobby, left (Arno Road) side, left upper unit; auditorium lobby, left cooler
Page HS	5/8/2024 10:50	WC-35-FD	<0.500	Auditorium lobby, right (parking lot) side, right lower unit; auditorium lobby, right cooler
Page HS	5/8/2024 10:51	WC-34-FD	<0.500	Auditorium lobby, right side, left upper unit; auditorium lobby, left cooler
Page HS	5/8/2024 10:55	WC-44-FD	<0.500	Auditorium back hallway(parking lot side)/lobby, left cooler w/ bottle filler
Page HS	5/8/2024 10:56	WC-45-FD	<0.500	Auditorium back hallway (parkinglot side)/lobby, right cooler; Left fountain. Across from room 132. OFFICE AREA
Page HS	5/8/2024 11:01	WC-46-FD	<0.500	Auditorium back hallway(road side)/lobby, left cooler; Right fountain across from room 132. Office areas.
Page HS	5/8/2024 11:05	WC-47-FD	<0.500	Auditorium back hallway(road side)/lobby, right cooler, lower unit, w bottle filler
Page MS	5/8/2024 8:49	FB-01	<0.500	Field Blank; Quality Control Sample
Page MS	5/8/2024 8:59	WC-25-FD	<0.500	WC w/ bottle filler (right side); in common area, right cooler
Page MS	5/8/2024 9:02	WC-23-FD	0.973	WC RIGHT SIDE, ADJ TO TROPHY CASE/GYM; outside gym, by music/band rooms
Page MS	5/8/2024 9:05	WC-20-FD	<0.500	WC left side adj girls restroom no bottle filler ; outside gym, by bathrooms, left cooler
Page MS	5/8/2024 9:10	WC-21-FD	<0.500	WC right side adj boys restroom; bottle filler ; outside gym, by bathrooms, right cooler
Page MS	5/8/2024 9:14	KT-33-FD	0.526	Food prep right; Kitchen dish, left tap
Page MS	5/8/2024 9:16	KT-34-FD	<0.500	Food prep left ; Kitchen dish, right tap
Page MS	5/8/2024 9:20	WC-28-FD	<0.500	SOW w bottle filler right side;adj boys restroom/E5 ; by bathroom & conference room, right cooler
Page MS	5/8/2024 9:24	WC-03-FD	0.625	Right unit adj CR D5; Fountain on the right, next to room D5
Page MS	5/8/2024 9:28	WC-29-FD	1.61	RIGHT UNIT ACROSS FROM CR C6; outside Room c-5, left cooler
Page MS	5/8/2024 9:28	WC-29-FD-D	1.57	RIGHT UNIT ACROSS FROM CR C6; outside Room c-5, left cooler
Page MS	5/8/2024 9:35	WC-30-FD	1.38	LEFT UNIT ACROSS FROM CR C6; outside Room c-5, right cooler
Page MS	5/8/2024 9:39	WC-31-FD	<0.500	Left upper unit across CR C14, ADJ RESTROOM ; outside Room c-14, left cooler
Page MS	5/8/2024 9:40	WC-32-FD	<0.500	Right Lower unit across from CR C14, ADJ C11; outside Room c-14, right cooler
Page MS	5/8/2024 9:45	WC-27-FD	<0.500	By bathroom & conference room, left cooler;left unit no bottle filler
Page MS	5/8/2024 9:49	WC-37-FD	0.596	Adj D5, left unit
Page MS	5/8/2024 9:54	WC-38-FD	<0.500	Adj restroom, special needs cr; Next to room 111. Left fountain. No bottle fill.
Page MS	5/8/2024 9:58	WC-24-FD	<0.500	In common area, left cooler;left unit no bottle filler
Page MS	5/8/2024 10:01	WC-36-FD	5.01	Right unit adj exit doors near auditorium ; new southern wing/addition of school, near southern entrance in auditorium hallway, right cooler
Page MS	5/8/2024 10:03	WC-35-FD	5.22	Left unit adj storage closet near auditorium ; new southern wing/addition of school, near southern entrance in auditorium hallway, left cooler
Page MS	5/8/2024 10:05	WC-39-FD	<0.500	Next to room 111 and girls restroom. Right fountain. No bottle fill.
Pinewood ES	5/22/2024 7:11	FB-01	<0.500	Field Blank; Quality Control Sample
Pinewood ES	5/22/2024 7:16	WC-04-FD	<0.500	Hallway near lobby (outside Room 3)
Pinewood ES	5/22/2024 7:16	WC-04-FD-D	<0.500	Hallway near lobby (outside Room 3)
Renaissance HS	5/8/2024 7:16	WC-06-FD	<0.500	Right WC with filter. 1st floor lobby
Renaissance HS	5/8/2024 7:16	FB-01	<0.500	Field Blank; Quality Control Sample
Renaissance HS	5/8/2024 7:19	WC-01-FD	<0.500	Left Cooler. Lobby of 1st floor
Renaissance HS	5/8/2024 7:21	WC-07-FD	<0.500	Right WC with filter. 2nd floor
Renaissance HS	5/8/2024 7:21	WC-07-FD-D	<0.500	Right WC with filter. 2nd floor
Renaissance HS	5/8/2024 7:27	WC-04-FD	<0.500	Adjacent to Room 204 and stairwell door, left cooler. 2nd floor
Renaissance HS	5/8/2024 7:29	WC-05-FD	<0.500	Right WC. Basement floor

WILLIAMSON COUNTY SCHOOLS 2024 DRINKING WATER RESULTS

School Name	Sampled Date/Time	Sample ID	Result	Location Notes
Renaissance HS	5/8/2024 7:35	WC-02-FD	<0.500	Across the hallway from women's restroom, adjacent to exterior exit, left cooler. Basement floor
Scales ES	5/10/2024 7:29	KT-02-FD	<0.500	Kitchen sink closest to storage;Kitchen
Scales ES	5/10/2024 7:29	FB-01	<0.500	Field Blank; Quality Control Sample
Scales ES	5/10/2024 7:32	WC-13-FD	<0.500	Cafeteria to the Right of stage; WC to right of stage, has bottle filler
Scales ES	5/10/2024 7:32	WC-13-FD-D	<0.500	Cafeteria to the Right of stage; WC to right of stage, has bottle filler
Scales ES	5/10/2024 7:36	WC-20-FD	<0.500	Bubbler on far side wall, away from stage; Cafeteria, WC by 40s rooms
Scales ES	5/10/2024 7:38	WC-46-FD	<0.500	40s hallway, right side of room, right WC
Scales ES	5/10/2024 7:39	WC-21-FD	<0.500	Bubbler on right side of the room, Bubbler on the left; 40s hallway, right side of room, left WC
Scales ES	5/10/2024 7:41	WC-47-FD	<0.500	40s hallway, left side of room, left WC
Scales ES	5/10/2024 7:42	WC-22-FD	<0.500	Bubbler on left side of the room, Bubbler on the right; 40s hallway, left side of room, right WC
Scales ES	5/10/2024 7:43	WC-9-FD	<0.500	Outside gym, left WC
Scales ES	5/10/2024 7:48	WC-48-FD	<0.500	20s hallway, left side of room, by Room 24, left WC
Scales ES	5/10/2024 7:50	WC-23-FD	<0.500	Bubbler on left side of the room, Bubbler on the right; 20s hallway, left side of room, by Room 24, right WC
Scales ES	5/10/2024 7:51	WC-24-FD	<0.500	Bubbler on right side of the room, Bubbler on the left; 20s hallway, by Room 22, right WC
Scales ES	5/10/2024 7:52	WC-49-FD	<0.500	20s hallway, by Room 22, left WC
Scales ES	5/10/2024 7:56	WC-41-FD	<0.500	Next to mechanical room, right WC
Scales ES	5/10/2024 7:57	WC-40-FD	<0.500	Next to mechanical room, left WC
Scales ES	5/10/2024 8:00	WC-50-FD	<0.500	Next to School office reception, right
Scales ES	5/10/2024 8:01	WC-51-FD	<0.500	Next to School office reception, left
Scales ES	5/10/2024 8:07	WC-14-FD	<0.500	bubbler on left side of the room, bubbler on the right
Scales ES	5/10/2024 8:09	WC-42-FD	<0.500	WC to right of room, next to Room 35 & 39, right WC
Scales ES	5/10/2024 8:10	WC-15-FD	<0.500	Pod/ common area in 30s block; bubbler on right side of the room, bubbler on the left
Scales ES	5/10/2024 8:13	WC-18-FD	<0.500	bubbler on left side of hallway, bubbler on the left
Scales ES	5/10/2024 8:15	WC-45-FD	<0.500	hallway of 50s rooms, right WC next to conference room & bathrooms
Scales ES	5/10/2024 8:17	SOW-19-FD	<0.500	Room 54
Scales ES	5/10/2024 8:21	SOW-33-FD	<0.500	Room 53
Trinity ES	5/17/2024 6:00	FB-01	<0.500	Field Blank; Quality Control Sample
Trinity ES	5/17/2024 6:02	KT-49-FD	<0.500	Kitchen sink to the right, left fixture; Kitchen sink to the right
Trinity ES	5/17/2024 6:06	WC-39-FD	<0.500	Hall outside cafeteria, left cooler
Trinity ES	5/17/2024 6:08	WC-40-FD	<0.500	Hall outside cafeteria, right cooler
Trinity ES	5/17/2024 6:10	WC-35-FD	<0.500	Outside Room 402, right cooler
Trinity ES	5/17/2024 6:11	WC-34-FD	<0.500	Outside Room 402, left cooler
Trinity ES	5/17/2024 6:13	SOW-36-FD	1.14	Room 404
Trinity ES	5/17/2024 6:14	SOW-37-FD	<0.500	Room 403
Trinity ES	5/17/2024 6:16	SOW-48-FD	<0.500	Room 405
Trinity ES	5/17/2024 6:16	SOW-48-FD-D	<0.500	Room 405
Trinity ES	5/17/2024 6:22	WC-29-FD	<0.500	Outside Room 302, left cooler
Trinity ES	5/17/2024 6:23	WC-30-FD	<0.500	Outside Room 302, right cooler
Trinity ES	5/17/2024 6:24	SOW-31-FD	<0.500	Room 304
Trinity ES	5/17/2024 6:26	SOW-32-FD	<0.500	Room 305
Trinity ES	5/17/2024 6:28	SOW-33-FD	<0.500	Room 307
Trinity ES	5/17/2024 6:29	SOW-06-FD	<0.500	Room 310
Trinity ES	5/17/2024 6:32	WC-05-FD	<0.500	Near room 202, left wc; Near room 202
Trinity ES	5/17/2024 6:33	WC-20-FD	<0.500	Outside Room 202, yellow hall, right wc with bottle filler; outside Room 202, yellow hall
Trinity ES	5/17/2024 6:36	SOW-23-FD	<0.500	Room 215
Trinity ES	5/17/2024 6:38	SOW-21-FD	<0.500	In Room 213
Trinity ES	5/17/2024 6:41	WC-47-FD	<0.500	Single WC in between 100s and 200s hallway, has bottle filler; Single WC in between 100s and 200s hallway
Trinity ES	5/17/2024 6:43	TL-50-FD	<0.500	Main office teacher's lounge
Trinity ES	5/17/2024 6:46	SOW-26-FD	<0.500	Room 102
Trinity ES	5/17/2024 6:49	WC-43-FD	<0.500	Left WC in between gym and main office has bottle filler; Left WC in between gym and main office
Trinity ES	5/17/2024 6:50	WC-44-FD	<0.500	Right WC in between gym and main office
Walnut Grove ES	5/10/2024 5:53	FB-01	<0.500	Field Blank; Quality Control Sample
Walnut Grove ES	5/10/2024 6:00	KT-22-FD	1.32	Hand wash sink adjacent to dish wash station
Walnut Grove ES	5/10/2024 6:04	WC-05-FD	<0.500	Left unit w/bottle filler, adj Room 617; left WC in between cafeteria and 700s hallway
Walnut Grove ES	5/10/2024 6:06	WC-04-FD	<0.500	Right unit no bottle filler, adj Room 617; right WC in between cafeteria and 700s hallway
Walnut Grove ES	5/10/2024 6:09	WC-32-FD	<0.500	Single with bottle filler adj to 613
Walnut Grove ES	5/10/2024 6:13	WC-44-FD	0.547	Single unit adj Room 608/609
Walnut Grove ES	5/10/2024 6:17	WC-37-FD	<0.500	Single, adjacent to Room 603
Walnut Grove ES	5/10/2024 6:20	WC-42-FD	<0.500	Next to gym across from Room 401, right cooler
Walnut Grove ES	5/10/2024 6:22	WC-43-FD	<0.500	Next to gym across from Room 401, left cooler
Walnut Grove ES	5/10/2024 6:27	SOW-45-FD	<0.500	Room 804;room 304

WILLIAMSON COUNTY SCHOOLS 2024 DRINKING WATER RESULTS

School Name	Sampled Date/Time	Sample ID	Result	Location Notes
Walnut Grove ES	5/10/2024 6:31	SOW-46-FD	<0.500	CR 303
Walnut Grove ES	5/10/2024 6:36	OW-47-FD	<0.500	cr 806
Walnut Grove ES	5/10/2024 6:38	OW-38-FD	<0.500	Room 808
Walnut Grove ES	5/10/2024 6:41	OW-05-FD	<0.500	Room 802
Walnut Grove ES	5/10/2024 6:42	OW-05-FD-D	<0.500	Room 802
Walnut Grove ES	5/10/2024 6:48	WC-35-FD	<0.500	Adjacent to mens restroom, right cooler
Walnut Grove ES	5/10/2024 6:50	WC-33-FD	<0.500	Adjacent to room 102, right cooler
Walnut Grove ES	5/10/2024 6:51	WC-34-FD	<0.500	Adjacent to mens restroom, left cooler
Walnut Grove ES	5/10/2024 6:54	WC-28-FD	<0.500	Adjacent to electrical closet, left cooler
Walnut Grove ES	5/10/2024 6:55	WC-29-FD	<0.500	Adjacent to Room 702, right cooler
Walnut Grove ES	5/10/2024 6:58	SOW-48-FD	0.618	cr 704
Walnut Grove ES	5/10/2024 7:00	SOW-31-FD	<0.500	Room 709
Walnut Grove ES	5/10/2024 7:03	WC-27-FD	<0.500	In admin office hall
Walnut Grove ES	5/10/2024 7:04	TL-26-FD	<0.500	Teacher lounge
Walnut Grove ES	5/10/2024 8:54	KT-23-FD	<0.500	Prep sink adjacent to Room 507
Woodland MS	5/10/2024 6:08	FB-01	<0.500	Field Blank; Quality Control Sample
Woodland MS	5/10/2024 6:09	KT-03-FD	0.672	kitchen food prep to the left of entry; kitchen dish
Woodland MS	5/10/2024 6:15	WC-45-FD	<0.500	Boys locker room, has bottle filler
Woodland MS	5/10/2024 6:16	WC-38-FD	<0.500	in girls locker room, has bottle filler;
Woodland MS	5/10/2024 6:19	WC-23-FD	<0.500	outside restrooms @ gym, left cooler
Woodland MS	5/10/2024 6:20	WC-24-FD	<0.500	outside restrooms @ gym, right cooler
Woodland MS	5/10/2024 6:22	WC-43-FD	<0.500	WC outside gym near cafeteria, left
Woodland MS	5/10/2024 6:24	WC-21-FD	<0.500	cafeteria, left cooler, has bottle filler; cafeteria, left cooler
Woodland MS	5/10/2024 6:28	WC-04-FD	<0.500	Cafeteria, right cooler
Woodland MS	5/10/2024 6:30	WC-27-FD	<0.500	Outside rm109, left cooler, btw bathrooms; outside office, left cooler
Woodland MS	5/10/2024 6:30	WC-27-FD-D	<0.500	Outside rm109, left cooler, btw bathrooms; outside office, left cooler
Woodland MS	5/10/2024 6:33	WC-28-FD	<0.500	Outside rm109, right cooler, btw bathrooms, has bottle filler; outside office, right cooler
Woodland MS	5/10/2024 6:36	TL-47-FD	<0.500	Teachers lounge near cafeteria and rm 207
Woodland MS	5/10/2024 6:38	WC-31-FD	<0.500	Outside Room 210, right cooler
Woodland MS	5/10/2024 6:40	WC-32-FD	<0.500	Outside Room 217, right WC; outside Room 217
Woodland MS	5/10/2024 6:45	WC-33-FD	<0.500	Outside Room 219, left taller wc; outside Room 219
Woodland MS	5/10/2024 6:47	WC-34-FD	<0.500	Outside Room 308 left
Woodland MS	5/10/2024 6:48	WC-35-FD	<0.500	Outside Room 308, right cooler
Woodland MS	5/10/2024 6:50	WC-37-FD	<0.500	Outside Room 118, right cooler, outside bathrooms; outside Room 118, right cooler
Woodland MS	5/10/2024 6:51	WC-36-FD	<0.500	Outside Room 118, left cooler, taller, next to bathroom, has bottle filler; outside Room 118, left cooler
Woodland MS	5/10/2024 6:53	WC-06-FD	<0.500	Outside Room 312, right cooler; outside Room 312, left cooler
Woodland MS	5/10/2024 6:54	WC-39-FD	<0.500	Across from room 313. Left fountain.
Woodland MS	5/10/2024 6:59	WC-30-FD	<0.500	Outside Room 200/202, right cooler

FIXTURE TYPE	
SOW	Sink with Bubblers
WC	Water Cooler
KT	Kitchen Tap
OW	Drinking Water Bubblers
NS	Nurse's Clinic
TL	Teacher's Lounge
FB	Quality Control Field Blank

Notes:

- Results are in parts per billion (ppb).
- "-FD" sample ID suffix indicates sample is a First Draw sample collected from a fixture.
- "-FD-D" sample ID suffix indicates a duplicate First Draw sample collected from a fixture concurrently with another First Draw sample from same fixture for quality control.
- "FB-01" sample is a Field Blank sample of distilled water poured into a container in the field & shipped to laboratory with field samples for quality control purposes.