

1320 West Main Street, Suite 202
Franklin, Tennessee 37064-3700
Phone: (615) 472-4000
Fax: (615) 472-4190
Website: <https://www.wcs.edu>



Lead in Drinking Water Results May 11, 2020

To: Parents, Guardians, and Employees of Grassland Middle School, Page High School, Page Middle School, Pinewood Annex, and Scales Elementary School

This notice is sent to inform all Parents, Guardians and Employees in the above schools of our efforts to comply with regulations related to testing for lead in the drinking water of schools. Tennessee Code Annotated 49-2-133 became effective on 1 January 2019 and requires drinking water sources in schools built prior to 1 January 1998 to be tested for lead levels at least biennially. The law requires this testing to be done in such a manner that the water drawn has been standing in the plumbing overnight, thus, it is best done while school is not in session.

We have hired an outside environmental firm to conduct the sampling and analysis. We started the 2-year cycle of testing in June 2019 and were planning on completing the cycle during the summer of 2020. Given the current school closure due to the COVID19 pandemic, we decided to do the testing the week of 20 April 2020. The pre-flush and first draw protocol prescribed in the law were followed and we obtained 554 samples from 26 schools. Each batch of samples from a school included a field blank quality control sample of distilled water that was inserted into the batches prior to sending them to a third-party testing laboratory.

We received the lab results of those samples on 5 May 2020. The results show 8 samples had lead levels that were above 20 ppb. Those samples were drawn from Grassland MS(1), Page HS(2), Page MS(2), Pinewood Annex(2), and Scales ES(1). The numbers in parenthesis indicates the number of samples at each school that tested above the 20 ppb level. The drinking water sources (water fountains, bubblers, sinks, etc.) that these samples were drawn from have been taken out of service and will be replaced.

We suspect that one of the issues causing some of the high levels was the long period of time this water had been standing in the plumbing given that school had been closed for over a month at the time of testing. Despite this long closure period, we decided to go ahead with the testing without changing the pre-flushing protocol from what we had used for previous samplings. We felt this would preserve transparency across previous and subsequent samplings. Thus, this low number of high-level results is very informative as it shows an overall high level of health of our drinking water systems even given a prolonged standing period.

If you want to review the entire set of sampling results you can do so [by going to the Public Notice page on the WCS website](#) and scrolling to “*Lead Testing Data for Williamson County Schools*” and select the data for April 2020. You will see the results grouped by school, with a description of each sample and where it was drawn from. Questions about these results and/or our lead testing program can be directed to our Maintenance Director, Adam Christopher at his e-mail address, adam.christopher@wcs.edu.

Sincerely,

A handwritten signature in black ink, appearing to read 'Mark B. Samuels', with a long horizontal flourish extending to the right.

Mark B. Samuels, PE
Assistant Superintendent of Operations

Revised: May 11, 2020

LEAD ANALYSIS RESULTS FROM DRINKING WATER SAMPLING ACTIVITIES (April 21-23, 2020)

School	Room No./Location	Sample ID	Fixture Type	Sample Date	Result (ppb)	Notes
BethesdaES		FB-01	Field Blank	4/22/2020	ND	
BethesdaES	Hallway	WC-20-FD	Bubbler with Cooler	4/22/2020	ND	next to mechanical room
BethesdaES	Hallway	WC-21-FD	Bubbler with Cooler	4/22/2020	ND	between Room 202 & boys' bathroom, left WC & sampled from bottle filler
BethesdaES	Hallway	WC-22-FD	Bubbler with Cooler	4/22/2020	ND	between Room 202 & boys' bathroom, right WC
BethesdaES	Hallway	SOW-23-FD	Sink with Bubbler	4/22/2020	2.85	Room 302, to the left, bubbler leaks
BethesdaES	302	SOW-24-FD	Sink with Bubbler	4/22/2020	ND	Room 301, to the right
BethesdaES	301	SOW-25-FD	Sink with Bubbler	4/22/2020	2.05	Room 304, to the right, leaks water
BethesdaES	304	SOW-26-FD	Sink with Bubbler	4/22/2020	ND	Room 303, to the left
BethesdaES	303	SOW-27-FD	Sink with Bubbler	4/22/2020	3.51	Room 305, to the right
BethesdaES	305	SOW-28-FD	Sink with Bubbler	4/22/2020	5.89	Room 306, to the left, leaks some water
BethesdaES	306	SOW-29-FD	Sink with Bubbler	4/22/2020	ND	Room 307, to the left
BethesdaES	307	SOW-30-FD	Sink with Bubbler	4/22/2020	ND	Room 308, to the right
BethesdaES	308	SOW-30-FD-D	Sink with Bubbler	4/22/2020	0.576	Room 308, to the right
BethesdaES	308	WC-31-FD	Bubbler with Cooler	4/22/2020	ND	next to Room 616 (office/admin) door. Sample taken from bottle filler
BethesdaES	Hallway	TL-32-FD	Sink	4/22/2020	0.577	sink in teacher's lounge
BethesdaES	Teacher's Lounge	NS-33-FD	Sink	4/22/2020	1.73	sink in nurse's clinic
BethesdaES	Nurse's Clinic	WC-34-FD	Bubbler with Cooler	4/22/2020	ND	left WC, next to Room 201 & boy's restroom
BethesdaES	Hallway	SOW-35-FD	Sink with Bubbler	4/22/2020	ND	Room 111, to the left
BethesdaES	111	WC-36-FD	Bubbler with Cooler	4/22/2020	ND	next to Room 613 (office room)
BethesdaES	Hallway	SOW-37-FD	Sink with Bubbler	4/22/2020	1.59	Room 701, music room. To the right
BethesdaES	701	SOW-38-FD	Sink with Bubbler	4/22/2020	2.82	Room 703, art room, bubbler has paint on it, dirty sink
BethesdaES	703	WC-39-FD	Bubbler with Cooler	4/22/2020	ND	WC on left with bottle filler. Sampling from bottle filler
BethesdaES	Hallway	WC-40-FD	Bubbler with Cooler	4/22/2020	ND	WC in cafeteria
BethesdaES	Cafeteria	KT-41-FD	Kitchen Tap	4/22/2020	ND	kitchen tap on the left, furthest from the door, 3 bay sink
BethesdaES	Kitchen	IM-42-FD	Ice Maker	4/22/2020	ND	ice maker
BrentwoodHS		FB-01	Field Blank	4/23/2020	ND	
BrentwoodHS	Hallway	WC-20-FD	Bubbler with Cooler	4/23/2020	1.2	WC in lobby hallway in front of cafeteria, left (taller) WC
BrentwoodHS	Hallway	WC-21-FD	Bubbler with Cooler	4/23/2020	0.906	WC in lobby hallway in front of cafeteria, right (shorter) WC
BrentwoodHS	Nurses Clinic	NS-22-FD	Sink	4/23/2020	0.79	sink in nurse's clinic
BrentwoodHS	Hallway	WC-23-FD	Bubbler with Cooler	4/23/2020	ND	WC next to C4 & C5 rooms, left (taller) WC
BrentwoodHS	Hallway	WC-24-FD	Bubbler with Cooler	4/23/2020	ND	WC next to C4 & C5 rooms, right (shorter) WC
BrentwoodHS	Hallway	WC-25-FD	Bubbler with Cooler	4/23/2020	ND	WC next to room C2, in front of library, left (taller) WC, sampled from bottle filler
BrentwoodHS	Hallway	WC-26-FD	Bubbler with Cooler	4/23/2020	ND	WC next to room C2, in front of library, right (shorter) WC
BrentwoodHS	Hallway	WC-27-FD	Bubbler with Cooler	4/23/2020	1.17	WC in front of Room A1, (taller) left WC
BrentwoodHS	Hallway	WC-28-FD	Bubbler with Cooler	4/23/2020	1.75	WC in front of Room A1, (shorter) right WC
BrentwoodHS	Hallway	WC-28-FD-D	Bubbler with Cooler	4/23/2020	1.89	WC in front of Room A1, (shorter) right WC
BrentwoodHS	Hallway	WC-29-FD	Bubbler with Cooler	4/23/2020	ND	WC in front of Room A4, taller, left WC. Sampled from bubbler head, bottle filler not working
BrentwoodHS	Hallway	WC-30-FD	Bubbler with Cooler	4/23/2020	0.744	WC in front of Room A4, (shorter) right WC
BrentwoodHS	Hallway	WC-06-FD	Bubbler with Cooler	4/23/2020	ND	WC in front of Room A7, left (taller) WC
BrentwoodHS	Hallway	WC-31-FD	Bubbler with Cooler	4/23/2020	ND	WC in front of Room A7, right (shorter) WC
BrentwoodHS	Hallway	WC-32-FD	Bubbler with Cooler	4/23/2020	ND	WC in front of Room A14, left (taller) WC
BrentwoodHS	Hallway	WC-33-FD	Bubbler with Cooler	4/23/2020	ND	WC in front of Room A14, right (shorter) WC
BrentwoodHS	Hallway	WC-34-FD	Bubbler with Cooler	4/23/2020	2.23	WC in front of Room A19, left (taller) WC
BrentwoodHS	Hallway	WC-35-FD	Bubbler with Cooler	4/23/2020	2.39	WC in front of Room A19, right (shorter) WC
BrentwoodHS	Hallway	WC-36-FD	Bubbler with Cooler	4/23/2020	ND	WC in front of Room A22, left (taller) WC. Sampled from bottle filler
BrentwoodHS	Hallway	WC-37-FD	Bubbler with Cooler	4/23/2020	0.97	WC in front of Room A22, right (shorter) WC
BrentwoodHS	Cafeteria	WC-38-FD	Bubbler with Cooler	4/23/2020	ND	in cafeteria, did not sample from bottle filler
BrentwoodHS	Kitchen	IM-39-FD	Ice Maker	4/23/2020	ND	ice maker by coffee station
BrentwoodHS	Kitchen	KT-02-FD	Kitchen Tap	4/23/2020	1.15	3 bay sink by exit doors, left faucet
BrentwoodHS	Kitchen	KT-40-FD	Kitchen Tap	4/23/2020	1.27	3 bay sink closer to ice maker, next to storage room, left faucet
BrentwoodMS		FB-01	Field Blank	4/23/2020	ND	
BrentwoodMS	Hallway	WC-20-FD	Bubbler with Cooler	4/23/2020	ND	WC in hallway by E8-E11 classrooms & theater room, in front of boys' bathroom
BrentwoodMS	Kitchen	KT-02-FD	Kitchen Tap	4/23/2020	0.511	Kitchen tap next to ice maker, right side of room, 3-bay sink, right faucet
BrentwoodMS	Hallway	IM-21-FD	Ice Maker	4/23/2020	ND	ice maker next to sink on right side of room
BrentwoodMS	Hallway	KT-22-FD	Kitchen Tap	4/23/2020	0.804	kitchen sink on left side of room, same side as walk-in fridge, 3-bay sink left faucet
BrentwoodMS	Hallway	WC-08-FD	Bubbler with Cooler	4/23/2020	ND	WC by "Pod E" hallway, in front of library, sample from bottle filler

LEAD ANALYSIS RESULTS FROM DRINKING WATER SAMPLING ACTIVITIES (April 21-23, 2020)

School	Room No./Location	Sample ID	Fixture Type	Sample Date	Result (ppb)	Notes
BrentwoodMS	Hallway	WC-23-FD	Bubbler with Cooler	4/23/2020	ND	WC next to Room A112 & bathrooms
BrentwoodMS	Hallway	WC-24-FD	Bubbler with Cooler	4/23/2020	ND	WC next to mechanical room and Room A110. Did not sample from bottle filler
BrentwoodMS	Hallway	WC-24-FD-D	Bubbler with Cooler	4/23/2020	ND	WC next to mechanical room and Room A110. Did not sample from bottle filler
BrentwoodMS	Hallway	WC-25-FD	Bubbler with Cooler	4/23/2020	ND	in "D" hallway by Room D-5, sample from bottle filler
BrentwoodMS	Hallway	WC-26-FD	Bubbler with Cooler	4/23/2020	ND	in "C" pod hallway, by Room C-7, sample from bottle filler
BrentwoodMS	Hallway	WC-06-FD	Bubbler with Cooler	4/23/2020	1.49	WC by Room C-2 and office
BrentwoodMS	Hallway	WC-27-FD	Bubbler with Cooler	4/23/2020	1.76	WC by "C Pod" hallway in main hallway next to lockers
BrentwoodMS	Hallway	WC-28-FD	Bubbler with Cooler	4/23/2020	0.926	WC in B hallway by Room B6
BrentwoodMS	Hallway	WC-29-FD	Bubbler with Cooler	4/23/2020	ND	WC in B hallway, in front of Room B3, sampled from bottle filler
BrentwoodMS	Nurses clinic	NS-30-FD	Sink	4/23/2020	2.09	sink in nurse's clinic
BrentwoodMS	Hallway	WC-04-FD	Bubbler with Cooler	4/23/2020	ND	WC in A hallway, by Room A4, sample from bottle filler
CentennialHS		FB-01	Field Blank	4/23/2020	ND	
CentennialHS	Lounge/Common Area	TL-02-FD	Teachers Lounge	4/23/2020	ND	kitchenette faucet; teacher's lounge
CentennialHS	125	TL-03-FD	Teachers Lounge	4/23/2020	0.685	kitchenette faucet; special ed room
CentennialHS	126	TL-04-FD	Teachers Lounge	4/23/2020	ND	kitchenette faucet; childcare right faucet
CentennialHS	126	TL-05-FD	Teachers Lounge	4/23/2020	ND	kitchenette faucet; childcare left faucet
CentennialHS	Hallway	WC-06-FD	Bubbler with Cooler	4/23/2020	ND	right (shorter) cooler; across from Room 115
CentennialHS	Hallway	WC-07-FD	Bubbler with Cooler	4/23/2020	ND	left (taller) cooler; across from Room 115
CentennialHS	Hallway	WC-08-FD	Bubbler with Cooler	4/23/2020	ND	left (shorter) bottle filler, across from stairwell near Room 124
CentennialHS	Hallway	WC-08-FD-D	Bubbler with Cooler	4/23/2020	ND	left (shorter) bottle filler, across from stairwell near Room 124
CentennialHS	Hallway	WC-09-FD	Bubbler with Cooler	4/23/2020	ND	right (taller) cooler, across from stairwell near Room 124
CentennialHS	Hallway	WC-10-FD	Bubbler with Cooler	4/23/2020	ND	left (shorter) cooler, adjacent to school store
CentennialHS	Hallway	WC-11-FD	Bubbler with Cooler	4/23/2020	ND	right (taller) bottle filler; adjacent to school store
CentennialHS	Hallway	WC-12-FD	Bubbler with Cooler	4/23/2020	ND	left (shorter) cooler; adjacent to women's restroom near exit
CentennialHS	Hallway	WC-13-FD	Bubbler with Cooler	4/23/2020	ND	right (taller) cooler; adjacent to women's restroom near exit
CentennialHS	Concession Stand	TL-14-FD	Teachers Lounge	4/23/2020	1.18	concession stand between restrooms across from gym; kitchenette faucet
CentennialHS	Kitchen	KT-15-FD	Kitchen Tap	4/23/2020	0.71	food prep sink; adjacent to kitchen office; right sink
CentennialHS	Kitchen	KT-16-FD	Kitchen Tap	4/23/2020	4.62	food prep sink; adjacent to kitchen office; left sink
CentennialHS	Kitchen	KT-17-FD	Kitchen Tap	4/23/2020	8.4	food prep sink; adjacent to storage closet; right sink
CentennialHS	Kitchen	KT-18-FD	Kitchen Tap	4/23/2020	3.73	food prep sink; adjacent to storage closet; left sink
CentennialHS	Nurses Office	NS-19-FD	Nurses Clinic	4/23/2020	ND	Nurses station across from Room 106
CentennialHS	Hallway	WC-20-FD	Bubbler with Cooler	4/23/2020	ND	left (taller) cooler; adjacent to Room 230
CentennialHS	Hallway	WC-21-FD	Bubbler with Cooler	4/23/2020	ND	right (shorter) cooler; adjacent to Room 230
CentennialHS	Hallway	WC-22-FD	Bubbler with Cooler	4/23/2020	ND	right (shorter) cooler; across from Room 239. Note: left unit not working
CentennialHS	Hallway	WC-23-FD	Bubbler with Cooler	4/23/2020	ND	left (taller) bottle filler; adjacent to Room 137
CollegeGroveES		FB-40	Field Blank	4/22/2020	ND	
CollegeGroveES	Kitchen	KT-05-FD	Kitchen Tap	4/22/2020	4.2	Sink next to kitchen office
CollegeGroveES	204	SOW-40-FD	Sink with Bubbler	4/22/2020	2.71	Room 204
CollegeGroveES	205	SOW-41-FD	Sink with Bubbler	4/22/2020	ND	Room 205
CollegeGroveES	206	SOW-42-FD	Sink with Bubbler	4/22/2020	ND	Room 206
CollegeGroveES	209	SOW-43-FD	Sink with Bubbler	4/22/2020	ND	Room 209
CollegeGroveES	212	SOW-44-FD	Sink with Bubbler	4/22/2020	ND	Room 212
CollegeGroveES	213	SOW-45-FD	Sink with Bubbler	4/22/2020	ND	Room 213
CollegeGroveES	301	SOW-46-FD	Sink with Bubbler	4/22/2020	1.26	Room 301
CollegeGroveES	301	SOW-46-FD-D	Sink with Bubbler	4/22/2020	2.79	Room 301
CollegeGroveES	303	SOW-47-FD	Sink with Bubbler	4/22/2020	3.72	Room 303
CollegeGroveES	300	SOW-48-FD	Sink with Bubbler	4/22/2020	4.65	Room 300
CollegeGroveES	404	SOW-49-FD	Sink with Bubbler	4/22/2020	6.61	Room 404
CollegeGroveES	409	SOW-50-FD	Sink with Bubbler	4/22/2020	ND	Room 409
CollegeGroveES	410	SOW-51-FD	Sink with Bubbler	4/22/2020	0.624	Room 410
CollegeGroveES	414	SOW-52-FD	Sink with Bubbler	4/22/2020	ND	Room 414
CollegeGroveES	Hallway	WC-21-FD	Bubbler with Cooler	4/22/2020	ND	cooler on right between bathrooms, in front of gym doors
CollegeGroveES	Hallway	WC-53-FD	Bubbler with Cooler	4/22/2020	1.62	outside gymnasium

LEAD ANALYSIS RESULTS FROM DRINKING WATER SAMPLING ACTIVITIES (April 21-23, 2020)

School	Room No./Location	Sample ID	Fixture Type	Sample Date	Result (ppb)	Notes
CollegeGroveES	202	SOW-13	Sink with Bubblers	4/22/2020	3.9	Room 202
CollegeGroveES	203	SOW-12	Sink with Bubblers	4/22/2020	4.29	Room 203
CollegeGroveES	Main Office	WC-10-FD	Bubbler with Cooler	4/22/2020	ND	in Main Office - Recently Installed
CrockettES		FB-01	Field Blank	4/23/2020	ND	
CrockettES	Kitchen	KT-03-FD	Kitchen Tap	4/23/2020	ND	food preparation tap
CrockettES	Lobby	WC-20-FD	Bubbler with Cooler	4/23/2020	ND	outside cafeteria, left cooler
CrockettES	Hallway	WC-06-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 2, left cooler
CrockettES	Lobby	WC-21-FD	Bubbler with Cooler	4/23/2020	ND	outside cafeteria, right cooler
CrockettES	Hallway	WC-22-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 2, right cooler
CrockettES	5	SOW-23-FD	Sink with Bubblers	4/23/2020	14.2	in Room 5
CrockettES	8	SOW-24-FD	Sink with Bubblers	4/23/2020	ND	in Room 8
CrockettES	8	SOW-24-FD-D	Sink with Bubblers	4/23/2020	ND	in Room 8
CrockettES	Hallway	WC-25-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 102, left cooler
CrockettES	Hallway	WC-04-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 102, right cooler
CrockettES	Hallway	WC-26-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 202, right cooler
CrockettES	Hallway	WC-05-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 202, left cooler
CrockettES	Library	WC-27-FD	Bubbler with Cooler	4/23/2020	ND	outside library (300 wing)
CrockettES	301	SOW-28-FD	Sink with Bubblers	4/23/2020	1.17	Room 301
CrockettES	302	SOW-29-FD	Sink with Bubblers	4/23/2020	ND	Room 302
CrockettES	304	SOW-30-FD	Sink with Bubblers	4/23/2020	1.58	Room 304
CrockettES	303	SOW-31-FD	Sink with Bubblers	4/23/2020	ND	Room 303
CrockettES	306	SOW-32-FD	Sink with Bubblers	4/23/2020	2.28	Room 306
CrockettES	305	SOW-33-FD	Sink with Bubblers	4/23/2020	1.73	Room 305
CrockettES	307	SOW-34-FD	Sink with Bubblers	4/23/2020	0.569	Room 307
CrockettES	308	SOW-35-FD	Sink with Bubblers	4/23/2020	1.52	Room 308
CrockettES	310	SOW-36-FD	Sink with Bubblers	4/23/2020	0.700	Room 310
CrockettES	309	SOW-37-FD	Sink with Bubblers	4/23/2020	1.77	Room 309
CrockettES	Hallway	WC-38-FD	Bubbler with Cooler	4/23/2020	ND	outside gymnasium
EdmondsonES		FB-01	Field Blank	4/22/2020	ND	
EdmondsonES	Kitchen	KT-20-FD	Kitchen Tap	4/22/2020	2.64	dish washing tap
EdmondsonES	Cafeteria	WC-21-FD	Bubbler with Cooler	4/22/2020	ND	outside cafeteria, left cooler
EdmondsonES	Cafeteria	WC-22-FD	Bubbler with Cooler	4/22/2020	ND	outside cafeteria, right cooler
EdmondsonES	Lounge	TL-23-FD	Teachers Lounge	4/22/2020	ND	in teacher's lounge
EdmondsonES	Hallway	WC-24-FD	Bubbler with Cooler	4/22/2020	ND	outside Room 302, left cooler
EdmondsonES	Hallway	WC-25-FD	Bubbler with Cooler	4/22/2020	ND	outside Room 302, right cooler
EdmondsonES	302	SOW-26-FD	Sink with Bubblers	4/22/2020	ND	in Room 302
EdmondsonES	304	SOW-27-FD	Sink with Bubblers	4/22/2020	ND	in Room 304
EdmondsonES	305	SOW-28-FD	Sink with Bubblers	4/22/2020	ND	in Room 305
EdmondsonES	309	SOW-29-FD	Sink with Bubblers	4/22/2020	ND	in Room 309
EdmondsonES	Hallway	WC-30-FD	Bubbler with Cooler	4/22/2020	ND	next to room 201, left cooler
EdmondsonES	Hallway	WC-31-FD	Bubbler with Cooler	4/22/2020	ND	next to room 201, right cooler
EdmondsonES	201	SOW-32-FD	Sink with Bubblers	4/22/2020	ND	in Room 201
EdmondsonES	201	SOW-32-FD-D	Sink with Bubblers	4/22/2020	ND	in Room 201
EdmondsonES	205	SOW-33-FD	Sink with Bubblers	4/22/2020	ND	in Room 205
EdmondsonES	206	SOW-34-FD	Sink with Bubblers	4/22/2020	ND	in Room 206
EdmondsonES	400	SOW-35-FD	Sink with Bubblers	4/22/2020	ND	in Room 400
EdmondsonES	402	SOW-36-FD	Sink with Bubblers	4/22/2020	ND	in Room 402
EdmondsonES	404	SOW-37-FD	Sink with Bubblers	4/22/2020	ND	in Room 404
EdmondsonES	407	SOW-38-FD	Sink with Bubblers	4/22/2020	ND	in Room 407
EdmondsonES	Hallway	WC-39-FD	Bubbler with Cooler	4/22/2020	ND	outside gym, left cooler
EdmondsonES	Hallway	WC-40-FD	Bubbler with Cooler	4/22/2020	ND	outside gym, right cooler
EdmondsonES	504	SOW-41-FD	Sink with Bubblers	4/22/2020	ND	in Room 504
EdmondsonES	509	SOW-42-FD	Sink with Bubblers	4/22/2020	ND	in Room 509
FairviewES		FB-20	Field Blank	4/21/2020	ND	
FairviewES	Hallway	WC-21-FD	Bubbler with Cooler	4/21/2020	ND	right cooler, by Room 306
FairviewES	Hallway	WC-22-FD	Bubbler with Cooler	4/21/2020	ND	left cooler, by Room 306
FairviewES	Hallway	WC-23-FD	Bubbler with Cooler	4/21/2020	ND	by library
FairviewES	Nurses Clinic	NS-24-FD	Nurses Clinic	4/21/2020	1.38	inside nurses clinic
FairviewES	Nurses Clinic	WC-25-FD	Bubbler with Cooler	4/21/2020	ND	inside nurses clinic
FairviewES	Hallway	WC-26-FD	Bubbler with Cooler	4/21/2020	ND	by Room 602
FairviewES	Kitchen	KT-27-FD	Kitchen Tap	4/21/2020	1.7	Kitchen, left sink (left side of room), left tap, double bay sink
FairviewES	Kitchen	KT-28-FD	Kitchen Tap	4/21/2020	0.911	Kitchen, left sink (left side of room), right tap, double bay sink
FairviewES	Kitchen	KT-29-FD-D	Kitchen Tap	4/21/2020	1.47	Kitchen, right sink (right side of room), left tap, double bay sink
FairviewES	Kitchen	KT-29-FD	Kitchen Tap	4/21/2020	1.82	Kitchen, right sink (right side of room), left tap, double bay sink
FairviewES	Teacher's Lounge	TL-33-FD	Teachers Lounge	4/21/2020	ND	staff lounge
FairviewES	Kitchen	KT-30-FD	Kitchen Tap	4/21/2020	1.64	Kitchen right sink (right side of room), right tap, double bay sink
FairviewES	Kitchen	KT-31-FD	Kitchen Tap	4/21/2020	2.25	separate sink to far right, right side of room
FairviewES	Hallway	WC-32-FD	Bubbler with Cooler	4/21/2020	ND	by office

LEAD ANALYSIS RESULTS FROM DRINKING WATER SAMPLING ACTIVITIES (April 21-23, 2020)

School	Room No./Location	Sample ID	Fixture Type	Sample Date	Result (ppb)	Notes
FairviewES	205	SOW-34-FD	Sink with Bubblers	4/21/2020	ND	Room 205
FairviewES	206	SOW-35-FD	Sink with Bubblers	4/21/2020	ND	Room 206
FairviewES	203	SOW-36-FD	Sink with Bubblers	4/21/2020	ND	Room 203
FairviewES	204	SOW-37-FD	Sink with Bubblers	4/21/2020	ND	Room 204
FairviewES	103	SOW-38-FD	Sink with Bubblers	4/21/2020	0.507	Room 103
FairviewES	104	SOW-39-FD	Sink with Bubblers	4/21/2020	ND	Room 104
FairviewHS		FB-20	Field Blank	4/21/2020	ND	
FairviewHS	100 Hallway	WC-21-FD	Bubbler with Cooler	4/21/2020	0.962	across from Room B111, right cooler
FairviewHS	100 Hallway	WC-22-FD	Bubbler with Cooler	4/21/2020	ND	across from Room B111, left cooler
FairviewHS	B117	SOW-23-FD	Sink with Bubblers	4/21/2020	1.68	Room B117, sink
FairviewHS	Hallway	WC-25-FD	Bubbler with Cooler	4/21/2020	ND	by Room C104, left cooler
FairviewHS	D108	SOW-26-FD	Sink with Bubblers	4/21/2020	2.02	Room D108, Concessions sink, right
FairviewHS	Hallway	WC-27-FD	Bubbler with Cooler	4/21/2020	ND	Room C104, main hall, right
FairviewHS	Hallway	WC-28-FD	Bubbler with Cooler	4/21/2020	ND	Room C104, main hall, left
FairviewHS	Hallway	WC-24-FD	Bubbler with Cooler	4/21/2020	0.632	by Room C104, main hall, right cooler
FairviewHS	E116	NS-29-FD	Bubbler with Cooler	4/21/2020	0.656	inside nurses office, right cooler
FairviewHS	E116	NS-30-FD	Bubbler with Cooler	4/21/2020	1.95	inside nurses office, left cooler
FairviewHS	E111	TL-31-FD	Teachers Lounge	4/21/2020	2.29	teacher's lounge sink
FairviewHS	Hallway	WC-32-FD	Bubbler with Cooler	4/21/2020	ND	by F117, in the C-Hall, right WC
FairviewHS	Hallway	WC-33-FD	Bubbler with Cooler	4/21/2020	ND	by F117, in the C-Hall, left WC
FairviewHS	G109	SOW-34-FD	Sink with Bubblers	4/21/2020	ND	in Room G109, special education room
FairviewHS	Hallway	WC-35-FD	Bubbler with Cooler	4/21/2020	ND	By Room G123, right WC
FairviewHS	Hallway	WC-36-FD	Bubbler with Cooler	4/21/2020	ND	By Room G123, left WC
FairviewHS	G Hallway	WC-37-FD	Bubbler with Cooler	4/21/2020	ND	G hallway across from G128, right cooler
FairviewHS	G Hallway	WC-38-FD	Bubbler with Cooler	4/21/2020	ND	G hallway across from G128, left cooler
FairviewHS	G Hallway	WC-38-FD-D	Bubbler with Cooler	4/21/2020	ND	G hallway across from G128, left cooler
FairviewHS	Kitchen	KT-39-FD	Kitchen Tap	4/21/2020	0.957	Kitchen left sink (left side of room), left tap
FairviewHS	Kitchen	KT-40-FD	Kitchen Tap	4/21/2020	0.917	Kitchen left sink (left side of room), right tap
FairviewHS	Kitchen	KT-41-FD	Kitchen Tap	4/21/2020	1.49	Kitchen right sink (right side of room), right tap
FairviewMS		FB-20	Field Blank	4/21/2020	ND	
FairviewMS	B Hall	WC-21-FD	Bubbler with Cooler	4/21/2020	0.981	across from Room B115, B hall, right WC
FairviewMS	B Hall	WC-22-FD	Bubbler with Cooler	4/21/2020	ND	across from Room B115, B hall, left WC
FairviewMS	Hallway	WC-23-FD	Bubbler with Cooler	4/21/2020	0.795	across from Room D102, right WC
FairviewMS	Hallway	WC-24-FD	Bubbler with Cooler	4/21/2020	1.12	across from Room D102, left WC
FairviewMS	Hallway	WC-25-FD	Bubbler with Cooler	4/21/2020	2.34	across from Room C106, right WC
FairviewMS	Hallway	WC-26-FD	Bubbler with Cooler	4/21/2020	0.675	across from Room C106, left WC
FairviewMS	B104B	NS-27-FD	Bubbler with Cooler	4/21/2020	0.65	inside office/nurses clinic, a water cooler
FairviewMS	Hallway	WC-28-FD	Bubbler with Cooler	4/21/2020	ND	across from Room B106, right WC
FairviewMS	Hallway	WC-28-FD-D	Bubbler with Cooler	4/21/2020	ND	across from Room B106, right WC
FairviewMS	Hallway	WC-29-FD	Bubbler with Cooler	4/21/2020	ND	across from Room B106 (left)
FairviewMS	A102	TL-30-FD	Teachers Lounge	4/21/2020	2.78	Room A102, teachers lounge
FairviewMS	Hallway	WC-31-FD	Bubbler with Cooler	4/21/2020	0.586	across from A117, right cooler
FairviewMS	Hallway	WC-32-FD	Bubbler with Cooler	4/21/2020	0.612	across from A117, left cooler
FairviewMS	Hallway	WC-33-FD	Bubbler with Cooler	4/21/2020	1.81	across from A104, right cooler
FairviewMS	Hallway	WC-34-FD	Bubbler with Cooler	4/21/2020	ND	across from A104, left cooler
FairviewMS	Cafeteria	WC-35-FD	Bubbler with Cooler	4/21/2020	ND	Cafeteria drinking fountain
FairviewMS	Hallway	WC-36-FD	Bubbler with Cooler	4/21/2020	ND	by gym, right WC
FairviewMS	Hallway	WC-37-FD	Bubbler with Cooler	4/21/2020	ND	by gym, left WC
FairviewMS	Hallway	WC-37-FD-D	Bubbler with Cooler	4/21/2020	ND	by gym, left WC
FairviewMS	Kitchen	KT-38-FD	Kitchen Tap	4/21/2020	2.1	kitchen double-bay sink, left tap
FairviewMS	Kitchen	KT-39-FD	Kitchen Tap	4/21/2020	2.06	kitchen double-bay sink, right tap
FairviewMS	Kitchen	KT-40-FD	Kitchen Tap	4/21/2020	0.862	opposite across from double bay sink (KT-38 and KT-39). KT-40 is a single bay sink
FranklinHS		FB-20	Field Blank	4/21/2020	ND	
FranklinHS	Hallway	WC-21-FD	Bubbler with Cooler	4/21/2020	ND	right cooler with bottle filler; adjacent to mens' restroom across from Room 203
FranklinHS	Hallway	WC-22-FD	Bubbler with Cooler	4/21/2020	ND	left cooler; adjacent to Room 204
FranklinHS	Hallway	WC-23-FD	Bubbler with Cooler	4/21/2020	ND	left cooler; adjacent to mens' restroom, across from Room 102
FranklinHS	Hallway	WC-24-FD	Bubbler with Cooler	4/21/2020	ND	right cooler with bottle filler; adjacent to Room 105, across from Room 102
FranklinHS	Hallway	WC-25-FD	Bubbler with Cooler	4/21/2020	ND	right with bottle filler; across from Room 409 and women's restroom
FranklinHS	Hallway	WC-26-FD	Bubbler with Cooler	4/21/2020	4.84	single with bottle filler behind auditorium stage
FranklinHS	Hallway	WC-26-FD-D	Bubbler with Cooler	4/21/2020	5.61	single with bottle filler behind auditorium stage
FranklinHS	Hallway	WC-27-FD	Bubbler with Cooler	4/21/2020	ND	right with bottle filler, adjacent to hallway parallel to gym, adjacent to ticket booth
FranklinHS	Hallway	WC-28-FD	Bubbler with Cooler	4/21/2020	ND	left with bottle filler, adjacent to womens' restroom at exit end of gym hall
FranklinHS Annex		FB-20	Field Blank	4/21/2020	ND	
FranklinHS Annex	Hallway	WC-21-FD	Bubbler with Cooler	4/21/2020	ND	adjacent to boys' restroom and Room A119, (left) tall

LEAD ANALYSIS RESULTS FROM DRINKING WATER SAMPLING ACTIVITIES (April 21-23, 2020)

School	Room No./Location	Sample ID	Fixture Type	Sample Date	Result (ppb)	Notes
FranklinHS Annex	Hallway	WC-22-FD	Bubbler with Cooler	4/21/2020	ND	adjacent to boys' restroom and Room A119, (right) short
FranklinHS Annex	Hallway	WC-23-FD	Bubbler with Cooler	4/21/2020	ND	adjacent to girls' restroom across from Room A138, single
FranklinHS Annex	Hallway	WC-23-FD-D	Bubbler with Cooler	4/21/2020	ND	adjacent to girls' restroom across from Room A138, single
FranklinHS Annex	Teacher's Lounge	TL-24-FD	Teachers Lounge	4/21/2020	1.33	Room A123, teacher work area
FranklinHS Annex	Hallway	WC-25-FD	Bubbler with Cooler	4/21/2020	ND	adjacent to boys' restroom (left) across from Room B102, short
FranklinHS Annex	Hallway	WC-26-FD	Bubbler with Cooler	4/21/2020	ND	adjacent to boys' restroom (right) across from Room B102, tall
FranklinHS Annex	Kitchenette/Snack Bar	KT-27-FD	Kitchen Tap	4/21/2020	0.719	Room B110; kitchenette in large communal hall
FranklinHS Annex	Hallway	WC-28-FD	Bubbler with Cooler	4/21/2020	ND	Tall with bottle filler adjacent to elevator in large common hall
GrasslandES		FB-01	Field Blank	4/23/2020	ND	
GrasslandES	Nurse's office	TL-02-FD	Sink	4/23/2020	ND	Nurse's office, handwashing sink
GrasslandES	Hallway	WC-03-FD	Bubbler with Cooler	4/23/2020	ND	left cooler; adjacent to Room 201
GrasslandES	Hallway	WC-04-FD	Bubbler with Cooler	4/23/2020	ND	right cooler; adjacent to Room 201
GrasslandES	204	SOW-06-FD	Sink with Bubbler	4/23/2020	ND	Room 204
GrasslandES	206	SOW-08-FD	Sink with Bubbler	4/23/2020	ND	Room 206, SOW to the right
GrasslandES	Hallway	WC-09-FD	Bubbler with Cooler	4/23/2020	ND	left bottle filler; adjacent to womens' restroom next to gym
GrasslandES	Hallway	WC-10-FD	Bubbler with Cooler	4/23/2020	ND	right cooler; adjacent to mens' restroom next to gym
GrasslandES	Hallway	WC-11-FD	Bubbler with Cooler	4/23/2020	ND	left cooler; adjacent to Room 503
GrasslandES	Hallway	WC-12-FD	Bubbler with Cooler	4/23/2020	ND	right cooler, bottle filler; adjacent to Room 503
GrasslandES	503	SOW-13-FD	Sink with Bubbler	4/23/2020	0.862	Room 503
GrasslandES	505	SOW-14-FD	Sink with Bubbler	4/23/2020	ND	Room 505
GrasslandES	506	SOW-15-FD	Sink with Bubbler	4/23/2020	ND	Room 506
GrasslandES	506	SOW-15-FD-D	Sink with Bubbler	4/23/2020	ND	Room 506
GrasslandES	507	SOW-16-FD	Sink with Bubbler	4/23/2020	ND	Room 507
GrasslandES	406	SOW-17-FD	Sink with Bubbler	4/23/2020	ND	Room 406
GrasslandES	408	SOW-18-FD	Sink with Bubbler	4/23/2020	ND	Room 408
GrasslandES	410	SOW-19-FD	Sink with Bubbler	4/23/2020	ND	Room 410
GrasslandES	Hallway	WC-20-FD	Bubbler with Cooler	4/23/2020	ND	right cooler, short; adjacent to Room 302
GrasslandES	Hallway	WC-21-FD	Bubbler with Cooler	4/23/2020	ND	left cooler, tall bottle filler adjacent to Room 302
GrasslandES	302	SOW-22-FD	Sink with Bubbler	4/23/2020	ND	Room 302
GrasslandES	Kitchen	KT-23-FD	Kitchen Tap	4/23/2020	1.48	food prep adjacent to office - used by staff
GrasslandES	Kitchen	KT-24-FD	Kitchen Tap	4/23/2020	ND	food prep left of K723 - used by staff, right tap
GrasslandES	202	SOW-05-FD	Sink with Bubbler	4/23/2020	ND	Room 202
GrasslandES	200	SOW-07-FD	Sink with Bubbler	4/23/2020	ND	Room 200
GrasslandMS		FB-01	Field Blank	4/23/2020	ND	
GrasslandMS	Nurses Office	TL-02-FD	Teachers Lounge	4/23/2020	1.09	kitchenette faucet in Nurse's Office (Room 611)
GrasslandMS	Admin Office	TL-03-FD	Teachers Lounge	4/23/2020	3.09	faucet in Admin Office closet
GrasslandMS	Hallway	WC-04-FD	Bubbler with Cooler	4/23/2020	ND	right cooler with bottle filler; adjacent to women's restroom & across from Principal's Office
GrasslandMS	Hallway	WC-05-FD	Bubbler with Cooler	4/23/2020	ND	left cooler; adjacent to women's restroom & across from Principal's Office
GrasslandMS	Hallway	WC-06-FD	Bubbler with Cooler	4/23/2020	ND	right; adjacent to gym and across from Room 503
GrasslandMS	Hallway	WC-07-FD	Bubbler with Cooler	4/23/2020	6.78	left; adjacent to gym and across from Room 503
GrasslandMS	Cafeteria	WC-08-FD	Bubbler with Cooler	4/23/2020	2.22	right cooler; cafeteria
GrasslandMS	Cafeteria	WC-08-FD-D	Bubbler with Cooler	4/23/2020	2.19	right cooler; cafeteria
GrasslandMS	Kitchen	KT-09-FD	Kitchen Tap	4/23/2020	5.40	closest to cafeteria; right
GrasslandMS	Kitchen	KT-10-FD	Kitchen Tap	4/23/2020	5.68	closest to cafeteria; left
GrasslandMS	Kitchen	KT-11-FD	Kitchen Tap	4/23/2020	8.97	farthest from cafeteria; right
GrasslandMS	Kitchen	KT-12-FD	Kitchen Tap	4/23/2020	77.3	farthest from cafeteria; left
GrasslandMS	Hallway	WC-13-FD	Bubbler with Cooler	4/23/2020	0.799	left/short cooler; adjacent to men's restroom across from Room 205
GrasslandMS	Hallway	WC-14-FD	Bubbler with Cooler	4/23/2020	ND	right/tall cooler with bottle filler adjacent to men's restroom across from Room 205
GrasslandMS	Hallway	WC-15-FD	Bubbler with Cooler	4/23/2020	ND	right/tall/cooler with bottle filler; adjacent to Room 804
GrasslandMS	Hallway	WC-16-FD	Bubbler with Cooler	4/23/2020	2.31	left/short cooler; adjacent to Room 804
GrasslandMS	Hallway	WC-17-FD	Bubbler with Cooler	4/23/2020	ND	right cooler with bottle filler; across from Room 714
GrasslandMS	Hallway	WC-18-FD	Bubbler with Cooler	4/23/2020	2.88	left cooler; across from Room 714
GrasslandMS	Hallway	WC-19-FD	Bubbler with Cooler	4/23/2020	2.41	right/tall cooler; adjacent to Room 111
GrasslandMS	Hallway	WC-20-FD	Bubbler with Cooler	4/23/2020	3.10	left/short cooler; adjacent to Room 111; leak at base of spout
GrasslandMS	Hallway	WC-21-FD	Bubbler with Cooler	4/23/2020	ND	left cooler; adjacent to Room 704

LEAD ANALYSIS RESULTS FROM DRINKING WATER SAMPLING ACTIVITIES (April 21-23, 2020)

School	Room No./Location	Sample ID	Fixture Type	Sample Date	Result (ppb)	Notes
GrasslandMS	Hallway	WC-22-FD	Bubbler with Cooler	4/23/2020	ND	right cooler; adjacent to Room 704
GrasslandMS	Hallway	WC-23-FD	Bubbler with Cooler	4/23/2020	ND	left cooler; adjacent to Room 618
HillsboroES-MS		FB-20	Field Blank	4/22/2020	ND	
HillsboroES-MS	Nurses Clinic	NS-21-FD	Sink	4/22/2020	1.17	clinic sink
HillsboroES-MS	Hallway	WC-22-FD	Bubbler with Cooler	4/22/2020	0.579	next to clinic
HillsboroES-MS	Room 1	SOW-23-FD	Sink with Bubbler	4/22/2020	0.634	Room 1
HillsboroES-MS	Room 2	SOW-24-FD	Sink with Bubbler	4/22/2020	ND	Room 2
HillsboroES-MS	Room 3	SOW-25-FD	Sink with Bubbler	4/22/2020	0.787	Room 3
HillsboroES-MS	Room 4	SOW-26-FD	Sink with Bubbler	4/22/2020	ND	Room 4
HillsboroES-MS	Hallway	WC-27-FD	Bubbler with Cooler	4/22/2020	ND	across from conference room, right
HillsboroES-MS	Hallway	WC-27-FD-D	Bubbler with Cooler	4/22/2020	ND	across from conference room, right
HillsboroES-MS	Hallway	WC-28-FD	Bubbler with Cooler	4/22/2020	ND	across from conference room, left cooler
HillsboroES-MS	Conference Room	TL-29-FD	Sink	4/22/2020	ND	conference room sink
HillsboroES-MS	Hallway	WC-30-FD	Bubbler with Cooler	4/22/2020	ND	across from Room 7, right
HillsboroES-MS	Hallway	WC-31-FD	Bubbler with Cooler	4/22/2020	ND	across from Room 7, left
HillsboroES-MS	Hallway	WC-32-FD	Bubbler with Cooler	4/22/2020	ND	WC next to library
HillsboroES-MS	Hallway	WC-33-FD	Bubbler with Cooler	4/22/2020	ND	next to electrical room, right WC
HillsboroES-MS	Hallway	WC-34-FD	Bubbler with Cooler	4/22/2020	ND	next to electrical room, left WC
HillsboroES-MS	Kitchen	KT-35-FD	Kitchen Tap	4/22/2020	2.02	kitchen sink on right side of room, right tap
HillsboroES-MS	Kitchen	KT-36-FD	Kitchen Tap	4/22/2020	1.05	kitchen sink on right side of room, left tap
HillsboroES-MS	Kitchen	KT-37-FD	Kitchen Tap	4/22/2020	0.950	kitchen sink on left side of room, right tap
HillsboroES-MS	Kitchen	KT-38-FD	Kitchen Tap	4/22/2020	0.615	kitchen sink on left side of room, left tap
HillsboroES-MS	Gym	WC-39-FD	Bubbler with Cooler	4/22/2020	ND	inside gym, right side, right
HillsboroES-MS	Gym	WC-40-FD	Bubbler with Cooler	4/22/2020	ND	inside gym, right side, left
HillsboroES-MS	Gym	WC-41-FD	Bubbler with Cooler	4/22/2020	ND	inside left side, right WC
HillsboroES-MS	Gym	WC-42-FD	Bubbler with Cooler	4/22/2020	ND	inside left side, left WC
HuntersBendES		FB-20	Field Blank	4/21/2020	ND	
HuntersBendES	Hallway	WC-21-FD	Bubbler with Cooler	4/21/2020	ND	water cooler with bottle filler. Adjacent to, server room
HuntersBendES	Hallway	WC-22-FD	Bubbler with Cooler	4/21/2020	ND	water cooler with bottle filler. Adjacent to, server room
HuntersBendES	301	SOW-23-FD	Sink with Bubbler	4/21/2020	2.17	Room 301 adjacent to exterior door
HuntersBendES	Hallway	WC-24-FD	Bubbler with Cooler	4/21/2020	ND	left, adjacent to Room 303
HuntersBendES	Hallway	WC-25-FD	Bubbler with Cooler	4/21/2020	ND	right, adjacent to double doors
HuntersBendES	310	SOW-26-FD	Sink with Bubbler	4/21/2020	ND	Room 310
HuntersBendES	311	SOW-27-FD	Sink with Bubbler	4/21/2020	ND	Room 311
HuntersBendES	Hallway	WC-28-FD	Bubbler with Cooler	4/21/2020	ND	right cooler, adjacent to women's' restroom
HuntersBendES	Hallway	WC-29-FD	Bubbler with Cooler	4/21/2020	ND	left cooler, adjacent to men's' restroom
HuntersBendES	Hallway	WC-29-FD-D	Bubbler with Cooler	4/21/2020	ND	left cooler, adjacent to men's' restroom
HuntersBendES	411	SOW-30-FD	Sink with Bubbler	4/21/2020	0.536	Room 411
HuntersBendES	409	SOW-31-FD	Sink with Bubbler	4/21/2020	0.942	Room 409
HuntersBendES	404	SOW-32-FD	Sink with Bubbler	4/21/2020	5.65	Room 404
HuntersBendES	400	SOW-33-FD	Sink with Bubbler	4/21/2020	1.67	Room 400
HuntersBendES	Hallway	WC-34-FD	Bubbler with Cooler	4/21/2020	ND	right adjacent to Room 509
HuntersBendES	Hallway	WC-35-FD	Bubbler with Cooler	4/21/2020	ND	left adjacent to Room 507
HuntersBendES	514	SOW-36-FD	Sink with Bubbler	4/21/2020	ND	Room 514
HuntersBendES	513	SOW-37-FD	Sink with Bubbler	4/21/2020	1.68	Room 513
HuntersBendES	208	SOW-38-FD	Sink with Bubbler	4/21/2020	ND	Room 208
HuntersBendES	207	SOW-39-FD	Sink with Bubbler	4/21/2020	ND	Room 207
HuntersBendES	Hallway	WC-40-FD	Bubbler with Cooler	4/21/2020	ND	right adjacent to end of hall junction/adjacent to Room 201
HuntersBendES	Hallway	WC-41-FD	Bubbler with Cooler	4/21/2020	ND	left adjacent to double doors/adjacent to Room 201
HuntersBendES	Kitchen	KT-42-FD	Kitchen Tap	4/21/2020	0.628	adjacent to kitchen office
HuntersBendES	Kitchen	KT-43-FD	Kitchen Tap	4/21/2020	1.91	wall with dish washing station
LipscombES		FB-01	Field Blank	4/23/2020	ND	
LipscombES	Kitchen	KT-20-FD	Kitchen Tap	4/23/2020	5.47	kitchen food prep
LipscombES	Hallway	WC-21-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 303 left cooler
LipscombES	Hallway	WC-22-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 303 right cooler
LipscombES	305	SOW-23-FD	Sink with Bubbler	4/23/2020	ND	Room 305
LipscombES	309	SOW-24-FD	Sink with Bubbler	4/23/2020	ND	Room 304
LipscombES	313	SOW-25-FD	Sink with Bubbler	4/23/2020	ND	Room 313
LipscombES	318	SOW-26-FD	Sink with Bubbler	4/23/2020	ND	Room 318
LipscombES	301	SOW-27-FD	Sink with Bubbler	4/23/2020	ND	Room 301
LipscombES	404	SOW-28-FD	Sink with Bubbler	4/23/2020	ND	Room 404
LipscombES	405	SOW-29-FD	Sink with Bubbler	4/23/2020	ND	Room 405
LipscombES	Hallway	WC-30-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 501/505
LipscombES	506	SOW-31-FD	Sink with Bubbler	4/23/2020	ND	Room 506
LipscombES	409	SOW-32-FD	Sink with Bubbler	4/23/2020	ND	Room 409
LipscombES	411	SOW-33-FD	Sink with Bubbler	4/23/2020	ND	Room 411
LipscombES	411	SOW-33-FD-D	Sink with Bubbler	4/23/2020	ND	Room 411
LipscombES	408	SOW-34-FD	Sink with Bubbler	4/23/2020	ND	Room 408
LipscombES	Hallway	WC-35-FD	Bubbler with Cooler	4/23/2020	ND	outside locker rooms, left cooler

LEAD ANALYSIS RESULTS FROM DRINKING WATER SAMPLING ACTIVITIES (April 21-23, 2020)

School	Room No./Location	Sample ID	Fixture Type	Sample Date	Result (ppb)	Notes
LipscombES	Hallway	WC-36-FD	Bubbler with Cooler	4/23/2020	ND	outside locker rooms, right cooler
LipscombES	Hallway	WC-37-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 200, left cooler
LipscombES	Hallway	WC-38-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 200, right cooler
LipscombES	200	SOW-39-FD	Sink with Bubbler	4/23/2020	ND	in Room 200
LipscombES	203	SOW-40-FD	Sink with Bubbler	4/23/2020	ND	in Room 203
LipscombES	202	SOW-41-FD	Sink with Bubbler	4/23/2020	ND	in Room 202
LipscombES	205	SOW-4-FD	Sink with Bubbler	4/23/2020	ND	in Room 205
OakviewES		FB-01-FD	Field Blank	4/22/2020	ND	
OakViewES	Teacher's Lounge	TL-40-FD	Teachers Lounge	4/22/2020	ND	teacher's lounge sink
OakViewES	Hallway	WC-41-FD	Bubbler with Cooler	4/22/2020	ND	in hallway, across Room 402. Left cooler with bottle filter, sampling from bottle filter
OakViewES	406	SOW-42-FD	Sink with Bubbler	4/22/2020	ND	Room 406, back right corner
OakViewES	403	SOW-43-FD	Sink with Bubbler	4/22/2020	ND	Room 403, back right corner
OakViewES	401	SOW-44-FD	Sink with Bubbler	4/22/2020	3.63	Room 401, back right corner
OakViewES	Hallway	WC-45-FD	Bubbler with Cooler	4/22/2020	ND	cooler on left with bottle filter, sampling from bottle filter
OakViewES	302	SOW-46-FD	Sink with Bubbler	4/22/2020	0.845	Room 302, SOW to right of door
OakViewES	305	SOW-47-FD	Sink with Bubbler	4/22/2020	1.24	Room 305, SOW to the right of door
OakViewES	306	SOW-48-FD	Sink with Bubbler	4/22/2020	ND	Room 306, SOW to the right of door
OakViewES	206	SOW-49-FD	Sink with Bubbler	4/22/2020	0.609	Room 206, SOW to the right of door
OakViewES	Hallway	WC-50-FD	Bubbler with Cooler	4/22/2020	ND	next to WC-16, between bathrooms, in front of gym doors. Left WC, sample from regular bubble head.
OakViewES	Hallway	WC-50-FD-D	Bubbler with Cooler	4/22/2020	ND	next to WC-16, in between bathrooms, in front of gym doors. Left WC, sample from regular bubbler head.
OakViewES	505	SOW-51-FD	Sink with Bubbler	4/22/2020	ND	Room 505, to the left of door
OakViewES	508	SOW-52-FD	Sink with Bubbler	4/22/2020	0.615	Room 408, to the left of door
OakViewES	510	SOW-53-FD	Sink with Bubbler	4/22/2020	0.93	Room 510, to the right of door
OakViewES	509	SOW-54-FD	Sink with Bubbler	4/22/2020	0.868	Room 509, to the left of door
OakViewES	512	SOW-55-FD	Sink with Bubbler	4/22/2020	2.49	Room 512, to the left of door
OakViewES	513	SOW-04-FD	Sink with Bubbler	4/22/2020	2.12	Room 513, to the left of door
OakViewES	Room 501	SOW-15-FD	Sink with Bubbler	4/22/2020	2.06	Room 501
OakViewES	Room 209	SOW-22-FD	Sink with Bubbler	4/22/2020	0.609	Room 209
OakViewES	Room 204	SOW-13-FD	Sink with Bubbler	4/22/2020	1.16	Room 204
OakViewES	Room 402	SOW-23-FD	Sink with Bubbler	4/22/2020	ND	Room 402
OakViewES	303	SOW-56-FD	Sink with Bubbler	4/22/2020	ND	Room 303, to the left of door
OakViewES	Room 304	SOW-11-FD	Sink with Bubbler	4/22/2020	ND	Room 304
PageHS		FB-01	Field Blank	4/21/2020	ND	
PageHS	Ringstaff Gym	WC-20-FD	Bubbler with Cooler	4/21/2020	ND	front right area of gym, left cooler
PageHS	Ringstaff Gym	WC-21-FD	Bubbler with Cooler	4/21/2020	0.61	front area of gym, right cooler
PageHS	Ringstaff Gym	WC-22-FD	Bubbler with Cooler	4/21/2020	ND	back left corner of gym
PageHS	Ringstaff Gym	WC-23-FD	Bubbler with Cooler	4/21/2020	ND	back right corner of gym
PageHS	Hallway	WC-24-FD	Bubbler with Cooler	4/21/2020	ND	media center near cafeteria
PageHS	Hallway	WC-26-FD	Bubbler with Cooler	4/21/2020	ND	outside gym near media
PageHS	Hallway	WC-25-FD	Bubbler with Cooler	4/21/2020	ND	outside Room 509
PageHS	Hallway	WC-27-FD	Bubbler with Cooler	4/21/2020	ND	bathroom in 600 block, left cooler
PageHS	Hallway	WC-28-FD	Bubbler with Cooler	4/21/2020	ND	bathroom in 600 block, right cooler
PageHS	Hallway	WC-28-FD-D	Bubbler with Cooler	4/21/2020	ND	bathroom in 600 block, right cooler
PageHS	Hallway	WC-29-FD	Bubbler with Cooler	4/21/2020	ND	middle area in 500 block
PageHS	Hallway	WC-30-FD	Bubbler with Cooler	4/21/2020	0.637	Room 504
PageHS	Hallway	WC-31-FD	Bubbler with Cooler	4/21/2020	0.544	in 300 block, bathroom
PageHS	Hallway	WC-32-FD	Bubbler with Cooler	4/21/2020	1.72	in 300 block, 311
PageHS	Hallway	WC-33-FD	Bubbler with Cooler	4/21/2020	ND	media center near 300 block
PageHS	Auditorium	WC-34-FD	Bubbler with Cooler	4/21/2020	0.869	auditorium lobby, left cooler
PageHS	Auditorium	WC-35-FD	Bubbler with Cooler	4/21/2020	1.26	auditorium lobby, right cooler
PageHS	Auditorium	WC-36-FD	Bubbler with Cooler	4/21/2020	79.1	auditorium lobby, left cooler
PageHS	Auditorium	WC-37-FD	Bubbler with Cooler	4/21/2020	102	auditorium lobby, right cooler
PageHS	Hallway	WC-38-FD	Bubbler with Cooler	4/21/2020	ND	100 block girls' bathroom
PageHS	Hallway	WC-39-FD	Bubbler with Cooler	4/21/2020	0.839	100 block boys' bathroom
PageHS	Kitchen	KT-40-FD	Kitchen Tap	4/21/2020	0.766	dishwashing, left tap
PageHS	Kitchen	KT-41-FD	Kitchen Tap	4/21/2020	1.25	dishwashing, right tap
PageHS	Library	TL-42-FD	Teachers Lounge	4/21/2020	3.89	lounge in media center
PageMS		FB-01	Field Blank	4/21/2020	ND	
PageMS	Hallway	WC-20-FD	Bubbler with Cooler	4/21/2020	1.39	outside gym, by bathrooms, left cooler
PageMS	Hallway	WC-21-FD	Bubbler with Cooler	4/21/2020	ND	outside gym, by bathrooms, right cooler
PageMS	Gym	KT-22-FD	Kitchen Tap	4/21/2020	10.3	Gym concessions
PageMS	Hallway	WC-23-FD	Bubbler with Cooler	4/21/2020	4.73	outside gym, by music/band rooms
PageMS	Commons Area	WC-24-FD	Bubbler with Cooler	4/21/2020	0.511	in common area, left cooler
PageMS	Commons Area	WC-25-FD	Bubbler with Cooler	4/21/2020	ND	in common area, right cooler
PageMS	Hallway	WC-26-FD	Bubbler with Cooler	4/21/2020	0.743	by Room E-1
PageMS	Hallway	WC-26-FD-D	Bubbler with Cooler	4/21/2020	0.852	by Room E-1
PageMS	Hallway	WC-27-FD	Bubbler with Cooler	4/21/2020	1.19	by bathroom & conference room, left cooler

LEAD ANALYSIS RESULTS FROM DRINKING WATER SAMPLING ACTIVITIES (April 21-23, 2020)

School	Room No./Location	Sample ID	Fixture Type	Sample Date	Result (ppb)	Notes
PageMS	Hallway	WC-28-FD	Bubbler with Cooler	4/21/2020	2.13	by bathroom & conference room, right cooler
PageMS	Hallway	WC-29-FD	Bubbler with Cooler	4/21/2020	2.41	outside Room c-5, left cooler
PageMS	Hallway	WC-30-FD	Bubbler with Cooler	4/21/2020	2.72	outside Room c-5, right cooler
PageMS	Hallway	WC-31-FD	Bubbler with Cooler	4/21/2020	ND	outside Room c-14, left cooler
PageMS	Hallway	WC-32-FD	Bubbler with Cooler	4/21/2020	ND	outside Room c-14, right cooler
PageMS	Kitchen	KT-33-FD	Kitchen Tap	4/21/2020	2.14	Kitchen dish, left tap
PageMS	Kitchen	KT-34-FD	Kitchen Tap	4/21/2020	8	Kitchen dish, right tap
PageMS	Auditorium Hallway	WC-35-FD	Bubbler with Cooler	4/21/2020	41.2	new southern wing/addition of school, near southern entrance in auditorium hallway, left cooler
PageMS	Auditorium Hallway	WC-36-FD	Bubbler with Cooler	4/21/2020	22.8	new southern wing/addition of school, near southern entrance in auditorium hallway, right cooler
PinewoodES		FB-20	Field Blank	4/22/2020	ND	
PinewoodES	Room 1	SOW-21-FD	Sink with Bubbler	4/22/2020	29.2	Room 1, payroll room
PinewoodES	Kitchen	KT-22-FD	Kitchen Tap	4/22/2020	32.2	Kitchen, left tap (only tap)
PinewoodES	Main Hall	WC-23-FD	Bubbler with Cooler	4/22/2020	ND	Main hall
PinewoodES	Teacher's Lounge	TL-24-FD	Teachers Lounge	4/22/2020	4.77	Conference room/teacher's lounge bathroom sink
PinewoodES	Teacher's Lounge	TL-24-FD-D	Teachers Lounge	4/22/2020	4.03	Conference room/teacher's lounge bathroom sink
RenaissanceHS		FB-01	Field Blank	4/22/2020	ND	
RenaissanceHS	Hallway/Basement	WC-05-FD	Bubbler with Cooler	4/22/2020	0.566	Right WC
RenaissanceHS	Hallway/1st floor	WC-06-FD	Bubbler with Cooler	4/22/2020	ND	Right WC with filter. Sample taken from filter not regular bubble head
RenaissanceHS	Hallway/2nd floor	WC-07-FD	Bubbler with Cooler	4/22/2020	ND	Right WC with filter. Sample taken from filter not regular bubble head
RenaissanceHS	Hallway/2nd floor	WC-07-FD-D	Bubbler with Cooler	4/22/2020	ND	Right WC with filter. Sample taken from filter not regular bubble head
RenaissanceHS	Hallway	WC-04-FD	Bubbler with Cooler	4/22/2020	ND	Adjacent to Room 204 and stairwell door, left cooler
RenaissanceHS	Lobby	WC-01-FD	Bubbler with Cooler	4/22/2020	ND	Left Cooler
RenaissanceHS	Hallway	WC-02-FD	Bubbler with Cooler	4/22/2020	0.661	Across the hallway from women's restroom, adjacent to exterior exit, left cooler
ScalesES		FB-01	Field Blank	4/23/2020	ND	
ScalesES	Hallway	WC-40-FD	Bubbler with Cooler	4/23/2020	0.544	next to mechanical room, left WC
ScalesES	Hallway	WC-41-FD	Bubbler with Cooler	4/23/2020	ND	next to mechanical room, right WC
ScalesES	Cafeteria	WC-13-FD	Bubbler with Cooler	4/23/2020	ND	Cafeteria to the Right of stage; WC to right of stage, has bottle filler, sampled from bottle filler 4/23/20
ScalesES	Area of 30-36 Rooms	WC-42-FD	Bubbler with Cooler	4/23/2020	ND	WC to right of room, next to Room 35 & 39, right WC
ScalesES	Area of 30-36 Rooms	WC-43-FD	Bubbler with Cooler	4/23/2020	ND	WC to left of room, next to Room 32, left WC
ScalesES	50	SOW-44-FD	Sink with Bubbler	4/23/2020	ND	Room 50, SOW to right of door
ScalesES	Area of 50s Rooms	WC-45-FD	Bubbler with Cooler	4/23/2020	ND	hallway of 50s rooms, right WC next to conference room & bathrooms
ScalesES	Room 51	SOW-16-FD	Sink with Bubbler	4/23/2020	ND	Room 51
ScalesES	Room 52	SOW-17-FD	Sink with Bubbler	4/23/2020	ND	Room 52
ScalesES	Room 53	SOW-33-FD	Sink with Bubbler	4/23/2020	ND	Room 53
ScalesES	Cafeteria	WC-20-FD	Bubbler with Cooler	4/23/2020	ND	Bubbler on far side wall, away from stage; Cafeteria, WC by 40s rooms, sampled from bottle filler 4/23/20
ScalesES	Hallway	WC-46-FD	Bubbler with Cooler	4/23/2020	ND	40s hallway, right side of room, right WC
ScalesES	Hallway	WC-47-FD	Bubbler with Cooler	4/23/2020	ND	40s hallway, left side of room, left WC
ScalesES	Hallway	WC-22-FD	Bubbler with Cooler	4/23/2020	ND	Bubbler on left side of the room, Bubbler on the right; 40s hallway, left side of room, right WC
ScalesES	Hallway	WC-21-FD	Bubbler with Cooler	4/23/2020	ND	Bubbler on right side of the room, Bubbler on the left; 40s hallway, right side of room, left WC
ScalesES	Hallway	WC-48-FD	Bubbler with Cooler	4/23/2020	1.44	20s hallway, left side of room, by Room 24, left WC
ScalesES	Area for Rooms 19-26	WC-23-FD	Bubbler with Cooler	4/23/2020	1.07	Bubbler on left side of the room, Bubbler on the right; 20s hallway, left side of room, by Room 24, right WC
ScalesES	Hallway	WC-49-FD	Bubbler with Cooler	4/23/2020	ND	20s hallway, by Room 22, left WC
ScalesES	Hallway	WC-49-FD-D	Bubbler with Cooler	4/23/2020	ND	20s hallway, by Room 22, left WC
ScalesES	Area for Rooms 19-26	WC-24-FD	Bubbler with Cooler	4/23/2020	ND	Bubbler on right side of the room, Bubbler on the left; 20s hallway, by Room 22, right WC
ScalesES	Room 11	SOW-25-FD	Sink with Bubbler	4/23/2020	1.04	Room 11
ScalesES	Room 13	SOW-27-FD	Sink with Bubbler	4/23/2020	1.99	Room 13
ScalesES	Room 15	SOW-29-FD	Sink with Bubbler	4/23/2020	117	Room 15
ScalesES	Room 17	SOW-31-FD	Sink with Bubbler	4/23/2020	8.7	Room 17
TrinityES		FB-20	Field Blank	4/21/2020	ND	
TrinityES	202	WC-20-FD	Bubbler with Cooler	4/21/2020	ND	outside Room 202, yellow hall

LEAD ANALYSIS RESULTS FROM DRINKING WATER SAMPLING ACTIVITIES (April 21-23, 2020)

School	Room No./Location	Sample ID	Fixture Type	Sample Date	Result (ppb)	Notes
TrinityES	213	SOW-21-FD	Sink with Bubblers	4/21/2020	ND	in Room 213
TrinityES	212	SOW-22-FD	Sink with Bubblers	4/21/2020	ND	Room 212
TrinityES	215	SOW-23-FD	Sink with Bubblers	4/21/2020	ND	Room 215
TrinityES	216	SOW-24-FD	Sink with Bubblers	4/21/2020	ND	Room 216
TrinityES	Hallway	WC-25-FD	Bubbler with Cooler	4/21/2020	0.54	outside bathrooms, near gym
TrinityES	102	SOW-26-FD	Sink with Bubblers	4/21/2020	ND	Room 102
TrinityES	108	SOW-27-FD-D	Sink with Bubblers	4/21/2020	1.33	Room 108
TrinityES	108	SOW-27-FD	Sink with Bubblers	4/21/2020	2.63	Room108
TrinityES	107	SOW-28-FD	Sink with Bubblers	4/21/2020	1.23	Room 107
TrinityES	Hallway	WC-29-FD	Bubbler with Cooler	4/21/2020	ND	outside Room 302, left cooler
TrinityES	Hallway	WC-30-FD	Bubbler with Cooler	4/21/2020	ND	outside Room 302, right cooler
TrinityES	304	SOW-31-FD	Sink with Bubblers	4/21/2020	0.642	Room 304
TrinityES	305	SOW-32-FD	Sink with Bubblers	4/21/2020	0.584	Room 305
TrinityES	307	SOW-33-FD	Sink with Bubblers	4/21/2020	1.33	Room 307
TrinityES	Hallway	WC-34-FD	Bubbler with Cooler	4/21/2020	ND	outside Room 402, left cooler
TrinityES	Hallway	WC-35-FD	Bubbler with Cooler	4/21/2020	ND	outside Room 402, right cooler
TrinityES	404	SOW-36-FD	Sink with Bubblers	4/21/2020	1.71	Room 404
TrinityES	403	SOW-37-FD	Sink with Bubblers	4/21/2020	ND	Room 403
TrinityES	410	SOW-38-FD	Sink with Bubblers	4/21/2020	0.953	Room 410
TrinityES	Hallway	WC-39-FD	Bubbler with Cooler	4/21/2020	ND	hall outside cafeteria, left cooler
TrinityES	Hallway	WC-40-FD	Bubbler with Cooler	4/21/2020	ND	hall outside cafeteria, right cooler
TrinityES	Hallway	WC-41-FD	Bubbler with Cooler	4/21/2020	ND	in main office
TrinityES	Hallway	WC-42-FD	Bubbler with Cooler	4/21/2020	ND	outside gym
WalnutGroveES		FB-20	Field Blank	4/21/2020	ND	
WalnutGroveES	Kitchen	KT-21-FD	Kitchen Tap	4/21/2020	ND	dish wash sprayer
WalnutGroveES	Kitchen	KT-22-FD	Kitchen Tap	4/21/2020	3.21	hand wash sink adjacent to dish wash station
WalnutGroveES	Kitchen	KT-23-FD	Kitchen Tap	4/21/2020	0.722	prep sink adjacent to Room 507
WalnutGroveES	Hallway	WC-24-FD	Bubbler with Cooler	4/21/2020	ND	adjacent to Room 617, right cooler
WalnutGroveES	Hallway	WC-25-FD	Bubbler with Cooler	4/21/2020	ND	adjacent to 617, left cooler (with bottle filler)
WalnutGroveES	Admin Office	TL-26-FD	Teachers Lounge	4/21/2020	ND	
WalnutGroveES	Hallway	WC-27-FD	Bubbler with Cooler	4/21/2020	4.95	in admin office hall
WalnutGroveES	Hallway	WC-28-FD	Bubbler with Cooler	4/21/2020	ND	adjacent to electrical closet, left cooler
WalnutGroveES	Hallway	WC-29-FD	Bubbler with Cooler	4/21/2020	ND	adjacent to Room 702, right cooler
WalnutGroveES	708	SOW-30-FD	Sink with Bubblers	4/21/2020	1.11	Room 708
WalnutGroveES	709	SOW-31-FD	Sink with Bubblers	4/21/2020	0.829	Room 709
WalnutGroveES	709	SOW-31-FD-D	Sink with Bubblers	4/21/2020	ND	Room 709
WalnutGroveES	Hallway	WC-32-FD	Bubbler with Cooler	4/21/2020	ND	single with bottle filler adjacent to 613
WalnutGroveES	Hallway	WC-33-FD	Bubbler with Cooler	4/21/2020	ND	adjacent to room 102, right cooler
WalnutGroveES	Hallway	WC-34-FD	Bubbler with Cooler	4/21/2020	ND	adjacent to men's' restroom, left cooler
WalnutGroveES	Hallway	WC-35-FD	Bubbler with Cooler	4/21/2020	ND	adjacent to men's' restroom, right cooler
WalnutGroveES	Hallway	WC-36-FD	Bubbler with Cooler	4/21/2020	ND	adjacent to Room 202 with bottle filler, left cooler
WalnutGroveES	Hallway	WC-37-FD	Bubbler with Cooler	4/21/2020	ND	single, adjacent to Room 603
WalnutGroveES	808	OW-38-FD	Drinking Water Bubblers	4/21/2020	ND	Room 808
WalnutGroveES	309	SOW-39-FD	Sink with Bubblers	4/21/2020	8.37	Room 309
WalnutGroveES	301	SOW-40-FD	Sink with Bubblers	4/21/2020	11.9	Room 301
WalnutGroveES	302	SOW-41-FD	Sink with Bubblers	4/21/2020	9.01	Room 302
WalnutGroveES	Hallway	WC-42-FD	Bubbler with Cooler	4/21/2020	ND	next to gym across from Room 401, right cooler
WalnutGroveES	Hallway	WC-43-FD	Bubbler with Cooler	4/21/2020	ND	next to gym across from Room 401, left cooler
WoodlandMS		FB-01	Field Blank	4/23/2020	ND	
WoodlandMS	Kitchen	KT-03-FD	Kitchen Tap	4/23/2020	1.23	kitchen dish
WoodlandMS	Kitchen	KT-20-FD	Kitchen Tap	4/23/2020	1.05	kitchen food prep
WoodlandMS	Cafeteria	WC-21-FD	Bubbler with Cooler	4/23/2020	ND	cafeteria, left cooler
WoodlandMS	Commons Area	WC-04-FD	Bubbler with Cooler	4/23/2020	ND	Cafeteria, right cooler
WoodlandMS	Gym	WC-22-FD	Bubbler with Cooler	4/23/2020	0.628	outside gym, right cooler
WoodlandMS	Gym	WC-23-FD	Bubbler with Cooler	4/23/2020	ND	outside restrooms @ gym, left cooler
WoodlandMS	Gym	WC-24-FD	Bubbler with Cooler	4/23/2020	ND	outside restrooms @ gym, right cooler
WoodlandMS	Chorus	WC-25-FD	Bubbler with Cooler	4/23/2020	ND	outside chorus room, left cooler
WoodlandMS	Chorus	WC-26-FD	Bubbler with Cooler	4/23/2020	ND	outside chorus room, right cooler
WoodlandMS	Office	WC-27-FD	Bubbler with Cooler	4/23/2020	ND	outside office, left cooler
WoodlandMS	Office	WC-28-FD	Bubbler with Cooler	4/23/2020	ND	outside office, right cooler
WoodlandMS	200	WC-29-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 200/202, left cooler
WoodlandMS	200	WC-30-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 200/202, right cooler
WoodlandMS	Hallway	WC-05-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 210, left cooler
WoodlandMS	210	WC-31-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 210, right cooler
WoodlandMS	217	WC-32-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 217
WoodlandMS	219	WC-33-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 219
WoodlandMS	308	WC-34-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 308 left
WoodlandMS	308	WC-34-FD-D	Bubbler with Cooler	4/23/2020	ND	outside Room 308 left
WoodlandMS	308	WC-35-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 308, right cooler
WoodlandMS	Hallway	WC-06-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 312, left cooler
WoodlandMS	118	WC-36-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 118, left cooler
WoodlandMS	118	WC-37-FD	Bubbler with Cooler	4/23/2020	ND	outside Room 118, right cooler

LEAD ANALYSIS RESULTS FROM DRINKING WATER SAMPLING ACTIVITIES (April 21-23, 2020)

School	Room No./Location	Sample ID	Fixture Type	Sample Date	Result (ppb)	Notes
WoodlandMS	Girls' locker room	WC-38-FD	Bubbler with Cooler	4/23/2020	ND	in girls' locker room

FIXTURE TYPE	
SOW	Sink with Bubbler
WC	Water Cooler
KT	Kitchen Tap
OW	Drinking Water Bubbler
NS or CL	Nurse's Clinic
IM	Ice Maker
TL	Teacher's Lounge
FB	Quality Control Field Blank

Notes:

Results are in parts per billion (ppb).

-FD sample ID suffix indicates sample is a First Draw sample collected from a fixture.

-FD-D sample ID suffix indicates a duplicate First Draw sample collected from a fixture concurrently with another First Draw sample from the same fixture for quality control purposes.

ND results indicate the lead concentration was less than 0.500 ppb which is the lower limit of the laboratory analysis protocol.

FB sample is a Field Blank sample of distilled water poured into a container in the field and shipped to laboratory with field samples for quality control purposes.