

1320 West Main Street Suite 202  
Franklin, Tennessee 37064-3700  
Phone (615) 472-4000  
Fax (615) 472-4190  
Website: <http://www.wcs.edu>



13 June 2022

To: Parents, Guardians, and Employees of Williamson County Schools

Subject: LEAD IN DRINKING WATER TESTING RESULTS (FINAL)

This notice is to inform all Parents, Guardians and Employees in the Williamson County School District of our efforts to comply with regulations related to testing for lead in the drinking water of schools. Tennessee Code Annotated 49-2-133 became effective on 1 January 2019 and requires drinking water sources in schools built prior to 1 January 1998 to be tested for lead levels at least biennially. The law requires this testing to be done in such a manner that the water drawn has been standing in the plumbing overnight, thus, it is best done while school is not in session.

We hired an outside environmental firm to conduct the sampling and analysis for WCS in 2022. The previous round of lead testing was conducted in 2020, so to meet the biennial requirement, we are conducting lead testing this year. We drew samples during April and May of 2022, and the results indicated that out of the 587 samples we took, 3 samples, one each at three different schools, showed lead levels above the threshold of 20ppb. The drinking water sources that these samples were drawn from were taken out of service, replaced, and the fixtures were retested. Upon receipt of satisfactory results, those three fixtures were returned to service. The specific 3 concerning results were:

- |   |          |                   |
|---|----------|-------------------|
| - BES, Room 110 (sample SOW-46-FD):             | 27.9ppb  | RETEST = 2.35ppb  |
| - Hillsboro E/MS, Room 2 (sample SOW-24-FD):    | 50.1ppb  | RETEST = 0.753ppb |
| - Hunters Bend ES, Room 505 (sample SOW-45-FD): | 20.3 ppb | RETEST = 0.956ppb |

The full results for all WCS lead testing is publicly posted and can be viewed by going to our website [www.wcs.edu](http://www.wcs.edu) and clicking "Public Notice" then "Lead Testing Data for Williamson County Schools". You will see the results grouped by school, with a description of each sample and where it was drawn from.

This notification and our regular testing/mitigation program are part of Williamson County Schools' on-going commitment to providing safe and healthy facilities for our families and staff. Questions about these results and/or our lead testing program can be directed to our Maintenance Director, Adam Christopher at his e-mail address, [adam.christopher@wcs.edu](mailto:adam.christopher@wcs.edu).

Sincerely,

Adam W. Christopher, PE, M.Eng.  
Maintenance Director

WCS Drinking Water Sampling Results Summary  
 April-May 2022

School	Sample Id	Sampled DateTime	Result (ppb)	Resample DateTime	Resample Result
Bethesda ES	FB-01	5/3/2022 6:03	<0.500		
Bethesda ES	KT-41-FD	5/3/2022 6:05	<0.500		
Bethesda ES	WC-39-FD	5/3/2022 6:11	<0.500		
Bethesda ES	WC-40-FD	5/3/2022 6:12	<0.500		
Bethesda ES	WC-04-FD	5/3/2022 6:15	<0.500		
Bethesda ES	WC-43-FD	5/3/2022 6:16	<0.500		
Bethesda ES	SOW-37-FD	5/3/2022 6:20	9.07		
Bethesda ES	TL-32-FD	5/3/2022 6:24	<0.500		
Bethesda ES	WC-36-FD	5/3/2022 6:26	<0.500		
Bethesda ES	WC-34-FD	5/3/2022 6:29	<0.500		
Bethesda ES	WC-34-FD-D	5/3/2022 6:29	<0.500		
Bethesda ES	WC-44-FD	5/3/2022 6:31	<0.500		
Bethesda ES	SOW-35-FD	5/3/2022 6:33	<0.500		
Bethesda ES	SOW-45-FD	5/3/2022 6:36	3.42		
Bethesda ES	SOW-46-FD	5/3/2022 6:42	27.9	5/24/2022 5:53	2.35
Bethesda ES	WC-21-FD	5/3/2022 6:46	<0.500		
Bethesda ES	WC-22-FD	5/3/2022 6:47	<0.500		
Bethesda ES	WC-20-FD	5/3/2022 6:49	0.502		
Bethesda ES	WC-31-FD	5/3/2022 6:51	<0.500		
Bethesda ES	SOW-25-FD	5/3/2022 6:53	7.27		
Bethesda ES	SOW-27-FD	5/3/2022 6:55	2.49		
Bethesda ES	SOW-02-FD	5/3/2022 6:58	2.3		
Bethesda ES	SOW-24-FD	5/3/2022 7:00	0.775		
Bethesda ES	NS-33-FD	5/3/2022 7:02	<0.500		
Brentwood HS	FB-01	4/19/2022 6:01	<0.500		
Brentwood HS	WC-21-FD	4/19/2022 6:06	<0.500		
Brentwood HS	WC-20-FD	4/19/2022 6:07	<0.500		
Brentwood HS	WC-38-FD	4/19/2022 6:09	<0.500		
Brentwood HS	WC-04-FD	4/19/2022 6:11	0.545		
Brentwood HS	WC-05-FD	4/19/2022 6:12	<0.500		
Brentwood HS	KT-02-FD	4/19/2022 6:15	1.1		
Brentwood HS	KT-02-FD-D	4/19/2022 6:15	1.19		
Brentwood HS	WC-23-FD	4/19/2022 6:19	<0.500		
Brentwood HS	WC-24-FD	4/19/2022 6:21	<0.500		
Brentwood HS	WC-27-FD	4/19/2022 6:25	2.16		
Brentwood HS	WC-28-FD	4/19/2022 6:26	0.937		
Brentwood HS	WC-29-FD	4/19/2022 6:28	<0.500		
Brentwood HS	WC-30-FD	4/19/2022 6:29	<0.500		
Brentwood HS	WC-06-FD	4/19/2022 6:31	<0.500		
Brentwood HS	WC-31-FD	4/19/2022 6:32	<0.500		
Brentwood HS	WC-32-FD	4/19/2022 6:34	<0.500		
Brentwood HS	WC-33-FD	4/19/2022 6:35	<0.500		
Brentwood HS	WC-34-FD	4/19/2022 6:40	0.653		
Brentwood HS	WC-35-FD	4/19/2022 6:41	1.95		
Brentwood HS	WC-36-FD	4/19/2022 6:43	<0.500		
Brentwood HS	WC-37-FD	4/19/2022 6:44	<0.500		
Brentwood HS	WC-41-FD	4/19/2022 6:49	0.641		
Brentwood HS	WC-42-FD	4/19/2022 6:50	0.648		
Brentwood HS	WC-43-FD	4/19/2022 6:52	<0.500		
Brentwood MS	WC-29-FD	4/19/2022 6:55	<0.500		
Brentwood MS	WC-28-FD	4/19/2022 6:56	0.763		
Brentwood MS	WC-27-FD	4/19/2022 7:00	1.93		
Brentwood MS	WC-26-FD	4/19/2022 7:04	<0.500		
Brentwood MS	WC-25-FD	4/19/2022 7:07	<0.500		
Brentwood MS	WC-08-FD	4/19/2022 7:10	<0.500		
Brentwood MS	KT-02-FD-D	4/19/2022 7:11	0.537		
Brentwood MS	KT-02-FD	4/19/2022 7:11	<0.500		
Brentwood MS	WC-20-FD	4/19/2022 7:12	<0.500		
Brentwood MS	KT-03-FD	4/19/2022 7:12	<0.500		
Brentwood MS	KT-22-FD	4/19/2022 7:14	<0.500		
Brentwood MS	WC-04-FD	4/19/2022 7:17	<0.500		
Brentwood MS	NS-30-FD	4/19/2022 7:20	1.44		
Brentwood MS	WC-23-FD	4/19/2022 7:21	<0.500		

WCS Drinking Water Sampling Results Summary  
April-May 2022

School	Sample Id	Sampled DateTime	Result (ppb)	Resample DateTime	Resample Result
Brentwood MS	WC-24-FD	4/19/2022 7:24	<0.500		
Brentwood MS	FB-01	4/19/2022 7:30	<0.500		
Centennial HS	FB-01	4/26/2022 6:00	<0.500		
Centennial HS	KT-06-FD	4/26/2022 6:12	<b>1.79</b>		
Centennial HS	KT-06-FD-D	4/26/2022 6:12	<b>0.866</b>		
Centennial HS	WC-07-FD	4/26/2022 6:17	<0.500		
Centennial HS	WC-08-FD	4/26/2022 6:18	<0.500		
Centennial HS	WC-09-FD	4/26/2022 6:20	<0.500		
Centennial HS	WC-10-FD	4/26/2022 6:21	<0.500		
Centennial HS	TL-11-FD	4/26/2022 6:25	<0.500		
Centennial HS	WC-05-FD	4/26/2022 6:29	<0.500		
Centennial HS	WC-12-FD	4/26/2022 6:30	<0.500		
Centennial HS	WC-04-FD	4/26/2022 6:33	<0.500		
Centennial HS	WC-13-FD	4/26/2022 6:34	<0.500		
Centennial HS	WC-14-FD	4/26/2022 6:36	<0.500		
Centennial HS	WC-15-FD	4/26/2022 6:37	<0.500		
Centennial HS	WC-18-FD	4/26/2022 6:40	<0.500		
Centennial HS	WC-17-FD	4/26/2022 6:41	<b>0.598</b>		
Centennial HS	WC-19-FD	4/26/2022 6:41	<0.500		
Centennial HS	WC-20-FD	4/26/2022 6:45	<0.500		
Centennial HS	WC-21-FD	4/26/2022 6:46	<0.500		
Centennial HS	WC-22-FD	4/26/2022 6:48	<b>0.526</b>		
Centennial HS	WC-23-FD	4/26/2022 6:49	<0.500		
Centennial HS	WC-24-FD	4/26/2022 6:51	<0.500		
Centennial HS	WC-25-FD	4/26/2022 6:52	<0.500		
Centennial HS	TL-26-FD	4/26/2022 6:56	<0.500		
Centennial HS	TL-27-FD	4/26/2022 6:57	<0.500		
CollegeGrove ES	FB-01	4/12/2022 5:56	<0.500		
CollegeGrove ES	WC-02-FD	4/12/2022 6:06	<0.500		
CollegeGrove ES	SOW-13-FD	4/12/2022 6:08	<b>2.19</b>		
CollegeGrove ES	SOW-17-FD	4/12/2022 6:11	<b>0.78</b>		
CollegeGrove ES	SOW-14-FD	4/12/2022 6:14	<0.500		
CollegeGrove ES	SOW-15-FD	4/12/2022 6:17	<b>0.788</b>		
CollegeGrove ES	SOW-16-FD	4/12/2022 6:19	<0.500		
CollegeGrove ES	SOW-44-FD	4/12/2022 6:22	<0.500		
CollegeGrove ES	SOW-45-FD	4/12/2022 6:23	<b>1.45</b>		
CollegeGrove ES	SOW-12-FD	4/12/2022 6:26	<b>2.22</b>		
CollegeGrove ES	WC-21-FD	4/12/2022 6:29	<0.500		
CollegeGrove ES	SOW-23-FD	4/12/2022 6:32	<b>2.53</b>		
CollegeGrove ES	SOW-08-FD-D	4/12/2022 6:34	<b>4.63</b>		
CollegeGrove ES	SOW-08-FD	4/12/2022 6:34	<b>1.8</b>		
CollegeGrove ES	SOW-24-FD	4/12/2022 6:39	<b>1.23</b>		
CollegeGrove ES	SOW-26-FD	4/12/2022 6:41	<b>0.685</b>		
CollegeGrove ES	SOW-04-FD	4/12/2022 6:44	<b>0.631</b>		
CollegeGrove ES	SOW-20-FD	4/12/2022 6:44	<b>1.79</b>		
CollegeGrove ES	SOW-03-FD	4/12/2022 6:49	<b>4.85</b>		
CollegeGrove ES	SOW-19-FD	4/12/2022 6:52	<b>2.44</b>		
CollegeGrove ES	WC-18-FD	4/12/2022 6:55	<0.500		
CollegeGrove ES	KT-09-FD	4/12/2022 6:57	<0.500		
CollegeGrove ES	KT-05-FD	4/12/2022 7:01	<b>1.25</b>		
CollegeGrove ES	WC-10-FD	4/12/2022 7:04	<0.500		
CollegeGrove ES	NS-11-FD	4/12/2022 7:06	<b>0.529</b>		
Crockett ES	FB-01	4/21/2022 7:10	<0.500		
Crockett ES	WC-26-FD	4/21/2022 7:14	<0.500		
Crockett ES	WC-04-FD	4/21/2022 7:15	<0.500		
Crockett ES	WC-25-FD	4/21/2022 7:17	<0.500		
Crockett ES	WC-06-FD	4/21/2022 7:19	<0.500		
Crockett ES	WC-22-FD	4/21/2022 7:20	<0.500		
Crockett ES	SOW-23-FD	4/21/2022 7:22	<0.500		
Crockett ES	SOW-24-FD	4/21/2022 7:22	<0.500		
Crockett ES	WC-20-FD	4/21/2022 7:26	<0.500		
Crockett ES	WC-21-FD	4/21/2022 7:27	<0.500		
Crockett ES	KT-03-FD	4/21/2022 7:29	<b>0.57</b>		
Crockett ES	WC-38-FD	4/21/2022 7:31	<0.500		

WCS Drinking Water Sampling Results Summary  
April-May 2022

School	Sample Id	Sampled DateTime	Result (ppb)	Resample DateTime	Resample Result
Crockett ES	WC-27-FD	4/21/2022 7:33	<0.500		
Crockett ES	TL-38-FD	4/21/2022 7:35	<b>0.583</b>		
Crockett ES	SOW-29-FD	4/21/2022 7:38	<0.500		
Crockett ES	SOW-28-FD	4/21/2022 7:40	<0.500		
Crockett ES	SOW-31-FD	4/21/2022 7:41	<b>1.08</b>		
Crockett ES	SOW-30-FD-D	4/21/2022 7:44	<b>0.854</b>		
Crockett ES	SOW-30-FD	4/21/2022 7:44	<b>0.891</b>		
Crockett ES	SOW-33-FD	4/21/2022 7:47	<0.500		
Crockett ES	SOW-32-FD	4/21/2022 7:48	<b>4.82</b>		
Crockett ES	SOW-34-FD	4/21/2022 7:49	<0.500		
Crockett ES	SOW-35-FD	4/21/2022 7:51	<b>0.949</b>		
Crockett ES	SOW-36-FD	4/21/2022 7:53	<0.500		
Crockett ES	WC-05-FD	4/21/2022 7:56	<0.500		
Edmondson ES	FB-01	4/12/2022 7:58	<0.500		
Edmondson ES	KT-03-FD	4/12/2022 8:04	<b>2.37</b>		
Edmondson ES	KT-20-FD	4/12/2022 8:05	<b>2.57</b>		
Edmondson ES	WC-21-FD	4/12/2022 8:09	<0.500		
Edmondson ES	WC-22-FD	4/12/2022 8:10	<0.500		
Edmondson ES	WC-24-FD	4/12/2022 8:14	<0.500		
Edmondson ES	SOW-28-FD	4/12/2022 8:16	<0.500		
Edmondson ES	SOW-27-FD	4/12/2022 8:18	<0.500		
Edmondson ES	SOW-29-FD	4/12/2022 8:20	<0.500		
Edmondson ES	SOW-05-FD	4/12/2022 8:22	<0.500		
Edmondson ES	SOW-35-FD	4/12/2022 8:26	<0.500		
Edmondson ES	SOW-36-FD-D	4/12/2022 8:28	<0.500		
Edmondson ES	SOW-36-FD	4/12/2022 8:28	<0.500		
Edmondson ES	SOW-37-FD	4/12/2022 8:31	<0.500		
Edmondson ES	SOW-38-FD	4/12/2022 8:34	<0.500		
Edmondson ES	WC-39-FD	4/12/2022 8:36	<0.500		
Edmondson ES	WC-45-FD	4/12/2022 8:39	<0.500		
Edmondson ES	SOW-42-FD	4/12/2022 8:42	<0.500		
Edmondson ES	SOW-06-FD	4/12/2022 8:44	<b>0.848</b>		
Edmondson ES	SOW-41-FD	4/12/2022 8:47	<0.500		
Edmondson ES	WC-30-FD	4/12/2022 8:50	<0.500		
Edmondson ES	SOW-32-FD	4/12/2022 8:52	<0.500		
Edmondson ES	SOW-33-FD	4/12/2022 8:54	<0.500		
Edmondson ES	SOW-34-FD	4/12/2022 8:55	<0.500		
Edmondson ES	SOW-04-FD	4/12/2022 8:57	<0.500		
Fairview ES	FB-01	5/3/2022 7:55	<0.500		
Fairview ES	WC-32-FD	5/3/2022 7:56	<0.500		
Fairview ES	SOW-48-FD	5/3/2022 8:01	<0.500		
Fairview ES	SOW-34-FD	5/3/2022 8:03	<0.500		
Fairview ES	SOW-35-FD	5/3/2022 8:05	<0.500		
Fairview ES	SOW-37-FD	5/3/2022 8:06	<0.500		
Fairview ES	SOW-36-FD-D	5/3/2022 8:08	<0.500		
Fairview ES	SOW-36-FD	5/3/2022 8:08	<0.500		
Fairview ES	SOW-40-FD	5/3/2022 8:13	<0.500		
Fairview ES	SOW-41-FD	5/3/2022 8:14	<0.500		
Fairview ES	SOW-39-FD	5/3/2022 8:16	<0.500		
Fairview ES	SOW-38-FD	5/3/2022 8:17	<b>0.505</b>		
Fairview ES	SOW-42-FD	5/3/2022 8:18	<0.500		
Fairview ES	SOW-04-FD	5/3/2022 8:21	<0.500		
Fairview ES	TL-33-FD	5/3/2022 8:24	<0.500		
Fairview ES	KT-30-FD	5/3/2022 8:27	<0.500		
Fairview ES	WC-21-FD	5/3/2022 8:33	<0.500		
Fairview ES	WC-22-FD	5/3/2022 8:34	<0.500		
Fairview ES	WC-43-FD	5/3/2022 8:41	<0.500		
Fairview ES	TL-44-FD	5/3/2022 8:44	<0.500		
Fairview ES	WC-23-FD	5/3/2022 8:47	<0.500		
Fairview ES	WC-45-FD	5/3/2022 8:50	<0.500		
Fairview ES	WC-46-FD	5/3/2022 8:54	<0.500		
Fairview ES	WC-02-FD	5/3/2022 8:56	<0.500		
Fairview ES	NS-47-FD	5/3/2022 9:00	<b>1.04</b>		
Fairview HS	FB-01	5/3/2022 9:12	<0.500		

WCS Drinking Water Sampling Results Summary  
April-May 2022

School	Sample Id	Sampled DateTime	Result (ppb)	Resample DateTime	Resample Result
Fairview HS	WC-48-FD	5/3/2022 9:17	<b>0.998</b>		
Fairview HS	WC-49-FD	5/3/2022 9:18	<0.500		
Fairview HS	WC-32-FD	5/3/2022 9:26	<0.500		
Fairview HS	WC-33-FD	5/3/2022 9:27	<0.500		
Fairview HS	WC-35-FD	5/3/2022 9:31	<0.500		
Fairview HS	WC-36-FD	5/3/2022 9:32	<0.500		
Fairview HS	WC-37-FD	5/3/2022 9:38	<0.500		
Fairview HS	WC-37-FD-D	5/3/2022 9:38	<0.500		
Fairview HS	WC-38-FD	5/3/2022 9:39	<0.500		
Fairview HS	WC-02-FD	5/3/2022 9:41	<0.500		
Fairview HS	WC-42-FD	5/3/2022 9:44	<0.500		
Fairview HS	WC-27-FD	5/3/2022 9:49	<0.500		
Fairview HS	WC-28-FD	5/3/2022 9:50	<b>0.501</b>		
Fairview HS	WC-43-FD	5/3/2022 9:54	<b>2.75</b>		
Fairview HS	KT-05-FD	5/3/2022 9:59	<0.500		
Fairview HS	WC-25-FD	5/3/2022 10:03	<0.500		
Fairview HS	WC-44-FD	5/3/2022 10:04	<b>1.61</b>		
Fairview HS	WC-21-FD	5/3/2022 10:11	<b>0.849</b>		
Fairview HS	WC-22-FD	5/3/2022 10:12	<0.500		
Fairview HS	TL-45-FD	5/3/2022 10:16	<b>0.76</b>		
Fairview HS	TL-34-FD	5/3/2022 10:23	<0.500		
Fairview HS	TL-31-FD	5/3/2022 10:29	<b>2.78</b>		
Fairview HS	WC-46-FD	5/3/2022 10:36	<0.500		
Fairview HS	WC-47-FD	5/3/2022 10:40	<0.500		
Fairview MS	FB-01	5/3/2022 10:54	<0.500		
Fairview MS	WC-40-FD	5/3/2022 10:59	<0.500		
Fairview MS	WC-41-FD	5/3/2022 11:00	<0.500		
Fairview MS	WC-42-FD	5/3/2022 11:01	<0.500		
Fairview MS	WC-43-FD	5/3/2022 11:02	<0.500		
Fairview MS	WC-32-FD	5/3/2022 11:07	<b>0.907</b>		
Fairview MS	WC-31-FD	5/3/2022 11:08	<b>1.1</b>		
Fairview MS	TL-30-FD	5/3/2022 11:13	<b>1.13</b>		
Fairview MS	WC-34-FD	5/3/2022 11:17	<0.500		
Fairview MS	WC-33-FD	5/3/2022 11:18	<b>0.619</b>		
Fairview MS	WC-37-FD	5/3/2022 11:23	<0.500		
Fairview MS	WC-36-FD	5/3/2022 11:24	<0.500		
Fairview MS	WC-35-FD	5/3/2022 11:26	<0.500		
Fairview MS	WC-29-FD	5/3/2022 11:32	<0.500		
Fairview MS	WC-28-FD	5/3/2022 11:33	<0.500		
Fairview MS	NS-48-FD	5/3/2022 11:35	<0.500		
Fairview MS	TL-49-FD	5/3/2022 11:39	<b>1.52</b>		
Fairview MS	WC-22-FD	5/3/2022 11:44	<0.500		
Fairview MS	WC-22-FD-D	5/3/2022 11:44	<0.500		
Fairview MS	WC-21-FD	5/3/2022 11:46	<b>0.535</b>		
Fairview MS	WC-26-FD-Filtered	5/3/2022 11:49	<b>0.526</b>		
Fairview MS	WC-25-FD	5/3/2022 11:52	<b>1.05</b>		
Fairview MS	TL-54-FD	5/3/2022 11:55	<b>0.745</b>		
Fairview MS	WC-23-FD	5/3/2022 11:58	<b>0.514</b>		
Fairview MS	KT-39-FD	5/3/2022 12:05	<b>2.25</b>		
Franklin HS	FB-01	4/28/2022 5:55	<0.500		
Franklin HS	WC-06-FD	4/28/2022 6:00	<0.500		
Franklin HS	WC-07-FD	4/28/2022 6:03	<0.500		
Franklin HS	WC-08-FD	4/28/2022 6:06	<0.500		
Franklin HS	WC-10-FD	4/28/2022 6:14	<0.500		
Franklin HS	WC-11-FD	4/28/2022 6:18	<0.500		
Franklin HS	WC-12-FD	4/28/2022 6:21	<0.500		
Franklin HS	WC-13-FD	4/28/2022 6:26	<0.500		
Franklin HS	WC-14-FD	4/28/2022 6:27	<0.500		
Franklin HS	WC-02-FD	4/28/2022 6:31	<0.500		
Franklin HS	WC-15-FD	4/28/2022 6:33	<0.500		
Franklin HS	TL-16-FD	4/28/2022 6:36	<0.500		
Franklin HS	KT-17-FD	4/28/2022 6:40	<0.500		
Franklin HS	WC-18-FD	4/28/2022 6:44	<0.500		
Franklin HS	WC-03-FD-D	4/28/2022 6:46	<0.500		

WCS Drinking Water Sampling Results Summary  
April-May 2022

School	Sample Id	Sampled DateTime	Result (ppb)	Resample DateTime	Resample Result
Franklin HS	WC-03-FD	4/28/2022 6:46	<0.500		
Franklin HS	WC-19-FD	4/28/2022 6:51	<0.500		
Franklin HS	WC-20-FD	4/28/2022 6:53	<0.500		
Franklin HS	WC-21-FD	4/28/2022 6:59	<0.500		
Franklin HS	WC-22-FD	4/28/2022 7:01	<0.500		
Franklin HS	TL-23-FD	4/28/2022 7:04	<b>2.17</b>		
Franklin HS	TL-24-FD	4/28/2022 7:09	<0.500		
Franklin HS	WC-25-FD	4/28/2022 7:12	<0.500		
Franklin HS	WC-04-FD	4/28/2022 7:14	<0.500		
Franklin HS	WC-26-FD	4/28/2022 7:17	<0.500		
Franklin HS Annex	FB-01	4/28/2022 7:26	<0.500		
Franklin HS Annex	WC-21-FD	4/28/2022 7:31	<0.500		
Franklin HS Annex	WC-22-FD	4/28/2022 7:32	<0.500		
Franklin HS Annex	WC-23-FD	4/28/2022 7:34	<0.500		
Franklin HS Annex	WC-25-FD	4/28/2022 7:36	<0.500		
Franklin HS Annex	WC-26-FD-D	4/28/2022 7:37	<0.500		
Franklin HS Annex	WC-26-FD	4/28/2022 7:37	<0.500		
Franklin HS Annex	TL-24-FD	4/28/2022 7:41	<0.500		
Franklin HS Annex	KT-27-FD	4/28/2022 7:46	<0.500		
Franklin HS Annex	WC-28-FD	4/28/2022 7:49	<0.500		
Franklin HS Annex	WC-29-FD	4/28/2022 7:51	<b>0.712</b>		
Grassland ES	FB-01	4/26/2022 7:18	<0.500		
Grassland ES	KT-23-FD	4/26/2022 7:23	<b>0.561</b>		
Grassland ES	NS-02-FD	4/26/2022 7:26	<0.500		
Grassland ES	WC-03-FD	4/26/2022 7:28	<0.500		
Grassland ES	WC-04-FD	4/26/2022 7:31	<0.500		
Grassland ES	SOW-07-FD	4/26/2022 7:33	<0.500		
Grassland ES	SOW-05-FD	4/26/2022 7:35	<0.500		
Grassland ES	SOW-06-FD	4/26/2022 7:37	<0.500		
Grassland ES	SOW-08-FD	4/26/2022 7:40	<0.500		
Grassland ES	WC-09-FD	4/26/2022 7:42	<0.500		
Grassland ES	WC-10-FD	4/26/2022 7:42	<0.500		
Grassland ES	SOW-13-FD	4/26/2022 7:46	<0.500		
Grassland ES	SOW-14-FD	4/26/2022 7:48	<0.500		
Grassland ES	WC-11-FD	4/26/2022 7:49	<0.500		
Grassland ES	WC-12-FD	4/26/2022 7:51	<0.500		
Grassland ES	SOW-15-FD	4/26/2022 7:53	<0.500		
Grassland ES	SOW-25-FD	4/26/2022 7:55	<0.500		
Grassland ES	SOW-26-FD	4/26/2022 7:57	<0.500		
Grassland ES	SOW-17-FD	4/26/2022 8:01	<0.500		
Grassland ES	SOW-17-FD-D	4/26/2022 8:01	<0.500		
Grassland ES	SOW-18-FD	4/26/2022 8:04	<0.500		
Grassland ES	SOW-19-FD	4/26/2022 8:09	<0.500		
Grassland ES	WC-20-FD	4/26/2022 8:13	<0.500		
Grassland ES	WC-21-FD	4/26/2022 8:14	<0.500		
Grassland ES	SOW-22-FD	4/26/2022 8:16	<0.500		
Grassland MS	FB-01	4/26/2022 6:09	<0.500		
Grassland MS	TL-03-FD	4/26/2022 6:14	<b>1.4</b>		
Grassland MS	WC-04-FD	4/26/2022 6:16	<0.500		
Grassland MS	WC-05-FD	4/26/2022 6:18	<b>0.533</b>		
Grassland MS	WC-24-FD	4/26/2022 6:20	<0.500		
Grassland MS	WC-08-FD	4/26/2022 6:22	<b>1.52</b>		
Grassland MS	WC-06-FD	4/26/2022 6:24	<0.500		
Grassland MS	WC-07-FD	4/26/2022 6:26	<0.500		
Grassland MS	WC-02-FD	4/26/2022 6:29	<0.500		
Grassland MS	WC-14-FD	4/26/2022 6:33	<0.500		
Grassland MS	WC-13-FD	4/26/2022 6:35	<0.500		
Grassland MS	WC-10-FD	4/26/2022 6:38	<b>9.32</b>		
Grassland MS	WC-17-FD	4/26/2022 6:43	<0.500		
Grassland MS	WC-18-FD	4/26/2022 6:44	<b>1.8</b>		
Grassland MS	WC-19-FD	4/26/2022 6:46	<0.500		
Grassland MS	WC-20-FD	4/26/2022 6:48	<b>0.629</b>		
Grassland MS	WC-21-FD	4/26/2022 6:50	<0.500		
Grassland MS	WC-22-FD	4/26/2022 6:52	<0.500		

WCS Drinking Water Sampling Results Summary  
April-May 2022

School	Sample Id	Sampled DateTime	Result (ppb)	Resample DateTime	Resample Result
Grassland MS	WC-22-FD-D	4/26/2022 6:52	<0.500		
Grassland MS	SOW-25-FD	4/26/2022 6:56	<b>0.587</b>		
Grassland MS	WC-08-FD	4/26/2022 6:57	<b>0.701</b>		
Grassland MS	WC-29-FD	4/26/2022 7:01	<b>1.14</b>		
Grassland MS	WC-26-FD	4/26/2022 7:06	<b>0.959</b>		
Grassland MS	WC-27-FD	4/26/2022 7:08	<0.500		
Grassland MS	WC-28-FD	4/26/2022 7:11	<0.500		
Hillsboro ESMS	FB-01	5/5/2022 6:03	<0.500		
Hillsboro ESMS	WC-42-FD	5/5/2022 6:05	<0.500		
Hillsboro ESMS	NS-43-FD	5/5/2022 6:09	<0.500		
Hillsboro ESMS	SOW-26-FD	5/5/2022 6:11	<b>0.521</b>		
Hillsboro ESMS	SOW-23-FD	5/5/2022 6:13	<b>1.45</b>		
Hillsboro ESMS	SOW-24-FD	5/5/2022 6:15	<b>50.1</b>	5/24/2022 6:32	<b>0.753</b>
Hillsboro ESMS	SOW-25-FD	5/5/2022 6:17	<b>1.14</b>		
Hillsboro ESMS	WC-44-FD-D	5/5/2022 6:20	<0.500		
Hillsboro ESMS	WC-44-FD	5/5/2022 6:20	<0.500		
Hillsboro ESMS	WC-45-FD	5/5/2022 6:24	<0.500		
Hillsboro ESMS	WC-30-FD	5/5/2022 6:28	<0.500		
Hillsboro ESMS	WC-31-FD	5/5/2022 6:30	<0.500		
Hillsboro ESMS	SOW-46-FD	5/5/2022 6:34	<0.500		
Hillsboro ESMS	SOW-47-FD	5/5/2022 6:35	<0.500		
Hillsboro ESMS	WC-32-FD	5/5/2022 6:39	<0.500		
Hillsboro ESMS	WC-34-FD	5/5/2022 6:42	<0.500		
Hillsboro ESMS	WC-33-FD	5/5/2022 6:43	<0.500		
Hillsboro ESMS	KT-05-FD	5/5/2022 6:47	<0.500		
Hillsboro ESMS	WC-48-FD	5/5/2022 6:49	<0.500		
Hillsboro ESMS	WC-39-FD	5/5/2022 6:51	<0.500		
Hillsboro ESMS	WC-40-FD	5/5/2022 6:52	<0.500		
Hillsboro ESMS	WC-41-FD	5/5/2022 6:55	<0.500		
Hillsboro ESMS	WC-42-FD	5/5/2022 6:56	<0.500		
Hillsboro ESMS	WC-49-FD	5/5/2022 7:00	<0.500		
Hillsboro ESMS	WC-50-FD	5/5/2022 7:02	<0.500		
Hunters Bend ES	KT-42-FD	4/28/2022 7:19	<0.500		
Hunters Bend ES	KT-42-FD-D	4/28/2022 7:19	<0.500		
Hunters Bend ES	WC-22-FD	4/28/2022 7:21	<0.500		
Hunters Bend ES	WC-21-FD	4/28/2022 7:22	<0.500		
Hunters Bend ES	WC-40-FD	4/28/2022 7:24	<0.500		
Hunters Bend ES	WC-41-FD	4/28/2022 7:25	<0.500		
Hunters Bend ES	SOW-42-FD	4/28/2022 7:27	<b>0.604</b>		
Hunters Bend ES	SOW-43-FD	4/28/2022 7:29	<b>0.876</b>		
Hunters Bend ES	SOW-44-FD	4/28/2022 7:31	<0.500		
Hunters Bend ES	SOW-32-FD	4/28/2022 7:33	<b>9.02</b>		
Hunters Bend ES	WC-28-FD	4/28/2022 7:35	<0.500		
Hunters Bend ES	WC-29-FD	4/28/2022 7:36	<0.500		
Hunters Bend ES	SOW-30-FD	4/28/2022 7:39	<b>1.89</b>		
Hunters Bend ES	SOW-45-FD	4/28/2022 7:41	<b>20.3</b>	5/24/2022 7:05	<b>0.956</b>
Hunters Bend ES	SOW-46-FD	4/28/2022 7:43	<0.500		
Hunters Bend ES	WC-34-FD	4/28/2022 7:46	<0.500		
Hunters Bend ES	WC-35-FD	4/28/2022 7:47	<0.500		
Hunters Bend ES	SOW-47-FD	4/28/2022 7:48	<b>1.17</b>		
Hunters Bend ES	SOW-48-FD	4/28/2022 7:50	<b>2.91</b>		
Hunters Bend ES	WC-24-FD	4/28/2022 7:51	<0.500		
Hunters Bend ES	WC-25-FD	4/28/2022 7:53	<0.500		
Hunters Bend ES	SOW-49-FD	4/28/2022 7:55	<b>0.695</b>		
Hunters Bend ES	SOW-50-FD	4/28/2022 7:58	<b>0.931</b>		
Hunters Bend ES	SOW-51-FD	4/28/2022 7:59	<b>0.979</b>		
Hunters Bend ES	FB-01	4/28/2022 8:04	<0.500		
Liscomb ES	KT-2-FD	4/26/2022 7:26	<0.500		
Liscomb ES	KT-2-FD-D	4/26/2022 7:26	<0.500		
Liscomb ES	WC-21-FD	4/26/2022 7:29	<0.500		
Liscomb ES	WC-22-FD	4/26/2022 7:30	<0.500		
Liscomb ES	SOW-46-FD	4/26/2022 7:33	<0.500		
Liscomb ES	SOW-47-FD	4/26/2022 7:36	<0.500		
Liscomb ES	SOW-48-FD	4/26/2022 7:39	<0.500		

WCS Drinking Water Sampling Results Summary  
April-May 2022

School	Sample Id	Sampled DateTime	Result (ppb)	Resample DateTime	Resample Result
Liscomb ES	SOW-25-FD	4/26/2022 7:40	<0.500		
Liscomb ES	SOW-42-FD	4/26/2022 7:42	<0.500		
Liscomb ES	SOW-43-FD	4/26/2022 7:43	<0.500		
Liscomb ES	WC-30-FD	4/26/2022 7:45	<0.500		
Liscomb ES	SOW-44-FD	4/26/2022 7:47	<b>0.972</b>		
Liscomb ES	SOW-31-FD	4/26/2022 7:50	<0.500		
Liscomb ES	SOW-9-FD	4/26/2022 7:51	<0.500		
Liscomb ES	WC-35-FD	4/26/2022 7:53	<0.500		
Liscomb ES	WC-36-FD	4/26/2022 7:54	<0.500		
Liscomb ES	SOW-6-FD	4/26/2022 7:56	<0.500		
Liscomb ES	SOW-37-FD	4/26/2022 7:59	<0.500		
Liscomb ES	WC-37-FD	4/26/2022 8:00	<0.500		
Liscomb ES	WC-38-FD	4/26/2022 8:01	<b>0.698</b>		
Liscomb ES	SOW-40-FD	4/26/2022 8:03	<0.500		
Liscomb ES	SOW-4-D	4/26/2022 8:05	<0.500		
Liscomb ES	SOW-45-FD	4/26/2022 8:08	<0.500		
Liscomb ES	SOW-41-FD	4/26/2022 8:09	<0.500		
Liscomb ES	FB-01	4/26/2022 8:15	<0.500		
OakView ES	KT-02-FD	4/12/2022 6:36	<0.500		
OakView ES	TL-40-FD	4/12/2022 6:38	<0.500		
OakView ES	NS-57-FD	4/12/2022 6:40	<0.500		
OakView ES	WC-45-FD	4/12/2022 6:43	<0.500		
OakView ES	WC-10-FD	4/12/2022 6:45	<0.500		
OakView ES	SOW-46-FD	4/12/2022 6:49	<b>0.859</b>		
OakView ES	SOW-47-FD	4/12/2022 6:51	<b>1.37</b>		
OakView ES	WC-50-FD	4/12/2022 6:53	<0.500		
OakView ES	WC-16-FD	4/12/2022 6:55	<0.500		
OakView ES	SOW-05-FD	4/12/2022 6:59	<0.500		
OakView ES	SOW-15-FD	4/12/2022 7:01	<b>0.651</b>		
OakView ES	SOW-19-FD	4/12/2022 7:04	<0.500		
OakView ES	SOW-53-FD	4/12/2022 7:06	<0.500		
OakView ES	SOW-04-FD	4/12/2022 7:09	<b>1.33</b>		
OakView ES	SOW-14-FD	4/12/2022 7:11	<0.500		
OakView ES	WC-07-FD	4/12/2022 7:13	<0.500		
OakView ES	WC-58-FD	4/12/2022 7:14	<0.500		
OakView ES	SOW-42-FD	4/12/2022 7:16	<0.500		
OakView ES	SOW-26-FD	4/12/2022 7:20	<0.500		
OakView ES	SOW-03-FD	4/12/2022 7:23	<0.500		
OakView ES	SOW-13-FD	4/12/2022 7:26	<0.500		
OakView ES	SOW-13-FD-D	4/12/2022 7:26	<b>0.522</b>		
OakView ES	SOW-11-FD	4/12/2022 7:29	<b>0.535</b>		
OakView ES	SOW-12-FD	4/12/2022 7:31	<0.500		
OakView ES	FB-01	4/12/2022 7:42	<0.500		
Page HS	FB-01	4/19/2022 6:06	<0.500		
Page HS	WC-43-FD	4/19/2022 6:12	<0.500		
Page HS	WC-44-FD	4/19/2022 6:14	<0.500		
Page HS	WC-45-FD	4/19/2022 6:18	<0.500		
Page HS	WC-46-FD	4/19/2022 6:19	<0.500		
Page HS	TL-47-FD	4/19/2022 6:22	<0.500		
Page HS	WC-48-FD	4/19/2022 6:24	<0.500		
Page HS	WC-49-FD	4/19/2022 6:27	<0.500		
Page HS	WC-36-FD	4/19/2022 6:30	<0.500		
Page HS	WC-37-FD	4/19/2022 6:32	<b>0.522</b>		
Page HS	WC-50-FD	4/19/2022 6:34	<0.500		
Page HS	WC-51-FD	4/19/2022 6:36	<0.500		
Page HS	WC-52-FD	4/19/2022 6:39	<0.500		
Page HS	WC-53-FD	4/19/2022 6:40	<b>1.37</b>		
Page HS	WC-54-FD	4/19/2022 6:45	<0.500		
Page HS	WC-55-FD-D	4/19/2022 6:46	<0.500		
Page HS	WC-55-FD	4/19/2022 6:46	<0.500		
Page HS	TL-56-FD	4/19/2022 6:50	<0.500		
Page HS	KT-02-FD	4/19/2022 6:55	<0.500		
Page HS	WC-01-FD	4/19/2022 6:58	<b>0.962</b>		
Page HS	WC-57-FD	4/19/2022 7:00	<0.500		



WCS Drinking Water Sampling Results Summary  
April-May 2022

School	Sample Id	Sampled DateTime	Result (ppb)	Resample DateTime	Resample Result
Page HS	WC-22-FD	4/19/2022 7:03	<0.500		
Page HS	WC-21-FD	4/19/2022 7:05	<b>3.78</b>		
Page HS	KT-58-FD	4/19/2022 7:07	<b>0.564</b>		
Page HS	WC-59-FD	4/19/2022 7:12	<0.500		
Page MS	FB-01	4/19/2022 7:24	<0.500		
Page MS	WC-25-FD	4/19/2022 7:31	<0.500		
Page MS	WC-24-FD	4/19/2022 7:32	<0.500		
Page MS	WC-23-FD	4/19/2022 7:34	<b>1.32</b>		
Page MS	WC-20-FD	4/19/2022 7:35	<0.500		
Page MS	KT-22-FD	4/19/2022 7:39	<b>0.969</b>		
Page MS	WC-33-FD	4/19/2022 7:42	<b>0.678</b>		
Page MS	TL-34-FD	4/19/2022 7:44	<0.500		
Page MS	WC-35-FD	4/19/2022 7:46	<0.500		
Page MS	WC-36-FD	4/19/2022 7:47	<0.500		
Page MS	TL-37-FD	4/19/2022 7:49	<0.500		
Page MS	WC-38-FD	4/19/2022 7:52	<0.500		
Page MS	WC-39-FD	4/19/2022 7:53	<0.500		
Page MS	WC-40-FD	4/19/2022 7:56	<0.500		
Page MS	TL-41-FD-D	4/19/2022 7:59	<0.500		
Page MS	TL-41-FD	4/19/2022 7:59	<0.500		
Page MS	WC-42-FD	4/19/2022 8:04	<0.500		
Page MS	WC-43-FD	4/19/2022 8:06	<0.500		
Page MS	WC-44-FD	4/19/2022 8:09	<0.500		
Page MS	TL-45-FD	4/19/2022 8:11	<b>0.967</b>		
Page MS	WC-46-FD	4/19/2022 8:13	<0.500		
Page MS	WC-31-FD	4/19/2022 8:17	<0.500		
Page MS	WC-30-FD	4/19/2022 8:19	<b>1.22</b>		
Page MS	WC-27-FD	4/19/2022 8:21	<0.500		
Page MS	WC-03-FD	4/19/2022 8:23	<b>0.632</b>		
Pinewood ES	FB-01	5/5/2022 7:24	<0.500		
Pinewood ES	WC-04-FD	5/5/2022 7:25	<0.500		
Pinewood ES	WC-24-FD	5/5/2022 7:31	<b>1.66</b>		
Renaissance HS	FB-01	4/12/2022 6:01	<0.500		
Renaissance HS	WC-06-FD	4/12/2022 6:12	<0.500		
Renaissance HS	WC-01-FD	4/12/2022 6:14	<0.500		
Renaissance HS	WC-07-FD	4/12/2022 6:16	<0.500		
Renaissance HS	WC-04-FD	4/12/2022 6:17	<0.500		
Renaissance HS	WC-02-FD	4/12/2022 6:19	<0.500		
Renaissance HS	WC-05-FD	4/12/2022 6:22	<0.500		
Renaissance HS	WC-05-FD-D	4/12/2022 6:22	<0.500		
Scales ES	FB-01	4/21/2022 6:03	<0.500		
Scales ES	WC-40-FD	4/21/2022 6:15	<0.500		
Scales ES	WC-41-FD	4/21/2022 6:16	<0.500		
Scales ES	SOW-25-FD	4/21/2022 6:20	<b>1.05</b>		
Scales ES	SOW-29-FD	4/21/2022 6:23	<b>2.4</b>		
Scales ES	SOW-30-FD	4/21/2022 6:25	<b>1.01</b>		
Scales ES	SOW-04-FD	4/21/2022 6:27	<b>1.59</b>		
Scales ES	WC-13-FD	4/21/2022 6:29	<0.500		
Scales ES	WC-43-FD	4/21/2022 6:31	<0.500		
Scales ES	WC-20-FD	4/21/2022 6:32	<0.500		
Scales ES	WC-15-FD	4/21/2022 6:33	<0.500		
Scales ES	WC-42-FD	4/21/2022 6:34	<0.500		
Scales ES	SOW-16-FD	4/21/2022 6:36	<0.500		
Scales ES	SOW-17-FD	4/21/2022 6:38	<0.500		
Scales ES	WC-18-FD	4/21/2022 6:39	<0.500		
Scales ES	WC-45-FD	4/21/2022 6:41	<0.500		
Scales ES	SOW-07-FD	4/21/2022 6:43	<0.500		
Scales ES	KT-02-FD	4/21/2022 6:45	<0.500		
Scales ES	KT-02-FD-D	4/21/2022 6:45	<0.500		
Scales ES	WC-46-FD	4/21/2022 6:47	<0.500		
Scales ES	WC-21-FD	4/21/2022 6:49	<0.500		
Scales ES	WC-47-FD	4/21/2022 6:51	<0.500		
Scales ES	WC-22-FD	4/21/2022 6:53	<0.500		
Scales ES	WC-48-FD	4/21/2022 6:55	<0.500		

WCS Drinking Water Sampling Results Summary  
April-May 2022

School	Sample Id	Sampled DateTime	Result (ppb)	Resample DateTime	Resample Result
Scales ES	WC-23-FD	4/21/2022 6:56	<0.500		
Trinity ES	WC-43-FD	4/28/2022 6:01	<0.500		
Trinity ES	WC-44-FD	4/28/2022 6:02	<0.500		
Trinity ES	WC-45-FD	4/28/2022 6:03	<b>0.889</b>		
Trinity ES	SOW-46-FD	4/28/2022 6:05	<b>8.95</b>		
Trinity ES	SOW-28-FD	4/28/2022 6:06	<0.500		
Trinity ES	WC-47-FD	4/28/2022 6:08	<0.500		
Trinity ES	WC-05-FD	4/28/2022 6:10	<0.500		
Trinity ES	WC-20-FD	4/28/2022 6:11	<0.500		
Trinity ES	SOW-21-FD	4/28/2022 6:13	<0.500		
Trinity ES	SOW-22-FD	4/28/2022 6:15	<b>0.621</b>		
Trinity ES	SOW-24-FD	4/28/2022 6:16	<0.500		
Trinity ES	WC-29-FD	4/28/2022 6:18	<0.500		
Trinity ES	WC-30-FD	4/28/2022 6:19	<0.500		
Trinity ES	SOW-31-FD	4/28/2022 6:22	<b>2.81</b>		
Trinity ES	SOW-32-FD	4/28/2022 6:24	<0.500		
Trinity ES	WC-35-FD	4/28/2022 6:27	<0.500		
Trinity ES	WC-34-FD	4/28/2022 6:29	<0.500		
Trinity ES	SOW-36-FD	4/28/2022 6:31	<b>2.44</b>		
Trinity ES	SOW-48-FD	4/28/2022 6:34	<0.500		
Trinity ES	WC-39-FD	4/28/2022 6:37	<0.500		
Trinity ES	WC-40-FD	4/28/2022 6:39	<0.500		
Trinity ES	KT-49-FD	4/28/2022 6:40	<0.500		
Trinity ES	KT-49-FD-D	4/28/2022 6:40	<0.500		
Trinity ES	TL-41-FD	4/28/2022 6:44	<0.500		
Trinity ES	FB-01	4/28/2022 6:47	<0.500		
Walnut Grove ES	WC-04-FD	4/21/2022 7:11	<0.500		
Walnut Grove ES	WC-05-FD	4/21/2022 7:12	<0.500		
Walnut Grove ES	WC-28-FD	4/21/2022 7:14	<0.500		
Walnut Grove ES	WC-29-FD	4/21/2022 7:15	<0.500		
Walnut Grove ES	WC-32-FD	4/21/2022 7:17	<0.500		
Walnut Grove ES	WC-33-FD	4/21/2022 7:19	<0.500		
Walnut Grove ES	WC-34-FD	4/21/2022 7:20	<0.500		
Walnut Grove ES	WC-35-FD	4/21/2022 7:22	<0.500		
Walnut Grove ES	WC-36-FD	4/21/2022 7:23	<0.500		
Walnut Grove ES	WC-37-FD	4/21/2022 7:25	<0.500		
Walnut Grove ES	SOW-41-FD	4/21/2022 7:26	<b>14.7</b>		
Walnut Grove ES	SOW-40-FD	4/21/2022 7:29	<b>6.73</b>		
Walnut Grove ES	SOW-42-FD	4/21/2022 7:31	<0.500		
Walnut Grove ES	SOW-39-FD	4/21/2022 7:33	<b>7.88</b>		
Walnut Grove ES	WC-43-FD	4/21/2022 7:35	<0.500		
Walnut Grove ES	WC-44-FD	4/21/2022 7:37	<0.500		
Walnut Grove ES	WC-45-FD	4/21/2022 7:40	<0.500		
Walnut Grove ES	WC-05-FD	4/21/2022 7:42	<0.500		
Walnut Grove ES	WC-42-FD	4/21/2022 7:46	<0.500		
Walnut Grove ES	WC-43-FD	4/21/2022 7:47	<0.500		
Walnut Grove ES	TL-26-FD	4/21/2022 7:50	<0.500		
Walnut Grove ES	TL-26-FD-D	4/21/2022 7:50	<0.500		
Walnut Grove ES	KT-22-FD	4/21/2022 7:57	<b>0.907</b>		
Walnut Grove ES	KT-23-FD	4/21/2022 7:58	<0.500		
Walnut Grove ES	FB-01	4/21/2022 8:02	<0.500		
Woodland MS	FB-01	4/21/2022 5:55	<0.500		
Woodland MS	WC-04-FD	4/21/2022 6:15	<0.500		
Woodland MS	WC-22-FD	4/21/2022 6:17	<0.500		
Woodland MS	KT-03-FD	4/21/2022 6:19	<b>0.659</b>		
Woodland MS	WC-36-FD	4/21/2022 6:22	<0.500		
Woodland MS	WC-37-FD	4/21/2022 6:23	<0.500		
Woodland MS	WC-06-FD	4/21/2022 6:26	<0.500		
Woodland MS	WC-39-FD	4/21/2022 6:28	<0.500		
Woodland MS	WC-35-FD	4/21/2022 6:30	<0.500		
Woodland MS	WC-34-FD	4/21/2022 6:30	<0.500		
Woodland MS	WC-33-FD	4/21/2022 6:33	<0.500		
Woodland MS	WC-40-FD	4/21/2022 6:35	<0.500		
Woodland MS	WC-32-FD	4/21/2022 6:35	<0.500		

WCS Drinking Water Sampling Results Summary  
April-May 2022

School	Sample Id	Sampled DateTime	Result (ppb)	Resample DateTime	Resample Result
Woodland MS	WC-31-FD	4/21/2022 6:39	<0.500		
Woodland MS	WC-05-FD	4/21/2022 6:40	<0.500		
Woodland MS	KT-41-FD	4/21/2022 6:42	<0.500		
Woodland MS	TL-42-FD	4/21/2022 6:46	<0.500		
Woodland MS	WC-29-FD	4/21/2022 6:48	<0.500		
Woodland MS	WC-30-FD	4/21/2022 6:50	<0.500		
Woodland MS	WC-30-FD-D	4/21/2022 6:50	<0.500		
Woodland MS	WC-28-FD	4/21/2022 6:54	<0.500		
Woodland MS	WC-27-FD	4/21/2022 6:54	<0.500		
Woodland MS	WC-25-FD	4/21/2022 6:57	<0.500		
Woodland MS	WC-43-FD	4/21/2022 7:01	<0.500		
Woodland MS	KT-44-FD	4/21/2022 7:03	9.19		

**Result >15 ppb**

**Result >10 ppb**

**Result 5-10 ppb**

**Result <5 ppb**

Non-detect (<0.500)