

ADDENDUM 4

To: Prospective Bidders
From: Matt Campbell, Project Manager
Subject: Williamson County Schools- RFB #1204

Date: April 23, 2020

Failure of any Bidder to receive this addendum shall not relieve such Bidder from any obligation under his bid as submitted.

Question from Bidder:

- 1. Q:** During pre-bid meeting, it was asked if 1.5" milling around the catch basins would eliminated the need for the adjustment item. It is my understanding the milling would be acceptable to WCS. If this assumption is correct, will you please adjust the pay quantity for ADJUSTMENT OF CATCH BASINS to only those that are outside of the milling or undercutting areas? This will allow the contractor to accurately price this scope based on the actual anticipated quantity.

A: No adjustment will be made to the estimate quantity total for SP-2 Adjustment of Catch Basin. Quantity will remain at 85 paid per each.
Yes, milling is acceptable. However, just because a catch basin is located in a designated milling or undercut area, doesn't automatically exclude it from not being adjusted. If there is a drainage issue that can't be addressed by milling alone, then the contractor will be instructed to adjust. As previously stated, this is site and condition dependent.