ENTECH

CONSULTING ENGINEERS

5301 VIRGINIA WAY, SUITE 140

BRENTWOOD, TENNESSEE 37027

PHONE: (615)373-2640 FAX: (615)373-4837

ADDENDUM NO. 1

DATE: April 22, 2020

TO: All Plan Holders of Record

PROJECT: Williamson County Schools

Boiler Replacements at Edmondson, Grassland, Hunters Bend, Lipscomb, Oak View and

Winstead Elementary Schools

WCS RFB#1207 EEI#19-194

The following amendments clarify, modify, change, delete from or add to the Bidding Documents for the referenced project. Where any portion of a document, specification or drawing is modified or deleted by these amendments, the unaltered portions of the document, specification or drawing shall remain in effect.

CHANGES TO THE SPECIFICATIONS

SECTION 00301 BID ADVERTISEMENT

Add ADDENDUM – Electronic Bid Opening Zoom Conference Instructions (attached).

SECTION 15540 HVAC PUMPS

1. Add paragraph 2.2-A.-2.-c) Grundfos Magna3

SECTION 15558 CONDENSING FIRE TUBE BOILERS

1. Add paragraph 1.9 – E. Laars.

CHANGES TO THE DRAWINGS

SHEET M1.1 HVAC LEGENDS & SCHEDULES

1. Reference GAS UNIT HEATER SCHEDULE: Add note just below schedule: ACCEPTABLE MANUFACTURERS OFFERING SIMILAR PRODUCTS: MODINE, STERLING.

End of Addendum No. 1

Purchasing
Department 1320 West Main
Street Suite 202 Franklin,
Tennessee 37064-3700
Phone (615) 4724010 Fax (615)
472-5609



ADDENDUM Electronic Bid Opening Zoom Conference Instructions

During the conference call all of the electronic bids that are submitted properly will be read out loud.

Bidders must follow the instructions in the Invitation to Bid to submit a bid.

Williamson County Schools RFB #1207

Boiler Replacements at Edmondson, Grassland, Hunters Bend, Lipscomb, Oak View and Winstead Elementary Schools.

TOPIC: RFB # 1207 Boiler Replacements on Friday, April 24, 2020

TIME: Bids are due and must be received via email no later than 10:30 AM.

The bid opening Zoom Conference Call will start promptly at 11:00 AM. This allows WCS a 30 minute time frame for printing, checking the requirements and organizing the bids before they are read out loud at 11:00 am during the conference call.

11:00 AM Central Time (US and Canada) Join Zoom Meeting

https://wcs.zoom.us/j/97349367526?pwd=ZTYvQisvWnVxMmFneUxpSmNaTUJkZz0

9

MEETING ID: 973 4936 7526

PASSWORD: 154852

Dial this number +1 301 715 8592 US

Please contact the offices of the project Engineer for further information regarding this addendum. The Engineers address, and phone number are listed below:

Entech Engineering Ben Hunter, Engineer 5301 Virginia Way, Suite 140 Brentwood, TN 37027

Phone 615-373-2640 <u>bhunter@entechtn.com</u>