

Purchasing Department
1320 West Main Street, Suite 202
Franklin, TN 37064-3700
Phone (615)-472-4079
Fax (615)-595-4869



ADDENDUM I

RFB # 1298

WILLIAMSON COUNTY SCHOOLS

HVAC Safety Platforms at the following 11 schools:

Franklin High (2) Brentwood High (2) College Grove Elementary (1) Edmondson Elementary (1)
Grassland Elementary (1) Heritage Middle (2) Hunters Bend Elementary (1)
Kenrose elementary (1) Lipscomb Elementary (1) Oak View Elementary (1)
Scales Elementary (1)

THIS ADDENDUM IS BEING DISTRIBUTED AT 3:30 PM ON SEPT. 15, 2022

WCS Conducted a Pre-Bid for RFB # 1298 HVAC Safety Platforms this morning at 10:00 AM. During the meeting a question was asked that is being addressed in this Addendum I.

Question:

During the installation of the safety platforms, if a fire sprinkler head or pipe needs to be relocated during the project what should the awarded bidder do?

Answer:

If a fire sprinkler head or pipe requires modification this shall be identified to the WCS Maintenance Assistant Director who will in turn work with a certifier provider to accomplish this modification.