

Facilities & Construction Division
1320 West Main Street, Suite 202
Franklin, TN 37064-3700
Tel. (615)-472-4041
Email: eric.gardner@wcs.edu



October 24, 2024

TO: All Potential Bidders

**RE: Addendum #2
RFB #1354 Mill Creek Middle School Softball Field Lighting and Upgrades**

CLARIFICATIONS

Q: Can we provide our galvanized steel pole on a Pre-Stressed concrete base as recommended by TSSAA Lighting Standards? Will a stamped structural drawing need to be provided meeting current Tennessee code?

A: **The current design indicates to match the existing poles that are installed on site currently. Alternates are not acceptable.**

Q: I see a 10-year warranty is in the drawings. Is these Parts only or Parts and Labor?

A: **The 10-year warranty is for Parts and Labor.**

Q: I didn't see any controls called out. Just want to clarify that.

A: **The current bid documents indicate a separate keyed override switch for the softball field lighting and would leave the multi-purpose field on its own switch. Refer to key notes for contactor make and model.**