

# RCR&A

**RICHARD C. RINKS & ASSOCIATES, INC.**

**Engineering and Architectural Services**

**Building Enclosure Consultants**

**ASCE - NSPE - TSPE - IIBEC - EDI**

30 North Jefferson Avenue - P.O. Box 691 - Cookeville, Tennessee 38503-0691

Telephone 931-528-5543 Rinks-Consulting.com Facsimile 931-528-5544

## **ADDENDUM 1**


### **ROOF REPLACEMENT PORTION OF FIVE SCHOOLS WILLIAMSON COUNTY SCHOOLS APRIL 21, 2025**

1. Minutes from Pre-Bid Meeting dated April 10, 2025 are hereby made a part of the Contract Documents.
2. Refer to WCS Legal Notice Request for Bids in Specifications: Change Friday, April 24, 2025 to Friday, April 25, 2025.
3. Refer to Sections 07605 and 07610: Metal Roofing Systems, Inc. is an approved equal for wall (MRS System 1000), roof (MRS System 2500) and soffit panels (MRS Flush Seam). The standing seam roof panels shall be double lock mechanically seamed.
4. Refer to Sheet R6: HVAC Contractor will be adding 7 C1's southwest of existing C1's for new platform. Contractor shall flash C1's per Detail 7/011. New platform will be approximately 30'-0" x 2'-6" and 2'-6" above the roof.
5. See attached Clarifications.
6. Contractor shall acknowledge receipt of this addendum on Bid Form.

END OF ADDENDUM

Attachment: Clarifications

\\wcs-25\\addendum1.doc



**CLARIFICATIONS  
ROOF REPLACEMENT  
PORTION OF FIVE SCHOOLS  
WILLIAMSON COUNTY SCHOOLS  
APRIL 21, 2025**

Q: Can Metal Roofing Systems, Inc. Rapid Lock Fascia detail be used on this Project?

**A: No, we prefer the anchor bar edge detail.**